

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: SR-000012	Report No: Service	Visit Date: 2026-07-28	Complaint No: 4	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
CHINNAPURAM	Service		Checking filters and replacing 1 mcf and cleaning filters and observation of all leakages good and Checking fr good	
		SPARES REQUIRED: 1.mcf		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	CHINNAPURAM	Raw Water TDS	1372	
Plant Capacity	100lph	Product Water TDS	105	
Design R/W TDS	1372	Product Water Flow in LPH	100.0	
Free Chlorine in R/W	No	Sensors Condition	OK	
No. of Hours Running	2hrs	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	24	
SPARES CONSUMED				
1.mcf				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Chinnapuram 7013630083			(no stamp on file)	
SERVICE ENGINEER: SUNNY		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623