

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: Sr 001	Visit Date: 2026-07-28	Complaint No: 001	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
srikahasthi temple	MPV problem		Leakage arrested	
	SPARES REQUIRED: Teflon tap			
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	srikahasthi temple	Raw Water TDS	299	
Plant Capacity	1000 lph	Product Water TDS	55	
Design R/W TDS	55	Product Water Flow in LPH	1000.0	
Free Chlorine in R/W	100 mg	Sensors Condition	OK	
No. of Hours Running	1 hrs	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	219.0	
UV Lamp Condition	OK	Current in Amps	14.5	
SPARES CONSUMED				
Teflon tap				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Naveen 9848999552			(no stamp on file)	
SERVICE ENGINEER: KASI SANTOSH		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: No remark				