

# SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

## WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

|                                        |                          |                                      |                                                                                                 |                       |
|----------------------------------------|--------------------------|--------------------------------------|-------------------------------------------------------------------------------------------------|-----------------------|
| <b>Serial No: PENDING VERIFICATION</b> | <b>Report No: 1</b>      | <b>Visit Date: 2026-07-28</b>        | <b>Complaint No: 1</b>                                                                          | <b>Unit Type: AMC</b> |
| <b>CUSTOMER NAME &amp; ADDRESS:</b>    | <b>PROBLEM REPORTED:</b> |                                      | <b>OBSERVATION &amp; ACTION TAKEN:</b>                                                          |                       |
| ZPHS VERRAREDDYPALLY                   | Visit Amc                |                                      | Water leakage solved,mcf cheking,tds chek, product flow chek,ro plant running is good condition |                       |
|                                        |                          | <b>SPARES REQUIRED: -</b>            |                                                                                                 |                       |
| <b>UNIT DETAILS / SITE CONDITION</b>   |                          |                                      | <b>PLANT READINGS</b>                                                                           |                       |
| <b>Plant Location</b>                  | ZPHS VERRAREDDYPALLY     | <b>Raw Water TDS</b>                 | 410                                                                                             |                       |
| <b>Plant Capacity</b>                  | 50                       | <b>Product Water TDS</b>             | 60                                                                                              |                       |
| <b>Design R/W TDS</b>                  | 2000                     | <b>Product Water Flow in LPH</b>     | 50.0                                                                                            |                       |
| <b>Free Chlorine in R/W</b>            | Nil                      | <b>Sensors Condition</b>             | OK                                                                                              |                       |
| <b>No. of Hours Running</b>            | 2                        | <b>Pre-Filter Condition</b>          | OK                                                                                              |                       |
| <b>Membrane Condition</b>              | OK                       | <b>Voltage</b>                       | 230.0                                                                                           |                       |
| <b>UV Lamp Condition</b>               | OK                       | <b>Current in Amps</b>               | 2.4                                                                                             |                       |
| <b>SPARES CONSUMED</b>                 |                          |                                      |                                                                                                 |                       |
| -                                      |                          |                                      |                                                                                                 |                       |
| <b>CUSTOMER NAME / MOBILE NUMBER</b>   |                          | <b>CUSTOMER SIGNATURE &amp; DATE</b> |                                                                                                 | <b>SCHOOL STAMP</b>   |
| B Sathyam 9666555360                   |                          |                                      |                                                                                                 | (no stamp on file)    |
| <b>SERVICE ENGINEER: MAHESH</b>        |                          |                                      | <b>STATUS: PROBLEM RESOLVED</b>                                                                 |                       |
| <b>SERVICE ENGINEER SIGNATURE:</b>     |                          |                                      |                                                                                                 |                       |
| <b>Customer Remarks: —</b>             |                          |                                      |                                                                                                 |                       |

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623