

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: PENDING VERIFICATION	Report No: .	Visit Date: 2026-07-12	Complaint No: .	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
GOVT. HS RAMANNAPET	.		.	
	SPARES REQUIRED: .			
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	GOVT. HS RAMANNAPET	Raw Water TDS	69	
Plant Capacity	.	Product Water TDS	69	
Design R/W TDS	.	Product Water Flow in LPH	69.0	
Free Chlorine in R/W	.	Sensors Condition	OK	
No. of Hours Running	.	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	69.0	
UV Lamp Condition	OK	Current in Amps	69	
SPARES CONSUMED				
.				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
GK 6969696969			(no stamp on file)	
SERVICE ENGINEER: GANESH		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623