

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: B	Visit Date: 2026-07-12	Complaint No: B	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
KGBV ATHMAKUR(M)	B		H	
	SPARES REQUIRED: B			
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	KGBV ATHMAKUR(M)	Raw Water TDS	9	
Plant Capacity	B	Product Water TDS	9	
Design R/W TDS	B	Product Water Flow in LPH	8.0	
Free Chlorine in R/W	G	Sensors Condition	OK	
No. of Hours Running	B	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	8.0	
UV Lamp Condition	OK	Current in Amps	5	
SPARES CONSUMED				
B				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Ff Cc			(no stamp on file)	
SERVICE ENGINEER: GANESH		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: Fg				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623