

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: SR-000004	Report No: 01	Visit Date: 2026-07-17	Complaint No: 01	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
MPPS KASHAVARI GUDEM (V)	Water leakage		Plant cheking and tds cheking and	
	SPARES REQUIRED: Mcf			
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	MPPS KASHAVARI GUDEM (V)	Raw Water TDS	250	
Plant Capacity	50lph	Product Water TDS	63	
Design R/W TDS	1500	Product Water Flow in LPH	50.0	
Free Chlorine in R/W	-	Sensors Condition	OK	
No. of Hours Running	3hr	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	24	
SPARES CONSUMED				
Mcf				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Madhu 9391756228			(no stamp on file)	
SERVICE ENGINEER: MADHU		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623