

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: PENDING VERIFICATION	Report No: 001	Visit Date: 2026-07-18	Complaint No: 01	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
—	Filter s problem		Plant checking filter s changed	
		SPARES REQUIRED: 2		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	—	Raw Water TDS	771	
Plant Capacity	2000	Product Water TDS	78	
Design R/W TDS	2000	Product Water Flow in LPH	1200.0	
Free Chlorine in R/W	-	Sensors Condition	OK	
No. of Hours Running	5	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	440.0	
UV Lamp Condition	OK	Current in Amps	12	
SPARES CONSUMED				
2				
CUSTOMER NAME / MOBILE NUMBER		CUSTOMER SIGNATURE & DATE		SCHOOL STAMP
Md thafiq 9640906451				(no stamp on file)
SERVICE ENGINEER: KAMALAKAR			STATUS: PROBLEM RESOLVED	
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623