Table of Contents

Purpose/Policy:.....1

Scope:.....2

Definitions/Acronyms:.....2

Authorities/Responsibilities:.....2

Resources and Materials:.....2

PPE Required:.....2

Procedures:.....2

Turning off Glycol to a Bright Tank:.....2

Turning off Glycol to a Fermenter Tank:.....3

Turning off Glycol to a Pilot Bright Tank:.....3

Forms:.....3

Reference Documents:.....3

Common Issues:.....3

Document History and Approval:.....3

Purpose/Policy:

This is SOP will direct a lead operator through turning Glycol off for either a bright beer tank or a fermenter. The Majority of our tank's glycol is controlled through Braumat. Some of our pilot bright tanks have their glycol control on the side of the tans.

Scope:

Lead operators turning glycol off to a bright beer tank, a fermenter, or a pilot bright tank, using Braumat or the controls on the side of the pilot bright tanks.

Definitions/Acronyms:

- SOP – Standard Operating Procedure
- PPE – Personal Protective Equipment
- CIP – Cleaning in Process
- Braumat – Control system that runs glycol to most of the tanks
- Glycol – Cooling liquid that controls tank temperature

Authorities/Responsibilities:

Once a tank is kicked or is cleared to be dumped it is the responsibility of the lead operator to turn the glycol off on the tank.

Resources and Materials:

Operations:

- Braumat login credentials

PPE Required:

- None.

Procedures:

Turning off Glycol to a Bright Tank:

1. Start by logging in to Braumat.
    1.1 To do this click the upper right box. Usually has the previous person's login name or it might be blank.
    1.2 This will prompt a new login window.
    1.3 Enter your username and password.
2. Once you're logged in click "Cellars".
3. Click the screen again and this will bring you to a list of tanks.
4. If you are turning a bright tank's glycol off, click the little hand next to the tank you want to turn off.
5. Next click the open loop button located next to the drop-down menu that says "Standard".
6. Click the play button and then another window will pop up with either "Okay" or "Cancel". Press "Okay".

7. This will prompt the system to go through several steps. The last step is “Idle”.
    7.1 If the system does not reach the “Idle” step you can right click on the CIP step and “Set token” and then press “Okay” when prompted. Then press the play button again and click “Okay”.
8. Once the system is done on the left side of the screen next to status it should say “Idle”.

Turning off Glycol to a Fermenter Tank:

1. If you are turning off a fermenter’s glycol follow step 1-2 of the previous section.
2. Click the group of tanks that has the fermenter you want to turn off.
3. Click the little hand next to the tank you want to turn off.
4. Next click the open loop button located next to the drop-down menu that says “Standard”.
5. Scroll over to the right.
6. Right click on the CIP step and “Set token” and then press “Okay” when prompted. Then press the play button again and click “Okay”.
7. This will prompt the system to go through several steps. The last step is “Idle”.
8. Once the system is done on the left side of the screen next to status it should say “Idle”.
9. Logout of Braumat once you are all set with it by clicking your username in the upper right corner.

Turning off Glycol to a Pilot Bright Tank:

1. Start by finding the temperature control unit on the side of the tank.
2. Press the play button on it until you find the temperature control screen.
3. Next press the up button until it reads 180.
4. Press the play button again until you get back to the home screen.

Forms:

Not Applicable

Reference Documents:

Not Applicable

Common Issues:

Not Applicable

Document History and Approval:

Revise document history as described in the table and key below.

(Reference to following document: B1C.SOP.P001: Document Control and Approval Procedure Template)

VERSION NO.	VERSION DATE	DESCRIPTION OF CHANGE	AUTHOR NAME/PROJECT MANAGER
001	2025/07/28		Kyle Szymanski
002	2026/10/26	Updated SOP to Newest Layout Version	Kyle Szymanski

Version Approval Number: 002

Approved by: Kyle Szymanski

Position Title: OSCI Manager

Date: 10/26/26