

MANGALORE REFINERY AND PETROCHEMICALS LIMITED
ROTATING EQUIPMENT CONDITION MONITORING REPORT

Report No : CM/CDU/2026/0847
Date : 12 September 2026
Unit : Crude Distillation Unit
Technician : R. Shetty (ID 4471)
Analyser : CSI 2140, S/N 88213, cal. valid to 2027-03

1. EQUIPMENT

Tag P-204
Description Crude Charge Pump B
Rated power 132 kW
Speed 2960 rpm
Condition Running, normal operating point

2. VIBRATION READINGS (RMS velocity, mm/s, 10-1000 Hz)

Point	Horiz	Vert	Axial
Pump drive end	8.2	7.4	3.1
Pump non-drive end	6.9	6.1	2.8
Motor drive end	4.4	3.9	2.2
Motor non-drive end	3.8	3.5	1.9

Previous month, pump drive end horizontal: 6.5
Reading after 2024-11 overhaul: 2.9

3. TEMPERATURE

Pump drive end bearing housing 79 deg C
Pump non-drive end bearing housing 74 deg C
Established baseline 61 deg C
Ambient 34 deg C

4. MECHANICAL SEAL

Visible leakage 3 drops per minute
Seal plan API Plan 11
Flush line Clear, no restriction observed

5. LUBRICATION

Oil level Within oiler marks
Oil condition Slight darkening, no water or metal visible

6. TECHNICIAN REMARKS

Drive end horizontal vibration has risen noticeably since the previous survey. Bearing housing temperature also elevated against baseline at comparable load. Recommend review against SOP-4 acceptance criteria.

Signature: R. Shetty