xrayutilities Documentation

Release 1.0.3

Dominik Kriegner Eugen Wintersberger

CONTENTS

1	Intro	oduction	3
	1.1	Concept of usage	4
	1.2	Angle calculation using the material classes	
	1.3	hello world	
2	xray	utilities Python package	9
3	Insta	allation	11
	3.1	Express instructions	11
	3.2	Detailed instructions	11
	3.3	Required third party software	11
	3.4	Building and installing the library and python package	
	3.5	Setup of the Python package	
	3.6	Notes for installing on Windows	
4	Exar	mples and API-documentation	15
	4.1	Examples	15
	4.2	xrayutilities Package	
	4.3	analysis Package	
	4.4	io Package	
	4.5	materials Package	
	4.6	math Package	
	4.7	xrayutilities	
5	Indic	ces and tables	165
Ру	thon I	Module Index	167
In	dex		169

If you look for downloading the package go to Sourceforge (source distribution) or the Python package index (MS Windows binary). Installation instructions you find further down Installation.

Read more about xrayutilities below or in Journal of Applied Crystallography 2013, Volume 46, 1162-1170

CONTENTS 1

2 CONTENTS


CHAPTER ONE

INTRODUCTION

xrayutilities is a collection of scripts used to analyze x-ray diffraction data. It consists of a python package and several routines coded in C. It especially useful for the reciprocal space conversion of diffraction data taken with linear and area detectors.

In the following two concepts of usage for the *xrayutilities* package will be described. First one should get a brief idea of how to analyze x-ray diffraction data with *xrayutilities*. After that the concept of how angular coordinates of Bragg reflections are calculated is presented.

1.1 Concept of usage



xrayutilities provides a set of functions to read experimental data from various data file formats. All of them are gathered in the io-subpackage. After reading data with a function from the io-submodule the data might be corrected for monitor counts and/or absorption factor of a beam attenuator. A special set of functions is provided to perform this for point, linear and area detectors.

Since the amount of data taken with modern detectors often is too large to be able to work with them properly, a functions for reducing the data from linear and area detectors are provided. They use block-averaging to reduce the amount of data. Use those carefully not to loose the features you are interested in in your measurements.


After the pre-treatment of the data, the core part of the package is the transformation of the angular data to reciprocal space. This is done as described in more detail below using the experiment-module'. The classes provided within the experiment module provide routines to help performing X-ray diffraction experiments. This includes methods to calculate the diffraction angles (described below) needed to align crystalline samples and to convert data between angular and reciprocal space. The conversion from angular to reciprocal space is implemented very general for various goniometer geometries. It is especially useful in combination with linear and area detectors as described in this article. In standard cases, Users will only need the initialized routines, which predefine a certain goniometer geometry like the popular four-circle and six-circle geometries.

After the conversion to reciprocal space, it is convenient to transform the data to a regular grid for visualization. For this purpose the gridder-module has been included into *xrayutilities*. For the visualization of the data in

reciprocal space the usage of matplotlib is recommended.

A practical example showing the usage is given below.

1.2 Angle calculation using the material classes



Materials in experiment for which Bragg peak position is needed

Experimental geometry in which Bragg peaks are measured

calculation of Q for Bragg reflection of the given materials

conversion of Q to angular coordinates for the specified experimental geometry

Calculation of angles needed to align Bragg reflections in various diffraction geometries is done using the Materials defined in the materials-package. This package provides a set of classes to describe crystal lattices and materials. Once such a material is properly defined one can calculate its properties, which includes the reciprocal lattice points, optical properties like the refractive index, the structure factor (including the atomic scattering factor) and the complex polarizability. These atomic properties are extracted from a database included in *xrayutilities*.

Using such a material and an experimental class from the experiment-module describing the experimental setup the needed diffraction angles can be calculated for certain coplanar diffraction (high, low incidence), grazing incidence diffraction and also special non-coplanar diffraction geometries.

1.3 hello world

A first example with step by step explanation is shown in the following. It showcases the use of *xrayutilities* to calculate angles and read a scan recorded with a linear detector from spec-file and plots the result as reciprocal space map using matplotlib.

```
Example script to show how to use xrayutilities to read and plot
reciprocal space map scans from a spec file created at the ESRF/ID10B

for details about the measurement see:
    D Kriegner et al. Nanotechnology 22 425704 (2011)
    http://dx.doi.org/10.1088/0957-4484/22/42/425704

"""

import numpy
import numpy
import matplotlib.pyplot as plt
import xrayutilities as xu
import os
```

```
14
   # global setting for the experiment
15
   sample = "test" # sample name used also as file name for the data file
16
   energy = 8042.5 \# x-ray energy in eV
17
   center_ch = 715.9 # center channel of the linear detector
18
   chpdeg = 345.28 # channels per degree of the linear detector
19
   roi=[100,1340] # region of interest of the detector
20
   nchannel = 1500 # number of channels of the detector
21
22
   # intensity normalizer function responsible for count time and absorber correction
   absfun = lambda d: d["detcorr"]/d["psd2"].astype(numpy.float)
24
   normalizer_detcorr = xu.IntensityNormalizer("MCA",mon="Monitor",time="Seconds",absfun=absfun)
25
26
   # substrate material used for Bragg peak calculation to correct for experimental offsets
27
  InP = xu.materials.InP
28
29
   # initialize experimental class to specify the reference directions of your crystal
30
  # 11-2: inplane reference
31
  # 111: surface normal
32
  hxrd = xu.HXRD(InP.Q(1,1,-2),InP.Q(1,1,1),en=energy)
34
   # configure linear detector
35
   # detector direction + parameters need to be given
36
   # mounted along z direction, which corresponds to twotheta
37
   hxrd.Ang2Q.init_linear('z-',center_ch,nchannel,chpdeg=chpdeg,roi=roi)
38
39
   # read spec file and save to HDF5-file
40
   # since reading is much faster from HDF5 once the data are transformed
41
   h5file = os.path.join("data", sample+".h5")
   try: s # try if spec file object already exist ("run -i" in ipython)
43
   except NameError: s = xu.io.SPECFile(sample+".spec",path="data")
   else: s.Update()
45
   s.Save2HDF5(h5file)
46
47
   ######################################
48
   # InP (333) reciprocal space map
49
   omalign = 43.0529 # experimental aligned values
50
   ttalign = 86.0733
51
   [omnominal, dummy, dummy, ttnominal] = hxrd.Q2Ang(InP.Q(3,3,3)) # nominal values of the substrate pe
52
  # read the data from the HDF5 file
  #(scan number: 36, names of motors in spec file: omega= sample rocking, gamma = twotheta)
  [om,tt],MAP = xu.io.geth5_scan(h5file,36,'omega','gamma')
  # normalize the intensity values (absorber and count time corrections)
57
  psdraw = normalizer_detcorr(MAP)
58
   # remove unusable detector channels/regions (no averaging of detector channels)
59
   psd = xu.blockAveragePSD(psdraw, 1, roi=roi)
60
61
   # convert angular coordinates to reciprocal space + correct for offsets
62
   [qx,qy,qz] = hxrd.Ang2Q.linear(om,tt,delta=[omalign-omnominal, ttalign-ttnominal])
63
   # calculate data on a regular grid of 200x201 points
   gridder = xu.Gridder2D(200,201)
   gridder(qy,qz,psd)
   # maplog function limits the shown dynamic range to 8 orders of magnitude from the maxium
   INT = xu.maplog(gridder.gdata.transpose(),8.,0)
70
   # plot the intensity as contour plot using matplotlib
71
  plt.figure()
72
  cf = plt.contourf(gridder.xaxis, gridder.yaxis,INT,100,extend='min')
74 plt.xlabel(r'$Q_{[11\bar2]}$ ($\AA^{-1}$)')
75 plt.ylabel(r'$Q_{[\bar1\bar1\bar1]}$ ($\AA^{-1}$)')
  cb = plt.colorbar(cf)
```

```
n cb.set_label(r"$\log($Int$)$ (cps)")
```

More such examples can be found on the *Examples* page.

1.3. hello world 7

XRAYUTILITIES PYTHON PACKAGE

xrayutilities is a Python package for assisting with x-ray diffraction experiments. Its the python package included in *xrayutilities*.

It helps with planning experiments as well as analyzing the data.

Authors Dominik Kriegner <dominik.kriegner@gmail.com> and Eugen Wintersberger <eugen.wintersberger@desy.de>

for more details see the full API documentation of xrayutilities found here: *Examples and API-documentation*.

INSTALLATION

3.1 Express instructions

- install the dependencies (Windows: pythonxy; Linux/Unix: see below for dependencies).
- download xrayutilities from here or use git to check out the latest version.
- open a command line and navigate to the downloaded sources and execute:
- > python setup.py install

which will install *xrayutilities* to the default directory. It should be possible to use it (*import xrayutilities*) from now on in python scripts.

Note: The python package of xrayutilities was formerly called "xrutils"

3.2 Detailed instructions

Installing *xrayutilities* is done using Python's distutils

The package can be installed on Linux, Mac OS X and Microsoft Windows, however it is mostly tested on Linux/Unix platforms. Please inform one of the authors in case the installation fails!

3.3 Required third party software

To keep the coding effort as small as possible *xrayutilities* depends on a large number of third party libraries and Python modules.

The needed dependencies are:

- GCC Gnu Compiler Collection or any compatible C compiler. On windows you most probably should use MinGW or CygWin. Others might work but are untested.
- **HDF5** a versatile binary data format (library is implemented in C). Although the library is not called directly, it is needed by the pytables Python module (see below).
- Python the scripting language in which most of xrayutilities code is written in.
- **git** a version control system used to keep track on the *xrayutilities* development. (only needed for development)

Additionally, the following Python modules are needed in order to make xrayutilities work as intended:

- Numpy a Python module providing numerical array objects
- Scipy a Python module providing standard numerical routines, which is heavily using numpy arrays

- Python-Tables a powerful Python interface to HDF5.
- Matplotlib a Python module for high quality 1D and 2D plotting (optionally)
- **IPython** although not a dependency of *xrayutilities* the IPython shell is perfectly suited for the interactive use of the *xrayutilities* python package.

After installing all required packages you can continue with installing and building the C library.

3.4 Building and installing the library and python package

xrayutilities uses the distutils packaging system to build and install all of its components. You can perform the installation by executing

```
>python setup.py install
or
>python setup.py install --prefix=INSTALLPATH
```

in the root directory of the source distribution.

The *-prefix* option sets the root directory for the installation. If it is omitted the libary is installed under /usr/lib/ on Unix systems or in the Python installation directory on Windows.

3.5 Setup of the Python package

You need to make your Python installation aware of where to look for the module. This is usually only needed when installing in non-standard *<install path>* locations. For this case append the installation directory to your *PYTHONPATH* environment variable by

```
>export PYTHONPATH=$PYTHONPATH:<local install path>/lib64/python2.7/site-packages
```

on a Unix/Linux terminal. Or, to make this configuration persistent append this line to your local *.bashrc* file in your home directory. On MS Windows you would like to create a environment variable in the system preferences under system in the advanced tab (Using pythonxy this is done automatically). Be sure to use the correct directory which might be similar to

```
<local install path>/Lib/site-packages
```

on Windows systems.

3.6 Notes for installing on Windows

Since there is no packages manager on Windows the packages need to be installed manual (including all the dependecies) or a pre-packed solution needs to be used. We strongly suggest to use the pyhton(x,y) python distribution, which includes already all of the needed dependencies for installing xrayutilities.

The setup of the environment variables is also done by the python(x,y) installation. One can proceed with the installation of *xrayutilities* directly! The easiest way to do this on windows is to use the binaries distributed on the Python package index, otherwise one can follow the general installation instructions. Depending on your compiler on Microsoft Windows it might be necessary to perform the building of the Python extension separately and specify the compiler manually. This is done by

```
python setup.py build -c <compiler_name>
```

Using Python(x,y) you want to specify "mingw32" as compiler name.

In case you want to do it the hard way install all of the following (versions in brackets indicate the tested set of versions by the

- MinGW (0.4alpha)
- Python (2.7.2)
- numpy (1.6.1)
- scipy (0.10.1)
- numexpr (1.4.2) needed for pytables
- pytables (2.3.1)
- matplotlib (1.1.0)
- ipython (0.12)

It is suggested to add the MinGW binary directory, as well as the Python and Python-scripts directory to the Path environment variable as described above! Installation is done as described above.

EXAMPLES AND API-DOCUMENTATION

4.1 Examples

In the following a few code-snippets are shown which should help you getting started with *xrayutilities*. Not all of the codes shown in the following will be run-able as stand-alone script. For fully running scripts look in the examples directory in the download found here.

4.1.1 Reading data from data files

The io submodule provides classes for reading x-ray diffraction data in various formats. In the following few examples are given.

Reading SPEC files

Working with spec files in xrayutilities can be done in two distinct ways.

- 1. parsing the spec file for scan headers; and parsing the data only when needed
- 2. parsing the spec file for scan headers; parsing all data and dump them to an HDF5 file; reading the data from the HDF5 file.

Both methods have their pros and cons. For example when you parse the spec-files over a network connection you need to re-read the data again over the network if using method 1) whereas you can dump them to a local file with method 2). But you will parse data of the complete file while dumping it to the HDF5 file.

Both methods work incremental, so they do not start at the beginning of the file when you reread it, but start from the last position they were reading and work with files including data from linear detectors.

An working example for both methods is given in the following.:

```
import tables
import xrayutilities as xu
import os

# open spec file or use open SPECfile instance
try: s
except NameError:
s = xu.io.SPECFile("sample_name.spec",path="./specdir")

# method (1)
scan10 = s[9] # Returns a SPECScan class, note 9 because the list starts at 0
scan10.ReadData()
scan10data = scan10.data
```

```
# method (2)
h5file = os.path.join("h5dir","h5file.h5")
s.Save2HDF5(h5file) # save content of SPEC file to HDF5 file
# read data from HDF5 file
[angle1,angle2],scan10data = xu.io.geth5_scan(h5file,[10], "motorname1", "motorname2")
```

See Also:

the fully working example hello world

In the following it is shown how to re-parsing the SPEC file for new scans and reread the scans (1) or update the HDF5 file(2)

```
s.Update() # reparse for new scans in open SPECFile instance

# reread data method (1)
scan10 = s[9] # Returns a SPECScan class
scan10.ReadData()
scan10data = scan10.data

# reread data method (2)
s.Save2HDF5(h5) # save content of SPEC file to HDF5 file
# read data from HDF5 file
[angle1,angle2],scan10data = xu.io.geth5_scan(h5file,[10], "motorname1", "motorname2")
```

Reading EDF files

EDF files are mostly used to store CCD frames at ESRF recorded from various different detectors. This format is therefore used in combination with SPEC files. In an example the EDFFile class is used to parse the data from EDF files and store them to an HDF5 file. HDF5 if perfectly suited because it can handle large amount of data and compression.:

```
import tables
  import xrayutilities as xu
  import numpy
  specfile = "specfile.spec"
  h5file = "h5file.h5"
  h5 = tables.openFile(h5file, mode='a')
   s = xu.io.SPECFile(specfile,path=specdir)
10
   s.Save2HDF5(h5) # save to hdf5 file
11
12
   # read ccd frames from EDF files
13
   for i in range(1,1000,1):
       efile = "edfdir/sample_%04d.edf" %i
14
       e = xu.io.edf.EDFFile(efile,path=specdir)
15
16
       e.ReadData()
       g5 = h5.createGroup(h5.root, "frelon_%04d" %i)
17
       e.Save2HDF5(h5,group=g5)
18
19
  h5.close()
```

See Also:

the fully working example provided in the examples directory perfectly suited for reading data from beamline ID01

Other formats

Other formats which can be read include

- files recorded from Panalytical diffractometers in the .xrdml format.
- files produces by the experimental control software at Hasylab/Desy (spectra).
- ccd images in the tiff file format produced by RoperScientific CCD cameras and Perkin Elmer detectors.
- files from recorded by Seifert diffractometer control software (.nja)
- basic support is also provided for reading of cif files from structure database to extract unit cell parameters

See the examples directory for more information and working example scripts.

4.1.2 Angle calculation using experiment and material classes

Methods for high angle x-ray diffraction experiments. Mostly for experiments performed in coplanar scattering geometry. An example will be given for the calculation of the position of Bragg reflections.

```
import xrayutilities as xu

si = xu.materials.Si  # load material from materials submodule

# initialize experimental class with directions from experiment

hxrd = xu.HXRD(Si.Q(1,1,-2),Si.Q(1,1,1))

# calculate angles of Bragg reflections and print them to the screen

om,chi,phi,tt = hxrd.Q2Ang(Si.Q(1,1,1))

print("Si (111)")

print("om,tt: %8.3f %8.3f" %(om,tt))

om,chi,phi,tt = hxrd.Q2Ang(Si.Q(2,2,4))

print("Si (224)")

print("om,tt: %8.3f %8.3f" %(om,tt))
```

Note that on line 5 the HXRD class is initialized without specifying the energy used in the experiment. It will use the default energy stored in the configuration file, which defaults to CuK α_1 .

One could also call:

```
hxrd = xu.HXRD(Si.Q(1,1,-2),Si.Q(1,1,1),en=10000) # energy in eV
```

to specify the energy explicitly. The HXRD class by default describes a four-circle goniometer as described in more detail here.

Similar functions exist for other experimental geometries. For grazing incidence diffraction one might use:

```
gid = xu.GID(Si.Q(1,-1,0),Si.Q(0,0,1))
# calculate angles and print them to the screen
(alphai,azimuth,tt,beta) = gid.Q2Ang(Si.Q(2,-2,0))
print("azimuth,tt: %8.3f %8.3f" %(azimuth,tt))
```

There are two implementations for GID experiments. Both describe 2S+2D diffractometers. They differ by the order of the detector circles. One describes a setup as available at ID10B/ESRF.

There exists also a powder diffraction class, which is able to convert powder scans from angular to reciprocal space and furthermore powder scans of materials can be simulated in a very primitive way, which should only be used to get an idea of the peak positions expected from a certain material.

```
import xrayutilities as xu
import matplotlib.pyplot as plt

energy = (2*8048 + 8028)/3. # copper k alpha 1,2

# creating Indium powder
In_powder = xu.Powder(xu.materials.In,en=energy)
# calculating the reflection strength for the powder
In_powder.PowderIntensity()
# convoluting the peaks with a gaussian in q-space
```

4.1. Examples 17

```
peak_width = 0.01 # in q-space
   resolution = 0.0005 # resolution in q-space
13
   In_th, In_int = In_powder.Convolute(resolution, peak_width)
14
15
  plt.figure()
16
  plt.xlabel(r"2Theta (deg)"); plt.ylabel(r"Intensity")
17
  # plot the convoluted signal
  plt.plot(In_th*2, In_int/In_int.max(), 'k-', label="Indium powder convolution")
  # plot each peak in a bar plot
  plt.bar(In_powder.ang*2, In_powder.data/In_powder.data.max(), width=0.3, bottom=0,
21
           linewidth=0, color='r',align='center', orientation='vertical',label="Indium bar plot")
22
23
   plt.legend(); plt.set_xlim(15,100); plt.grid()
```

One can also print the peak positions and other informations of a powder by

```
>>> print In_powder
2
      Powder diffraction object
      _____
     Material: In
      Lattice:
      a1 = (3.252300 \ 0.000000 \ 0.000000), \ 3.252300
      a2 = (0.000000 \ 3.252300 \ 0.000000), \ 3.252300
      a3 = (0.000000 \ 0.000000 \ 4.946100), \ 4.946100
      alpha = 90.000000, beta = 90.000000, gamma = 90.000000
      Lattice base:
10
      Base point 0: In (49) (0.000000 0.000000 0.000000) occ=1.00 b=0.00
11
      Base point 1: In (49) (0.500000 0.500000 0.500000) occ=1.00 b=0.00
12
      Reflections:
13
14
           h k l | tth
                              |Q|
                                           | Int
                                                       | Int (%)
15
16
         [-1, 0, -1] 32.9611
                                  2.312
                                               217.75
                                                          100.00
17
          [0, 0, -2] 36.3267
                                   2.541
                                                41.80
                                                           19.20
18
         [-1, -1, 0] 39.1721
                                   2.732
                                                67.72
                                                            31.10
19
         [-1, -1, -2]
                      54.4859
                                   3.731
                                                50.75
                                                            23.31
20
21
         . . . .
```

4.1.3 Using the material class

xrayutilities provides a set of python classes to describe crystal lattices and materials.

Examples show how to define a new material by defining its lattice and deriving a new material, furthermore materials can be used to calculate the structure factor of a Bragg reflection for an specific energy or the energy dependency of its structure factor for anomalous scattering. Data for this are taken from a database which is included in the download.

First defining a new material from scratch is shown. This consists of an lattice with base and the type of atoms with elastic constants of the material:

```
import xrayutilities as xu

defining a ZincBlendeLattice with two types of atoms and lattice constant a

def ZincBlendeLattice (aa,ab,a):
    #create lattice base
    lb = xu.materials.LatticeBase()
    lb.append(aa,[0,0,0])
    lb.append(aa,[0.5,0.5,0])
    lb.append(aa,[0.5,0,0.5])
    lb.append(aa,[0,0.5,0.5])
    lb.append(ab,[0.25,0.25,0.25])
    lb.append(ab,[0.75,0.75,0.25])
```

```
1b.append(ab, [0.75, 0.25, 0.75])
13
       lb.append(ab, [0.25, 0.75, 0.75])
14
15
       #create lattice vectors
16
17
       a1 = [a, 0, 0]
       a2 = [0, a, 0]
18
       a3 = [0,0,a]
19
       1 = xu.materials.Lattice(a1, a2, a3, base=1b)
21
22
       return 1
23
   # defining InP, no elastic properties are given,
24
   # helper functions exist to create the (6,6) elastic tensor for cubic materials
25
   atom_In = xu.materials.elements.In
26
   atom_P = xu.materials.elements.P
27
   elastictensor = xu.materials.CubicElasticTensor(10.11e+10,5.61e+10,4.56e+10)
28
        = xu.materials.Material("InP",ZincBlendeLattice(atom_In, atom_P,5.8687), elastictensor)
```

InP is of course already included in the xu.materials module and can be loaded by:

```
InP = xu.materials.InP
```

like many other materials.

Using the material properties the calculation of the reflection strength of a Bragg reflection can be done as follows:

```
import xrayutilities as xu
import numpy

# defining material and experimental setup
InAs = xu.materials.InAs
energy= 8048 # eV

# calculate the structure factor for InAs (111) (222) (333)
hkllist = [[1,1,1],[2,2,2],[3,3,3]]
for hkl in hkllist:
    qvec = InAs.Q(hkl)
    F = InAs.StructureFactor(qvec,energy)
print(" |F| = %8.3f" %numpy.abs(F))
```

Similar also the energy dependence of the structure factor can be determined:

```
import matplotlib.pyplot as plt

energy= numpy.linspace(500,20000,5000) # 500 - 20000 eV

F = InAs.StructureFactorForEnergy(InAs.Q(1,1,1),energy)

plt.figure(); plt.clf()

plt.plot(energy,F.real,'k-',label='Re(F)')

plt.plot(energy,F.imag,'r-',label='Imag(F)')

plt.xlabel("Energy (eV)"); plt.ylabel("F"); plt.legend()
```

It is also possible to calculate the components of the structure factor of atoms, which may be needed for input into XRD simulations.:

```
# f = f0(|Q|) + f1(en) + j * f2(en)
import xrayutilities as xu
import numpy

Fe = xu.materials.elements.Fe # iron atom
Q = numpy.array([0,0,1.9],dtype=numpy.double)
en = 10000 # energy in eV

print "Iron (Fe): E: %9.1f eV" % en
```

4.1. Examples 19

```
print "f0: %8.4g" % Fe.f0(numpy.linalg.norm(Q))
print "f1: %8.4g" % Fe.f1(en)
print "f2: %8.4g" % Fe.f2(en)
```

4.1.4 User-specific config file

Several options of *xrayutilities* can be changed by options in a config file. This includes the default x-ray energy as well as parameters to set the number of threads used by the parallel code and the verbosity of the output.

The default options are stored inside the installad Python module and should not be changed. Instead it is suggested to use a user-specific config file '~/.xrayutilities.conf' or a 'xrayutilities.conf' file in the working directory.

An example of such a user config file is shown below:

```
# begin of xrayutilities configuration
[xrayutilities]
# verbosity level of information and debugging outputs
   0: no output
   1: very import notes for users
   2: less import notes for users (e.g. intermediate results)
   3: debuging output (e.g. print everything, which could be interesing)
   levels can be changed in the config file as well
verbosity = 1
# default wavelength in Angstrom,
wavelength = MoKa1 # Molybdenum K alpha1 radiation (17479.374eV)
# default energy in eV
# if energy is given wavelength settings will be ignored
\#energy = 10000 \#eV
# number of threads to use in parallel sections of the code
nthreads = 1
# 0: the maximum number of available threads will be used (as returned by omp_get_max_threads()
   n: n-threads will be used
```

4.1.5 Determining detector parameters

In the following three examples of how to determine the detector parameters for linear and area detectors is given. The procedure we use is in more detail described in this article.

Linear detectors

To determine the detector parameters of a linear detector one needs to perform a scan with the detector angle through the primary beam and aquire a detector spectrum at any point.

Using the following script determines the parameters necessary for the detector initialization, which are:

- · pixelwidth of one channel
- · the center channel
- and the detector tilt (optional)

```
1 """
2 example script to show how the detector parameters
3 such as pixel width, center channel and detector tilt
4 can be determined for a linear detector.
5 """
```

```
import xrayutilities as xu
   import os
   # load any data file with with the detector spectra of a reference scan
10
   # in the primary beam, here I use spectra measured with a Seifert XRD
11
   # diffractometer
12
   dfile = os.path.join("data", "primarybeam_alignment20130403_2_dis350.nja")
13
   s = xu.io.SeifertScan(dfile)
15
   ang = s.axispos["T"] # detector angles during the scan
   spectra = s.data[:,:,1] # detector spectra aquired
17
18
   # determine detector parameters
19
   # this function accepts some optional arguments to describe the goniometer
20
   # see the API documentation
21
   pwidth,cch,tilt = xu.analysis.linear_detector_calib(ang,spectra,usetilt=True)
```

Area detector (Variant 1)

To determine the detector parameters of a area detector one needs to perform scans with the detector angles through the primary beam and aquire a detector images at any position. For the area detector at least two scans (one with the outer detector and and one with the inner detector angle) are required.

Using the following script determines the parameters necessary for the detector initialization from such scans in the primary beam only. Further down we discuss an other variant which is also able to use additionally detector images recorded at the Bragg reflection of a known reference crystal.

The determined detector parameters are:

- pixelwidth of the channels in both directions (2 parameters)
- center channels: position of the primary beam at the true zero position of the goniometer (considering the outer angle offset) (2 parameters)
- detector tilt azimuth in degree from 0 to 360
- detector tilt angle in degree (>0deg)
- detector rotation around the primary beam in degree
- outer angle offset, which describes a offset of the outer detector angle from its true zero position

The misalignment parameters can be fixed during the fitting.

```
example script to show the detector parameter determination for area detectors from images record
4
   import xrayutilities as xu
5
   import os
6
   en=10300.0 \#eV
8
   datadir = os.path.join("data", "wire_") # data path for CCD files
   filetmp = os.path.join(datadir,"wire_12_%05d.edf.gz") # template for the CCD file names
10
11
   ## manually selected images
12
   # select images which have the primary beam fully on the CCD
13
   imagenrs = [2,3,4,5,6,7,8,9,10,11,12,13,14,15,16,17,18,19,20,21,22,23,24,25,26,27,28,29,30,31,32,
14
15
   images = []
16
   ang1 = []
17
   ang2 = []
18
19
   # read images and angular positions from the data file
20
```

4.1. Examples 21

```
# this might differ for data taken at different beamlines since
   # they way how motor positions are stored is not always consistent
22
   for imgnr in imagenrs:
23
       filename = filetmp%imgnr
24
       edf = xu.io.EDFFile(filename)
25
26
       images.append(edf.data)
       ang1.append(float(edf.header['ESRF_ID01_PSIC_NANO_NU']))
27
       ang2.append(float(edf.header['ESRF_ID01_PSIC_NANO_DEL']))
29
30
   # call the fit for the detector parameters
31
   # detector arm rotations and primary beam direction need to be given
32
   # in total 8 parameters are fitted, however the 4 misalignment parameters can be fixed
33
   # they are the detector tilt azimuth, the detector tilt angle, the detector rotation around the p
34
  param, eps = xu.analysis.sample_align.area_detector_calib(ang1,ang2,images,['z+','y-'],'x+',start=
```

A possible output of this script could be

```
fitted parameters: epsilon: 8.0712e-08 (2,['Parameter convergence'])
param: (cch1,cch2,pwidth1,pwidth2,tiltazimuth,tilt,detrot,outerangle_offset)
param: 140.07 998.34 4.4545e-05 4.4996e-05 72.0 1.97 -0.792 -1.543
please check the resulting data (consider setting plot=True)
detector rotation axis / primary beam direction (given by user): ['z+', 'y-'] / x+
detector pixel directions / distance: z- y+ / 1
detector initialization with: init_area('z-','y+',cch1=140.07,cch2=998.34,Nch1=516,Nch2=516, pwid
AND ALWAYS USE an (additional) OFFSET of -1.9741deg in the OUTER DETECTOR ANGLE!
```

The output gives the fitted detector parameters and compiles the python code line one needs to use to initialize the detector. Important to note is that the outer angle offset which was determined by the fit (-1.9741 degree in the aboves example) is not included in the initialization of the detector parameters BUT needs to be used in every call to the q-conversion function as offset. This step needs to be performed manually by the user!

Area detector (Variant 2)

In addition to scans in the primary beam this variant enables also the use of detector images recorded in scans at Bragg reflections of a known reference materials. However this also required that the sample orientation and x-ray wavelength need to be fit. To keep the additional parameters as small as possible we only implemented this for symmetric coplanar diffractions.

The advantage of this method is that it is more sensitive to the outer angle offset also at large detector distances. The additional parameters are:

- sample tilt angle in degree
- · sample tilt azimuth in degree
- and the x-ray wavelength in Angstrom

```
example script to show the detector parameter determination for area detectors from images record
and at known symmetric coplanar Bragg reflections of a reference crystal

"""

import xrayutilities as xu
import os
import numpy

Si = xu.materials.Si

datadir = 'data'
specfile = "si_align.spec"
```

15

en=15000 #eV

```
wl = xu.lam2en(en)
   imgdir = os.path.join(datadir, "si_align_") # data path for CCD files
17
   filetmp = "si_align_12_%04d.edf.gz"
18
19
   qconv = xu.QConversion(['z+','y-'],['z+','y-'],[1,0,0])
20
   hxrd = xu.HXRD(Si.Q(1,1,-2),Si.Q(1,1,1),wl=wl,qconv=qconv)
21
22
   ## manually selected images
23
24
   s = xu.io.SPECFile(specfile,path=datadir)
25
   for num in [61,62,63,20,21,26,27,28]:
26
       s[num].ReadData()
27
       try:
28
           imagenrs = numpy.append(imagenrs,s[num].data['ccd_n'])
29
       except:
30
           imagenrs = s[num].data['ccd_n']
31
32
33
   # avoid images which do not have to full beam on the detector as well as other which show signal
   avoid_images = [37,57,62,63,65,87,99,106,110,111,126,130,175,181,183,185,204,206,207,208,211,212,
34
36
   images = []
   ang1 = [] # outer detector angle
37
   ang2 = [] # inner detector angle
38
   sang = [] # sample rocking angle
39
   hkls = [] # Miller indices of the reference reflections
40
41
   def hotpixelkill(ccd):
42
43
       function to remove hot pixels from CCD frames
44
       ADD REMOVE VALUES IF NEEDED!
45
46
       ccd[304,97] = 0
47
       ccd[303,96] = 0
48
       return ccd
49
50
   # read images and angular positions from the data file
51
   # this might differ for data taken at different beamlines since
52
   # they way how motor positions are stored is not always consistent
53
   for imgnr in numpy.sort(list(set(imagenrs)-set(avoid_images))[::4]):
       filename = os.path.join(imgdir, filetmp%imgnr)
55
56
       edf = xu.io.EDFFile(filename)
       ccd = hotpixelkill(edf.data)
57
       images.append(ccd)
58
       ang1.append(float(edf.header['motor_pos'].split()[4]))
59
       ang2.append(float(edf.header['motor_pos'].split()[3]))
60
       sang.append(float(edf.header['motor_pos'].split()[1]))
61
       if imgnr > 1293.:
62
           hkls.append((0,0,0))
63
       elif imgnr < 139:
           hkls.append((0,0,numpy.sqrt(27))) \#(3,3,3))
       else:
67
           hkls.append((0,0,numpy.sqrt(75))) \#(5,5,5)
68
   # call the fit for the detector parameters
69
   # detector arm rotations and primary beam direction need to be given
70
   # in total 8 detector parameters + 2 additional parameters for the reference crystal orientation
71
   # however the 4 misalignment parameters of the detector and the 3 other parameters can be fixed
72
   # the fixable parameters are detector tilt azimuth, the detector tilt angle, the detector rotation
73
74
   # sample tilt, sample tilt azimuth and the x-ray wavelength
   param, eps = xu.analysis.area_detector_calib_hkl(sang, ang1, ang2, images, hkls, hxrd, Si, ['z+','y-'],'x
   # Following is an example of the output of the summary of the area_detector_calib_hkl function
77
```

4.1. Examples 23

#total time needed for fit: 624.51sec

4.2 xrayutilities Package

4.2.1 xrayutilities Package

xrayutilities is a Python package for assisting with x-ray diffraction experiments. Its the python package included in *xrayutilities*.

It helps with planning experiments as well as analyzing the data.

Authors Dominik Kriegner dominik.kriegner@gmail.com and Eugen Wintersberger eugen.wintersberger@desy.de

4.2.2 config Module

module to parse xrayutilities user-specific config file the parsed values are provide as global constants for the use in other parts of xrayutilities. The config file with the default constants is found in the python installation path of xrayutilities. It is however not recommended to change things there, instead the user-specific config file ~/.xrayutilities.conf or the local xrayutilities.conf file should be used.

4.2.3 exception Module

xrayutilities derives its own exceptions which are raised upon wrong input when calling one of xrayutilities functions. none of the pre-defined exceptions is made for that purpose.

```
exception xrayutilities.exception.InputError(msg)
Bases: exceptions.Exception
```

Exception raised for errors in the input. Either wrong datatype not handled by TypeError or missing mandatory keyword argument (Note that the obligation to give keyword arguments might depend on the value of the arguments itself)

Attibutesexpr - input expression in which the error occurred :msg: - explanation of the error

4.2.4 experiment Module

module helping with planning and analyzing experiments

various classes are provided for

* describing experiments * calculating angular coordinates of Bragg reflections * converting angular coordinates to Q-space and vice versa * simulating powder diffraction patterns for materials

base class for describing experiments users should use the derived classes: HXRD, GID, Powder

Ang2HKL (*args, **kwargs)

angular to (h,k,l) space conversion. It will set the UB argument to Ang2Q and pass all other parameters unchanged. See Ang2Q for description of the rest of the arguments.

Parameters

**kwargs: optional keyword arguments

Breciprocal space conversion matrix of a Material. you can specify the matrix B (default identity matrix) shape needs to be (3,3)

matMaterial object to use to obtain a B matrix (e.g. xu.materials.Si) can be used as alternative to the B keyword argument B is favored in case both are given

Uorientation matrix U can be given if none is given the orientation defined in the Experiment class is used.

dettypedetector type: one of ('point', 'linear', 'area') decides which routine of Ang2Q to call default 'point'

Returns

H K L coordinates as numpy.ndarray with shape (* , 3) where * corresponds to the number of points given in the input (*args)

Q2Ang (qvec)

TiltAngle (q, deg=True)

TiltAngle(q,deg=True): Return the angle between a q-space position and the surface normal.

Parameters

qlist or numpy array with the reciprocal space position

optional keyword arguments:

degTrue/False whether the return value should be in degree or radians :(default: True)

Transform (v)

transforms a vector, matrix or tensor of rank 4 (e.g. elasticity tensor) to the coordinate frame of the Experiment class.

Parameters

vobject to transform, list or numpy array of shape (n,) (n,n), (n,n,n,n) where n is the rank of the transformation matrix

Returns

transformed object of the same shape as v

energy

wavelength

```
{\bf class} \; {\tt xrayutilities.experiment.GID} \; ({\it idir}, {\it ndir}, \; **keyargs)
```

 $Bases: \verb|xrayutilities.experiment.Experiment|\\$

class describing grazing incidence x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as it helps with analyzing measured data

the class describes a four circle (alpha_i,azimuth,twotheta,beta) goniometer to help with GID experiments at the ROTATING ANODE. 3D data can be treated with the use of linear and area detectors. see help self.Ang2Q

Ang2Q (ai, phi, tt, beta, **kwargs)

angular to momentum space conversion for a point detector. Also see help GID.Ang2Q for procedures which treat line and area detectors

Parameters

ai,phi,tt,betasample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 4. used angles are than ai,phi,tt,beta - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

Q2Ang (Q, trans=True, deg=True, **kwargs)

calculate the GID angles needed in the experiment the inplane reference direction defines the direction were the reference direction is parallel to the primary beam (i.e. lattice planes perpendicular to the beam)

Parameters

Qa list or numpy array of shape (3) with q-space vector components

optional keyword arguments:

transTrue/False apply coordinate transformation on Q

degTrue/Flase (default True) determines if the angles are returned in radians or degrees

Returns

a numpy array of shape (4) with the four GID scattering angles which are [al-pha_i,azimuth,twotheta,beta]

alpha_iincidence angle to surface (at the moment always 0)

azimuthsample rotation with respect to the inplane reference direction

twothetascattering angle

betaexit angle from surface (at the moment always 0)

```
class xrayutilities.experiment.GID_ID10B(idir, ndir, **keyargs)
```

```
Bases: xrayutilities.experiment.GID
```

class describing grazing incidence x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as it helps with analyzing measured data

the class describes a four circle (theta,omega,delta,gamma) goniometer to help with GID experiments at ID10B / ESRF. 3D data can be treated with the use of linear and area detectors. see help self.Ang2Q

```
Ang2Q (th, om, delta, gamma, **kwargs)
```

angular to momentum space conversion for a point detector. Also see help GID_ID10B.Ang2Q for procedures which treat line and area detectors

Parameters

th,om,delta,gammasample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 4. used angles are than th,om,delta,gamma - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self. wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

Q2Ang (Q, trans=True, deg=True, **kwargs)

calculate the GID angles needed in the experiment the inplane reference direction defines the direction were the reference direction is parallel to the primary beam (i.e. lattice planes perpendicular to the beam)

Parameters

Qa list or numpy array of shape (3) with q-space vector components

optional keyword arguments:

transTrue/False apply coordinate transformation on Q

degTrue/Flase (default True) determines if the angles are returned in radians or degrees

Returns

a numpy array of shape (4) with the four GID scattering angles which are (theta,omega,delta,gamma)

thetaincidence angle to surface (at the moment always 0)

omegasample rotation with respect to the inplane reference direction

deltaexit angle from surface (at the moment always 0)

gammascattering angle

```
{\bf class} \; {\tt xrayutilities.experiment.GISAXS} \; ({\it idir}, {\it ndir}, \; {\tt **keyargs})
```

```
Bases: xrayutilities.experiment.Experiment
```

class describing grazing incidence x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as it helps with analyzing measured data

the class describes a three circle (alpha_i,twotheta,beta) goniometer to help with GISAXS experiments at the ROTATING ANODE. 3D data can be treated with the use of linear and area detectors. see help self.Ang2Q

```
Ang2Q (ai, tt, beta, **kwargs)
```

angular to momentum space conversion for a point detector. Also see help GISAXS.Ang2Q for procedures which treat line and area detectors

Parameters

ai,tt,betasample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 3. used angles are than ai,tt,beta - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

Q2Ang (Q, trans=True, deg=True, **kwargs)

```
class xrayutilities.experiment.HXRD (idir, ndir, geometry='hi_lo', **keyargs)
```

Bases: xrayutilities.experiment.Experiment

class describing high angle x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as helps with analyzing measured data

the class describes a two circle (omega,twotheta) goniometer to help with coplanar x-ray diffraction experiments. Nevertheless 3D data can be treated with the use of linear and area detectors. see help self.Ang2Q

Ang2Q(om, tt, **kwargs)

angular to momentum space conversion for a point detector. Also see help HXRD.Ang2Q for procedures which treat line and area detectors

Parameters

om,ttsample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 2. used angles are than om,tt - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

Q2Ang (*Q, **keyargs)

Convert a reciprocal space vector Q to COPLANAR scattering angles. The keyword argument trans determines whether Q should be transformed to the experimental coordinate frame or not.

Parameters

Qa list, tuple or numpy array of shape (3) with q-space vector components or 3 separate lists with qx,qy,qz

optional keyword arguments:

transTrue/False apply coordinate transformation on Q (default True)

degTrue/Flase (default True) determines if the angles are returned in radians or degrees **geometry**determines the scattering geometry:

- •"hi_lo" high incidence and low exit
- •"lo_hi" low incidence and high exit
- •"real" general geometry with angles determined by q-coordinates (azimuth); this and upper geometry

-"realTilt" general geometry with angles determined by q-coordinates (tilt); returns [omega,chi,phi,twotheta]

defaultself.geometry

refracboolean to determine if refraction is taken into account :default: False if True then also a material must be given

matMaterial object; needed to obtain its optical properties for refraction correction, otherwise not used

full_outputboolean to determine if additional output is given to determine scattering angles more accurately in case refraction is set to True :default: False

fi,fdif refraction correction is applied one can optionally specify the facet through which the beam enters (fi) and exits (fd) fi, fd must be the surface normal vectors (not transformed & not necessarily normalized). If omitted the normal direction of the experiment is used.

Returns

a numpy array of shape (4) with four scattering angles which are [omega,chi,phi,twotheta]

omegaincidence angle with respect to surface

chisample tilt for the case of non-coplanar geometry

phisample azimuth with respect to inplane reference direction

twothetascattering angle/detector angle

if full_output: a numpy array of shape (6) with five angles which are [omega,chi,phi,twotheta,psi_i,psi_d]

psi_ioffset of the incidence beam from the scattering plane due to refraction

pdi_doffset ot the diffracted beam from the scattering plane due to refraction

 ${\bf class} \; {\tt xrayutilities.experiment.NonCOP} \; ({\it idir}, {\it ndir}, \; **keyargs)$

Bases: xrayutilities.experiment.Experiment

class describing high angle x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as helps with analyzing measured data for NON-COPLANAR measurements, where the tilt is used to align asymmetric peaks, like in the case of a polefigure measurement.

the class describes a four circle (omega,twotheta) goniometer to help with x-ray diffraction experiments. Linear and area detectors can be treated as described in "help self.Ang2Q"

Ang2Q (om, chi, phi, tt, **kwargs)

angular to momentum space conversion for a point detector. Also see help NonCOP.Ang2Q for procedures which treat line and area detectors

Parameters

om,chi,phi,ttsample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 4. used angles are than om,chi,phi,tt - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (* , 3) where * corresponds to the number of points given in the input

```
Q2Ang (*Q, **keyargs)
```

Convert a reciprocal space vector Q to NON-COPLANAR scattering angles. The keyword argument trans determines whether Q should be transformed to the experimental coordinate frame or not.

Parameters

Qa list, tuple or numpy array of shape (3) with q-space vector components or 3 separate lists with qx,qy,qz

optional keyword arguments:

transTrue/False apply coordinate transformation on Q (default True)

degTrue/Flase (default True) determines if the angles are returned in radians or degree

Returns

a numpy array of shape (4) with four scattering angles which are [omega,chi,phi,twotheta]

omegasample rocking angle

chisample tilt

phisample azimuth

twothetascattering angle (detector)

class xrayutilities.experiment.Powder (mat, **keyargs)

Bases: xrayutilities.experiment.Experiment

Experimental class for powder diffraction This class is able to simulate a powder spectrum for the given material

Convolute (stepwidth, width, min=0, max=None)

Convolutes the intensity positions with Gaussians with width in momentum space of "width". returns array of angular positions with corresponding intensity

thetaarray with angular positions

intintensity at the positions ttheta

PowderIntensity (tt_cutoff=180)

Calculates the powder intensity and positions up to an angle of tt_cutoff (deg) and stores the result in:

dataarray with intensities

angular position of intensities

qposreciprocal space position of intensities

Q2Ang(qpos, deg=True)

Converts reciprocal space values to theta angles

Class for the conversion of angular coordinates to momentum space for arbitrary goniometer geometries

the class is configured with the initialization and does provide three distinct routines for conversion to momentum space for

```
* point detector: point(...) or __call__() * linear detector: linear(...) * area detector: area(...)
```

linear() and area() can only be used after the init_linear() or init_area() routines were called

UВ

area(*args, **kwargs)

angular to momentum space conversion for a area detector the center pixel defined by the init_area routine must be in direction of self.r_i when detector angles are zero

the detector geometry must be initialized by the init_area(...) routine

Parameters

*args: sample and detector angles as numpy array, lists or Scalars

in total len(self.sampleAxis)+len(detectorAxis) must be given always starting with the outer most circle all arguments must have the same shape or length

sAnglessample circle angles, number of arguments must correspond to len(self.sampleAxis)

dAnglesdetector circle angles, number of arguments must correspond to len(self.detectorAxis)

**kwargs: possible keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of len(*args) used angles are than *args - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: self.UB)

roiregion of interest for the detector pixels; e.g. [100,900,200,800] :(default: self._area_roi)

Navnumber of channels to average to reduce data size e.g. [2,2] :(default: self._area_nav)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space position of all detector pixels in a numpy.ndarray of shape ($(*)*(self._area_roi[1]-self._area_roi[0]+1)*(self._area_roi[3]-self._area_roi[2]+1)$, 3) were detectorDir1 is the fastest varing

detectorAxis

property handler for _detectorAxis

Returns

list of detector axis following the syntax /[xyz][+-]/

energy

initialization routine for area detectors detector direction as well as distance and pixel size or channels per degree must be given. Two separate pixel sizes and channels per degree for the two orthogonal directions can be given

Parameters

detectorDir1direction of the detector (along the pixel direction 1); e.g. 'z+' means higher pixel numbers at larger z positions

detectorDir2direction of the detector (along the pixel direction 2); e.g. 'x+'

cch1,2center pixel, in direction of self.r_i at zero detectorAngles

Nch1number of detector pixels along direction 1

Nch2number of detector pixels along direction 2

distance distance of center pixel from center of rotation

pwidth1,2width of one pixel (same unit as distance)

chpdeg1,2channels per degree (only absolute value is relevant) sign determined through detectorDir1,2

detrotangle of the detector rotation around primary beam direction (used to correct misalignments)

tiltazimuthdirection of the tilt vector in the detector plane (in degree)

tilttilt of the detector plane around an axis normal to the direction given by the tiltazimuth

Note: Note: Either distance and pwidth1,2 or chpdeg1,2 must be given!!

Note: Note: the channel numbers run from 0 .. NchX-1

**kwargs: optional keyword arguments

Navnumber of channels to average to reduce data size (default: [1,1])

roiregion of interest for the detector pixels; e.g. [100,900,200,800]

initialization routine for linear detectors detector direction as well as distance and pixel size or channels per degree must be given.

Parameters

detectorDirdirection of the detector (along the pixel array); e.g. 'z+'

cchcenter channel, in direction of self.r_i at zero detectorAngles

Nchanneltotal number of detector channels

distancedistance of center channel from center of rotation

pixelwidth width of one pixel (same unit as distance)

chpdegchannels per degree (only absolute value is relevant) sign determined through detectorDir

!! Either distance and pixelwidth or chpdeg must be given !!

tilttilt of the detector axis from the detectorDir (in degree)

Note: Note: the channel numbers run from 0 .. Nchannel-1

**kwargs: optional keyword arguments

Navnumber of channels to average to reduce data size (default: 1)

roiregion of interest for the detector pixels; e.g. [100,900]

linear (*args, **kwargs)

angular to momentum space conversion for a linear detector the cch of the detector must be in direction of self.r_i when detector angles are zero

the detector geometry must be initialized by the init_linear(...) routine

Parameters

*args: sample and detector angles as numpy array, lists or Scalars

in total len(self.sampleAxis)+len(detectorAxis) must be given always starting with the outer most circle all arguments must have the same shape or length

sAnglessample circle angles, number of arguments must correspond to len(self.sampleAxis)

dAnglesdetector circle angles, number of arguments must correspond to len(self.detectorAxis)

**kwargs: possible keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of len(*args) used angles are than *args - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: self.UB)

Navnumber of channels to average to reduce data size (default: self._linear_nav)

roiregion of interest for the detector pixels; e.g. [100,900] (default: self._linear_roi)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space position of all detector pixels in a numpy.ndarray of shape ($(*)*(self._linear_roi[1]-self._linear_roi[0]+1)$, 3)

point (*args, **kwargs)

angular to momentum space conversion for a point detector located in direction of self.r_i when detector angles are zero

Parameters

*args: sample and detector angles as numpy array, lists

or Scalars in total len(self.sampleAxis)+len(detectorAxis) must be given, always starting with the outer most circle. all arguments must have the same shape or length

sAnglessample circle angles, number of arguments must correspond to len(self.sampleAxis)

dAnglesdetector circle angles, number of arguments must correspond to len(self.detectorAxis)

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of len(*args) used angles are than *args - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: self.UB)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree :(default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

```
sampleAxis
          property handler for _sampleAxis
          list of sample axis following the syntax /[xyzk][+-]/
     wavelength
4.2.5 gridder Module
class xrayutilities.gridder.Gridder
     Bases: object
     KeepData (bool)
     Normalize (bool)
class xrayutilities.gridder.Gridder1D (nx)
     Bases: xrayutilities.gridder.Gridder
     Clear()
     data
          Returns the xaxis of the gridder the returned values correspond to the center of the data bins used by
          the numpy.histogram function
xrayutilities.gridder.axis (min_value, max_value, n)
     Compute the a grid axis.
     Parameters
          Min_value axis minimum value
          Max_value axis maximum value
          N number of steps
xrayutilities.gridder.check_array(a, dtype)
     Check if an array fits the requirements for the C-code and returns it back to the callee. Such arrays must be
     aligned and C_CONTIGUOUS which means that they have to follow C-ordering.
     Parameters
          A array to check
          Dtype numpy data type
xrayutilities.gridder.delta(min_value, max_value, n)
     Compute the stepsize along an axis of a grid.
     Parameters
          Min value axis minimum value
          Max_value axis maximum value
          N number of steps
xrayutilities.gridder.ones(*args)
     Compute ones for matrix generation. The shape is determined by the number of input arguments.
```

4.2.6 gridder2d Module

```
Clear()

SetResolution (nx, ny)

Reset the resolution of the gridder. In this case the original data stored in the object will be deleted.

Parameters

Nx number of points in x-direction

Ny number of points in y-direction

data

xaxis

xmatrix

yaxis

ymatrix
```

4.2.7 gridder3d Module

```
class xrayutilities.gridder3d.Gridder3D (nx, ny, nz)
    Bases: xrayutilities.gridder.Gridder
    SetResolution (nx, ny, nz)
    xaxis
    xmatrix
    yaxis
    ymatrix
    zaxis
    zmatrix
```

4.2.8 normalize Module

module to provide functions that perform block averaging of intensity arrays to reduce the amount of data (mainly for PSD and CCD measurements

and

provide functions for normalizing intensities for

* count time * absorber (user-defined function) * monitor * flatfield correction

generic class for correction of intensity (point detector, or MCA, single CCD frames) for count time and absorber factors the class must be supplied with a absorber correction function and works with data structures provided by xrayutilities.io classes or the corresponding objects from hdf5 files read by pytables

absfun

absfun property handler returns the costum correction function or None

avmon

av_mon property handler returns the value of the average monitor or None if average is calculated from the monitor field

darkfield

flatfield property handler returns the current set darkfield of the detector or None if not set

det

det property handler returns the detector field name

flatfield

flatfield property handler returns the current set flatfield of the detector or None if not set

mon

mon property handler returns the monitor field name or None if not set

time

time property handler returns the count time or the field name of the count time or None if time is not set

xrayutilities.normalize.blockAverage1D (data, Nav)

perform block average for 1D array/list of Scalar values all data are used. at the end of the array a smaller cell may be used by the averaging algorithm

Parameter

datadata which should be contracted (length N)

Navnumber of values which should be averaged

Returns

block averaged numpy array of data type numpy.double (length ceil(N/Nav))

xrayutilities.normalize.blockAverage2D (data2d, Nav1, Nav2, **kwargs)

perform a block average for 2D array of Scalar values all data are used therefore the margin cells may differ in size

Parameter

data2darray of 2D data shape (N,M)

Nav1,2a field of (Nav1 x Nav2) values is contracted

**kwargs: optional keyword argument

roiregion of interest for the 2D array. e.g. [20,980,40,960] N = 980-20; M = 960-40

Returns

block averaged numpy array with type numpy.double with shape (ceil(N/Nav1), ceil(M/Nav2))

xrayutilities.normalize.blockAveragePSD (psddata, Nav, **kwargs)

perform a block average for serveral PSD spectra all data are used therefore the last cell used for averaging may differ in size

Parameter

psddataarray of 2D data shape (Nspectra, Nchannels)

Navnumber of channels which should be averaged

**kwargs: optional keyword argument

roiregion of interest for the 2D array. e.g. [20,980] Nchannels = 980-20

Returns

block averaged psd spectra as numpy array with type numpy.double of shape (Nspectra , ceil(Nchannels/Nav))

4.2.9 utilities Module

xrayutilities utilities contains a conglomeration of useful functions which do not fit into one of the other files

```
xrayutilities.utilities.maplog (inte, dynlow='config', dynhigh='config', **keyargs) clips values smaller and larger as the given bounds and returns the log10 of the input array. The bounds are given as exponent with base 10 with respect to the maximum in the input array. The function is implemented in analogy to J. Stangl's matlab implementation.
```

Parameters

intenumpy.array, values to be cut in range

dynlow10^(-dynlow) will be the minimum cut off

dynhigh 10[^](-dynhigh) will be the maximum cut off

optional keyword arguments (NOT IMPLEMENTED):

```
abslow10^(abslow) will be taken as lower boundary
abshigh10^(abshigh) will be taken as higher boundary
```

Returns

numpy.array of the same shape as inte, where values smaller/larger then 10^(-dynlow,dynhigh) were replaced by 10^(-dynlow,dynhigh)

Example

```
>>> lint = maplog(int, 5, 2)
```

4.2.10 utilities_noconf Module

xrayutilities utilities contains a conglomeration of useful functions this part of utilities does not need the config class

```
xrayutilities.utilities_noconf.energy (en)
convert common energy names to energies in eV
so far this works with CuKa1, CuKa2, CuKa12, CuKb, MoKa1
```

Parameter

enenergy (scalar (energy in eV will be returned unchanged) or string with name of emission line)

Returns

energy in eV as float

```
xrayutilities.utilities_noconf.lam2en(inp)
```

converts the input energy in eV to a wavelength in Angstrom or the input wavelength in Angstrom to an energy in eV

Parameter

inpeither an energy in eV or an wavelength in Angstrom

Returns

float, energy in eV or wavlength in Angstrom

Examples

```
>>> lambda = lam2en(8048)
>>> energy = lam2en(1.5406)
```

```
\label{eq:converted} \begin{tabular}{ll} $\tt xrayutilities\_noconf.wavelength\,(\it{wl})$ \\ convert common energy names to energies in eV \\ so far this works with CuKa1, CuKa2, CuKa12, CuKb, MoKa1 \\ \end{tabular}
```

Parameter

wlwavelength (scalar (wavelength in Angstrom will be returned unchanged) or string with name of emission line)

Returns

wavelength in Angstrom as float

4.2.11 Subpackages

analysis Package

analysis Package

xrayutilities.analysis is a package for assisting with the analysis of x-ray diffraction data, mainly reciprocal space maps

Routines for obtaining line cuts from gridded reciprocal space maps are offered, with the ability to integrate the intensity perpendicular to the line cut direction.

line_cuts Module

```
xrayutilities.analysis.line_cuts.fwhm_exp(pos, data)
```

function to determine the full width at half maximum value of experimental data. Please check the obtained value visually (noise influences the result)

Parameter

posposition of the data points

datadata values

Returns

fwhm value (single float)

extracts an omega scan from a gridded reciprocal space map

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

omcenteromega-position at which the omega scan should be extracted

ttcenter2theta-position at which the omega scan should be extracted

omrangerange of the omega scan to extract

npoints number of points of the omega scan

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

```
Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative omega positions are returned (default: True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               om,omintomega scan coordinates and intensities (bounds=False)
               om,omint,(qxb,qzb)omega scan coordinates and intensities + reciprocal space bounds
                   of the extraced scan (bounds=True)
     Example
     >>> omcut, intcut = get_omega_scan(qx,qz,intensity,0.0,5.0,2.0,200)
xrayutilities.analysis.line_cuts.get_omega_scan_bounds_ang(omcenter,
                                                                                 center,
                                                                                              om-
                                                                                          npoints.
                                                                                 range,
                                                                                 **kwargs)
     return reciprocal space boundaries of omega scan
     Parameters
               omcenteromega-position at which the omega scan should be extracted
               ttcenter2theta-position at which the omega scan should be extracted
               omrangerange of the omega scan to extract
               npointsnumber of points of the omega scan
      **kwargs: possible keyword arguments:
               grangeintegration range perpendicular to scan direction
               lamwavelength for use in the conversion to angular coordinates
     Returns
               qx,qzreciprocal space coordinates of the omega scan boundaries
     Example
     >>> qxb,qzb = get_omega_scan_bounds_ang(1.0,4.0,2.4,240,qrange=0.1)
\verb|xrayutilities.analysis.line_cuts.get_omega_scan_q| (qx, qz, intensity, qxcenter,
                                                                    qzcenter, omrange, npoints,
                                                                     **kwargs)
     extracts an omega scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
```

npointsnumber of points of the omega scan

omrangerange of the omega scan to extract

qxcenterqx-position at which the omega scan should be extracted **qzcenter**qz-position at which the omega scan should be extracted

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

Nintnumber of subscans used for the integration (optionally)

lamwavelength for use in the conversion to angular coordinates

relativedetermines if absolute or relative omega positions are returned (default: True)

boundsflag to specify if the scan bounds should be returned (default: False)

Returns

om,omintomega scan coordinates and intensities (bounds=False)

om,omint,(**qxb,qzb**)omega scan coordinates and intensities + reciprocal space bounds of the extraced scan (bounds=True)

Example

```
>>> omcut, intcut = get_omega_scan(qx,qz,intensity,0.0,5.0,2.0,200)
```

xrayutilities.analysis.line_cuts.**get_qx_scan** (*qx*, *qz*, *intensity*, *qzpos*, **kwargs) extract qx line scan at position qzpos from a gridded reciprocal space map by taking the closest line of the

Parameters

qxequidistant array of qx momentum transfer

intensity matrix, or summing up a given range along qz

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qzposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

qmin,qmaxminimum and maximum value of extracted scan axis

boundsflag to specify if the scan bounds of the extracted scan should be returned (default:False)

Returns

qx,qxintqx scan coordinates and intensities (bounds=False)

qx,qxint,(qxb,qyb)qx scan coordinates and intensities + scan bounds for plotting

Example

```
>>> qxcut,qxcut_int = get_qx_scan(qx,qz,inten,5.0,qrange=0.03)
```

xrayutilities.analysis.line_cuts.get_qz_scan(qx, qz, intensity, qxpos, **kwargs)

extract qz line scan at position qxpos from a gridded reciprocal space map by taking the closest line of the intensity matrix, or summing up a given range along qx

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qxposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

qmin,qmaxminimum and maximum value of extracted scan axis

Returns

qz,qzintqz scan coordinates and intensities

Example

```
>>> qzcut,qzcut_int = get_qz_scan(qx,qz,inten,1.5,qrange=0.03)
```

extracts a qz scan from a gridded reciprocal space map with integration along omega (sample rocking angle) or 2theta direction

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qxposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

angrangeintegration range in angular direction

qmin,qmaxminimum and maximum value of extracted scan axis

boundsflag to specify if the scan bounds of the extracted scan should be returned (default:False)

intdirintegration direction 'omega': sample rocking angle (default) '2theta': scattering angle

Returns

qz,qzintqz scan coordinates and intensities (bounds=False)

qz,qzint,(qzb,qzb)qz scan coordinates and intensities + scan bounds for plotting

Example

```
>>> qzcut,qzcut_int = get_qz_scan_int(qx,qz,inten,5.0,omrange=0.3)
```

extracts a radial scan from a gridded reciprocal space map

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

omcenterom-position at which the radial scan should be extracted

ttcentertt-position at which the radial scan should be extracted

ttrangetwo theta range of the radial scan to extract

npoints number of points of the radial scan

**kwargs: possible keyword arguments:

omrangeintegration range perpendicular to scan direction

Nintnumber of subscans used for the integration (optionally)

```
lamwavelength for use in the conversion to angular coordinates
               relative determines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               om,tt,radintomega,two theta scan coordinates and intensities (bounds=False)
               om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space
                   bounds of the extraced scan (bounds=True)
     Example
     >>> omc,ttc,cut_int = get_radial_scan_ang(qx,qz,intensity,32.0,64.0,30.0,800,omrange=0.2)
xrayutilities.analysis.line_cuts.get_radial_scan_bounds_ang(omcenter,
                                                                                    ttrange, npoints,
                                                                                    **kwargs)
     return reciprocal space boundaries of radial scan
     Parameters
               omcenterom-position at which the radial scan should be extracted
               ttcentertt-position at which the radial scan should be extracted
               ttrangetwo theta range of the radial scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range perpendicular to scan direction
               lamwavelength for use in the conversion to angular coordinates
     Returns
               qxrad,qzradreciprocal space boundaries of radial scan
     Example
     >>>
xrayutilities.analysis.line_cuts.get_radial_scan_q(qx, qz, intensity, qxcenter,
                                                                       qzcenter, ttrange, npoints,
                                                                       **kwargs)
     extracts a radial scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               qxcenterqx-position at which the radial scan should be extracted
               qzcenterqz-position at which the radial scan should be extracted
               ttrangetwo theta range of the radial scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range perpendicular to scan direction
```

```
Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               om,tt,radintomega,two theta scan coordinates and intensities (bounds=False)
               om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space
                   bounds of the extraced scan (bounds=True)
     Example
      >>> omc,ttc,cut_int = get_radial_scan_q(qx,qz,intensity,0.0,5.0,1.0,100,omrange=0.01)
xrayutilities.analysis.line_cuts.get_ttheta_scan_ang(qx, qz, intensity, omcenter,
                                                                          ttcenter, ttrange, npoints,
                                                                           **kwargs)
     extracts a twotheta scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               omcenterom-position at which the 2theta scan should be extracted
               ttcentertt-position at which the 2theta scan should be extracted
               ttrangetwo theta range of the scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range in omega direction
               Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               tt,ttinttwo theta scan coordinates and intensities (bounds=False)
               tt,ttint,(qxb,qzb)2theta scan coordinates and intensities + reciprocal space bounds of
                   the extraced scan (bounds=True)
     Example
      >>> ttc,cut_int = get_ttheta_scan_ang(qx,qz,intensity,32.0,64.0,4.0,400)
```

return reciprocal space boundaries of 2theta scan

Parameters

omcenterom-position at which the 2theta scan should be extracted

```
ttcentertt-position at which the 2theta scan should be extracted
               ttrangetwo theta range of the 2theta scan to extract
               npointsnumber of points of the 2theta scan
      **kwargs: possible keyword arguments:
               omrangeintegration range in omega direction
               lamwavelength for use in the conversion to angular coordinates
     Returns
               qxtt,qzttreciprocal space boundaries of 2theta scan (bounds=False)
               tt,ttint,(qxb,qzb)2theta scan coordinates and intensities + reciprocal space bounds of
                   the extraced scan (bounds=True)
     Example
      >>>
xrayutilities.analysis.line_cuts.get_ttheta_scan_q(qx, qz, intensity, qxcenter,
                                                                        qzcenter, ttrange, npoints,
                                                                        **kwargs)
     extracts a twotheta scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               qxcenterqx-position at which the 2theta scan should be extracted
               qzcenterqz-position at which the 2theta scan should be extracted
               ttrangetwo theta range of the scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range in omega direction
               Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
      Returns
               tt,ttinttwo theta scan coordinates and intensities (bounds=False)
               om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space
                   bounds of the extraced scan (bounds=True)
     Example
      >>> ttc,cut_int = get_ttheta_scan_q(qx,qz,intensity,0.0,4.0,4.4,440)
xrayutilities.analysis.line_cuts.getindex(x, y, xgrid, ygrid)
      gives the indices of the point x,y in the grid given by xgrid ygrid xgrid,ygrid must be arrays containing
     equidistant points
     Parameters
```

```
x,ycoordinates of the point of interest (float)
               xgrid,ygridgrid coordinates in x and y direction (array)
     Returns
               ix,iyindex of the closest gridpoint (lower left) of the point (x,y)
line cuts3d Module
xrayutilities.analysis.line_cuts3d.get_qx_scan3d(gridder,
                                                                                            qzpos,
                                                                                 qypos,
                                                                    **kwargs)
     extract qx line scan at position y,z from a gridded reciprocal space map by taking the closest line of the
     intensity matrix, or summing up a given area around this position
     Parameters
               gridder3d xrayutilities.Gridder3D object containing the data
               qypos,qzposposition at which the line scan should be extracted
     **kwargs: possible keyword arguments:
               qrangeintegration range perpendicular to scan direction
               qmin,qmaxminimum and maximum value of extracted scan axis
     Returns
               qx,qxintqx scan coordinates and intensities
     Example
     >>> qxcut,qxcut_int = get_qx_scan3d(gridder,0,0,qrange=0.03)
xrayutilities.analysis.line_cuts3d.get_qy_scan3d(gridder,
                                                                                 qxpos,
                                                                                            qzpos,
                                                                    **kwargs)
     extract qy line scan at position x,z from a gridded reciprocal space map by taking the closest line of the
     intensity matrix, or summing up a given area around this position
     Parameters
               gridder3d xrayutilities.Gridder3D object containing the data
               qxpos,qzposposition at which the line scan should be extracted
      **kwargs: possible keyword arguments:
               qrangeintegration range perpendicular to scan direction
               qmin,qmaxminimum and maximum value of extracted scan axis
     Returns
               qy,qyintqy scan coordinates and intensities
     Example
     >>> qycut,qycut_int = get_qy_scan3d(gridder,0,0,grange=0.03)
xrayutilities.analysis.line_cuts3d.get_qz_scan3d(gridder,
                                                                                 qxpos,
                                                                                            gypos,
                                                                    **kwargs)
     extract qz line scan at position x,y from a gridded reciprocal space map by taking the closest line of the
     intensity matrix, or summing up a given area around this position
```

gridder3d xrayutilities.Gridder3D object containing the data

4.2. xrayutilities Package

Parameters

```
qxpos,qyposposition at which the line scan should be extracted
      **kwargs: possible keyword arguments:
               qrangeintegration range perpendicular to scan direction
               qmin,qmaxminimum and maximum value of extracted scan axis
     Returns
               qz,qzintqz scan coordinates and intensities
     Example
     >>> qzcut,qzcut_int = get_qz_scan3d(gridder,0,0,qrange=0.03)
xrayutilities.analysis.line_cuts3d.getindex3d(x, y, z, xgrid, ygrid, zgrid)
     gives the indices of the point x,y,z in the grid given by xgrid ygrid xgrid,ygrid,ygrid,zgrid must be arrays
     containing equidistant points
     Parameters
               x,y,zcoordinates of the point of interest (float)
               xgrid,ygrid,zgridgrid coordinates in x,y,z direction (array)
     Returns
               ix,iy,iz index of the closest gridpoint (lower left) of the point (x,y,z)
misc Module
miscellaneous functions helpful in the analysis and experiment
xrayutilities.analysis.misc.getangles(peak, sur, inp)
     calculates the chi and phi angles for a given peak
     Parameter
               peakarray which gives hkl for the peak of interest
               surhkl of the surface
               inpinplane reference peak or direction
     Returns
           [chi,phi] for the given peak on surface sur with inplane direction inp as reference
     Example
          To get the angles for the -224 peak on a 111 surface type[chi,phi]
                                                                                         getangles([-
               2,2,4],[1,1,1],[2,2,4])
sample_align Module
functions to help with experimental alignment during experiments, especially for experiments with linear detectors
xrayutilities.analysis.sample aliqn.area detector calib(angle1,
                                                                                             angle2.
                                                                              ccdimages,
                                                                                                 de-
                                                                              taxis, r_i, plot=True,
                                                                              cut off=0.7, start=(0,
                                                                              0, 0, 0), fix=(False,
                                                                              False, False, False),
                                                                              fig=None, wl=None
```

function to calibrate the detector parameters of an area detector it determines the detector tilt possible

```
rotations and offsets in the detector arm angles parameters
```

```
angle1outer detector arm angle
angle2inner detector arm angle
ccdimagesimages of the ccd taken at the angles given above
detaxisdetector arm rotation axis :default: ['z+','y-']
r_iprimary beam direction [xyz][+-] default 'x+'
```

Keyword_arguments

plotflag to determine if results and intermediate results should be plotted :default: True

cut_offcut off intensity to decide if image is used for the determination or not :default: 0.7 = 70%

startsequence of start values of the fit for parameters, which can not be estimated automatically these are: tiltazimuth,tilt,detector_rotation,outerangle_offset. By default (0,0,0,0) is used.

fixfix parameters of start (default: (False,False,False,False))

figmatplotlib figure used for plotting the error :default: None (creates own figure)

wlwavelength of the experiment in Angstrom (default: config.WAVELENGTH) value does not matter here and does only affect the scaling of the error

```
xrayutilities.analysis.sample aliqn.area detector calib hkl(sampleang,
```

```
angle1, angle2,
ccdimages, hkls,
experiment, ma-
terial,
        detaxis,
r_i, plot=True,
cut\_off=0.1,
start=(0, 0, 0,
0, 0, 0, 'con-
fig'), fix=(False,
False,
           False,
False,
           False,
False.
          False),
fig=None)
```

function to calibrate the detector parameters of an area detector it determines the detector tilt possible rotations and offsets in the detector arm angles

in this variant not only scans through the primary beam but also scans at a set of symmetric reflections can be used for the detector parameter determination. for this not only the detector parameters but in addition the sample orientation and wavelength need to be fit.

parameters

sampleangsample rocking angle (needed to align the reflections (same rotation direction as inner detector rotation)) other sample angle are not allowed to be changed during the scans

angle1outer detector arm angle

angle2inner detector arm angle

ccdimagesimages of the ccd taken at the angles given above

hklsarray/list of hkl values for every image

```
material material used as reference crystal
```

detaxisdetector arm rotation axis :default: ['z+','y-']

r_iprimary beam direction [xyz][+-] default 'x+'

Keyword_arguments

plotflag to determine if results and intermediate results should be plotted :default:

cut_offcut off intensity to decide if image is used for the determination or not :default: 0.7 = 70%

startsequence of start values of the fit for parameters, which can not be estimated automatically these are: tiltazimuth,tilt,detector_rotation,outerangle_offset, stilt,stazimuth, wavelength. By default (0,0,0,0,0,0,config') is used.

fixfix parameters of start (default: (False,False,False,False,False,False,False,False))

figmatplotlib figure used for plotting the error :default: None (creates own figure)

helper function to determine the Bragg peak position in a reciprocal space map used to obtain the position needed for correction of the data. the determination is done by fitting a two dimensional Gaussian (xrayutilities.math.Gauss2d)

PLEASE ALWAYS CHECK THE RESULT CAREFULLY!

Parameter

om,ttangular coordinates of the measurement (numpy.ndarray) either with size of psd or of psd.shape[0]

psdintensity values needed for fitting

omalignaligned omega value, used as first guess in the fit

ttalignaligned two theta values used as first guess in the fit these values are also used to set the range for the fit: the peak should be within +/-frangeAA^{-1} of those values

exphxrdexperiment class used for the conversion between angular and reciprocal space.

frangedata range used for the fit in both directions (see above for details default: (0.03,0.03) unit: AA^{-1})

plotif True (default) function will plot the result of the fit in comparison with the measurement.

Returns

Omfit,ttfit,params,covariance fitted angular values, and the fit parameters (of the Gaussian) as well as their errors

function to calibrate the detector distance/channel per degrees for a straight linear detector mounted on a detector arm

parameters

anglearray of angles in degree of measured detector spectra

mca_spectracorresponding detector spectra :(shape: (len(angle),Nchannels)

**keyargs passed to psd_chdeg function used for the modelling, additional options are:

```
r_iprimary beam direction as vector [xyz][+-]; default: 'y+' detaxisdetector arm rotation axis [xyz][+-] e.g. 'x+'; default: 'x+'
```

selected options from psd_chdeg:

plotflag to specify if a visualization of the fit should be done

usetiltwhether to use model considering a detector tilt (deviation angle of the pixel direction from orthogonal to the primary beam) (default: True)

Note: Note: see help of psd_chdeg for more options

returns

pixelwidth (at one meter distance) , center_channel[, detector_tilt]

Note: Note: L/pixelwidth*pi/180 ~= channel/degree, with the sample detector distance L

pixelwidth is negative in case the hit channel number decreases upon an increase of the detector angle The function also prints out how a linear detector can be initialized using the results obtained from this calibration. Carefully check the results

function to calculate the miscut direction and miscut angle of a sample by fitting a sinusoidal function to the variation of the aligned omega values of more than two reflections. The function can also be used to fit reflectivity alignment values in various azimuths.

Parameters

 ${\bf phi}$ azimuths in which the reflection was aligned (deg)

aomegaaligned omega values (deg)

zeros(optional) angles at which surface is parallel to the beam (deg). For the analysis the angles (aomega-zeros) are used.

omega0if specified the nominal value of the reflection is not included as fit parameter, but is fixed to the specified value. This value is MANDATORY if ONLY TWO AZIMUTHs are given.

plotflag to specify if a visualization of the fit is wanted. :default: True

Returns

[omega0,phi0,miscut]

list with fitted values for

 $omega\ 0\\$ the omega value of the reflection should be close to the nominal one

phi0the azimuth in which the primary beam looks upstairs

miscutamplitude of the sinusoidal variation == miscut angle

function to determine the channels per degree using a linear fit of the function nchannel = center_ch+chdeg*tan(angles) or the equivalent including a detector tilt

Parameters

angles detector angles for which the position of the beam was measured channels detector channels where the beam was found

keyword arguments:

stdevstandard deviation of the beam position

plotflag to specify if a visualization of the fit should be done

usetiltwhether to use model considering a detector tilt (deviation angle of the pixel direction from orthogonal to the primary beam) (default: True)

datapplot format of data points

modellineplot format of modelline

modeltiltplot format of modeltilt

fignumfigure number to use for the plot

mlabellabel of the model w/o tilt to be used in the plot

mtiltlabellabel of the model with tilt to be used in the plot

dlabellabel of the data line to be used in the plot

figtitleboolean to tell if the figure title should show the fit parameters

Returns

(pixelwidth,centerch,tilt)

Pixelwidth the width of one detector channel @ 1m distance, which is negative in case the hit channel number decreases upon an increase of the detector angle.

Centerch center channel of the detector

Tilt tilt of the detector from perpendicular to the beam (will be zero in case of usetilt=False)

Note: Note: L/pixelwidth*pi/180 = channel/degree for large detector distance with the sample detector distance L

```
xrayutilities.analysis.sample_align.psd_refl_align(primarybeam, angles, chan-
nels, plot=True)
```

function which calculates the angle at which the sample is parallel to the beam from various angles and detector channels from the reflected beam. The function can be used during the half beam alignment with a linear detector.

Parameters

```
primary beam channel number
```

angles list or numpy.array with angles

channels list or numpy array with corresponding detector channels

plotflag to specify if a visualization of the fit is wanted :default: True

Returns

omegaangle at which the sample is parallel to the beam

Example

```
>>> psd_refl_align(500,[0,0.1,0.2,0.3],[550,600,640,700])
```

io Package

io Package

edf Module

Parses a directory for EDF files, which can be stored to a HDF5 file for further usage

```
Save2HDF5 (h5, group='', comp=True)
```

Saves the data stored in the EDF files in the specified directory in a HDF5 file as a HDF5 arrays in a subgroup. By default the data is stored in a group given by the foldername - this can be changed by passing the name of a target group or a path to the target group via the "group" keyword argument.

required arguments. :h5: a HDF5 file object

optional keyword arguments: :group: group where to store the data (defaults to pathname if group is empty string) :comp: activate compression - true by default

Bases: object

ReadData()

Read the CCD data into the .data object this function is called by the initialization

```
Save2HDF5 (h5, group='/', comp=True)
```

Saves the data stored in the EDF file in a HDF5 file as a HDF5 array. By default the data is stored in the root group of the HDF5 file - this can be changed by passing the name of a target group or a path to the target group via the "group" keyword argument.

required arguments. :h5: a HDF5 file object

optional keyword arguments: :group: group where to store the data (default to the root of the file) :comp: activate compression - true by default

imagereader Module

Bases: object

parse CCD frames in the form of tiffs or binary data (*.bin) to numpy arrays. ignore the header since it seems to contain no useful data

The routine was tested so far withRoperScientific files with 4096x4096 pixels created at Hasylab Hamburg, which save an 16bit integer per point. Perkin Elmer images created at Hasylab Hamburg with 2048x2048 pixels.

readImage (filename)

read image file and correct for dark- and flatfield in case the necessary data are available.

returned data = ((image data)-(darkfield))/flatfield*average(flatfield)

Parameter

filenamefilename of the image to be read. so far only single filenames are supported. The data might be compressed. supported extensions: .tiff, .bin and .bin.xz

```
class xrayutilities.io.imagereader.PerkinElmer(**keyargs)
```

Bases: xrayutilities.io.imagereader.ImageReader

parse PerkinElmer CCD frames (*.bin) to numpy arrays Ignore the header since it seems to contain no useful data

The routine was tested only for files with 2048x2048 pixel images created at Hasylab Hamburg which save an 32bit float per point.

```
class xrayutilities.io.imagereader.RoperCCD(**keyargs)
    Bases: xrayutilities.io.imagereader.ImageReader
```

parse RoperScientific CCD frames (*.bin) to numpy arrays Ignore the header since it seems to contain no useful data

The routine was tested only for files with 4096x4096 pixel images created at Hasylab Hamburg which save an 16bit integer per point.

panalytical_xml Module

Panalytical XML (www.XRDML.com) data file parser

based on the native python xml.dom.minidom module. want to keep the number of dependancies as small as possible

```
class xrayutilities.io.panalytical_xml.XRDMLFile (fname)
    Bases: object
```

class to handle XRDML data files. The class is supplied with a file name and uses the XRDMLScan class to parse the xrdMeasurement in the file

```
class xrayutilities.io.panalytical_xml.XRDMLMeasurement (measurement)
     Bases: object
```

class to handle scans in a XRDML datafile

```
xrayutilities.io.panalytical_xml.getOmPixcel(omraw, ttraw)
```

function to reshape the Omega values into a form needed for further treatment with xrayutilities

parses multiple XRDML file and concatenates the results for parsing the xrayutilities.io.XRDMLFile class is used. The function can be used for parsing maps measured with the PIXCel and point detector.

Parameter

filetemplatetemplate string for the file names, can contain a %d which is replaced by the scan number or be a list of filenames

scannrsint or list of scan numbers

pathcommon path to the filenames

roiregion of interest for the PIXCel detector, for other measurements this i not usefull!

Returns

om,tt,psdas flattened numpy arrays

Example

```
>>> om,tt,psd = xrayutilities.io.getxrdml_map("samplename_%d.xrdml",[1,2],path="./data")
```

radicon Module

python module for converting radicon data to HDF5

```
xrayutilities.io.radicon.hst2hdf5 (h5, hstfile, nofchannels, h5path='/', hstpath='.')
Converts a HST file to an HDF5 file.
```

Required input arguments:

h5HDF5 object where to store the data

hstfilename of the HST file

nofchannelsnumber of channels

optional input arguments:

h5pathPath in the HDF5 file where to store the data

hstpathpath where the HST file is located (default is the current working directory)

xrayutilities.io.radicon.rad2hdf5(h5, rdcfile, h5path='/', rdcpath='.')

Converts a RDC file to an HDF5 file.

Required input arguments:

h5HDF5 object where to store the data

rdcfilename of the RDC file

optional input arguments:

h5pathPath in the HDF5 file where to store the data (default to root)

rdcpathpath where the RDC file is located (default is the current working directory)

```
xrayutilities.io.radicon.selecthst(et_limit, mca_info, mca_array)
```

Select historgrams form the complete set of recorded MCA data and stores it into a new numpy array. The selection is done due to a exposure time limit. Spectra below this limit are ignored.

required input arguments:

et limitexposure time limit

mca_infopytables table with the exposure data

mca_arrayarray with all the MCA spectra

return value: a numpy array with the selected mca spectra of shape (hstnr,channels).

rotanode_alignment Module

parser for the alignment log file of the rotating anode

```
class xrayutilities.io.rotanode_alignment.RA_Alignment (filename)
    Bases: object
```

class to parse the data file created by the alignment routine (tpalign) at the rotating anode spec installation

this routine does an iterative alignment procedure and saves the center of mass values were it moves after each scan. It iterates between two different peaks and iteratively aligns at each peak between two different motors (om/chi at symmetric peaks, om/phi at asymmetric peaks)

Parse (

parser to read the alignment log and obtain the aligned values at every iteration.

get (key)

keys()

returns a list of keys for which aligned values were parsed

plot (pname)

function to plot the alignment history for a given peak

Parameters

pnamepeakname for which the alignment should be plotted

seifert Module

a set of routines to convert Seifert ASCII files to HDF5 in fact there exist two posibilities how the data is stored (depending on the use detector):

- 1. as a simple line scan (using the point detector)
- 2. as a map using the PSD

In the first case the data ist stored

```
{\bf class} \; {\tt xrayutilities.io.seifert. \bf Seifert Header} \\ Bases: {\tt object}
```

```
save_h5_attribs(obj)
```

class xrayutilities.io.seifert.SeifertMultiScan (filename, m_scan, m2, path=None)
 Bases: object

```
dump2hdf5 (h5, iname='INT', group='/')
```

Saves the content of a multi-scan file to a HDF5 file. By default the data is stored in the root group of the file. To save data somewhere else the keyword argument "group" must be used.

required arguments:

h5a HDF5 file object

optional keyword arguments:

inamename for the intensity matrix

grouppath to the HDF5 group where to store the data

```
dump2mlab (fname, *args)
```

Store the data in a matlab file.

```
parse()
```

class xrayutilities.io.seifert.SeifertScan (filename, path=None)

Bases: object

```
dump2h5 (h5, *args, **keyargs)
```

Save the data stored in the Seifert ASCII file to a HDF5 file.

required input arguments:

h5HDF5 file object

optional arguments:

names to use to store the motors. The first must be the name for the intensity array. The number of names must be equal to the second element of the shape of the data object.

optional keyword arguments:

groupHDF5 group object where to store the data.

```
dump2mlab (fname, *args)
```

Save the data from a Seifert scan to a matlab file.

required input arugments:

fnamename of the matlab file

optional position arguments:

names to use to store the motors. The first must be the name for the intensity array. The number of names must be equal to the second element of the shape of the data object.

```
parse()
```

parses multiple Seifert *.nja files and concatenates the results. for parsing the xrayutilities.io.SeifertMultiScan class is used. The function can be used for parsing maps measured with the Meteor1D and point detector.

Parameter

filetemplatetemplate string for the file names, can contain a %d which is replaced by the scan number or be a list of filenames

scannrsint or list of scan numbers

pathcommon path to the filenames

scantypetype of datafile: "map": reciprocal space map measured with a regular Seifert job "tsk": MCA spectra measured using the TaskInterpreter

Nchannelsnumber of channels of the MCA (needed for "tsk" measurements)

Returns

om,tt,psdas flattened numpy arrays

Example

```
>>> om,tt,psd = xrayutilities.io.getSeifert_map("samplename_%d.xrdml",[1,2],path="./data")
xrayutilities.io.seifert.repair key(key)
```

Repair a key string in the sense that the string is changed in a way that it can be used as a valid Python identifier. For that purpose all blanks within the string will be replaced by _ and leading numbers get an preceeding _.

spec Module

a threaded class for observing a SPEC data file

Motivation

SPEC files can become quite large. Therefore, subsequently reading the entire file to extract a single scan is a quite cumbersome procedure. This module is a proof of concept code to write a file observer starting a reread of the file starting from a stored offset (last known scan position)

```
class xrayutilities.io.spec.SPECCmdLine (n, prompt, cmdl, out)
     Bases: object
     Save2HDF5 (h5, **keyargs)
class xrayutilities.io.spec.SPECFile (filename, path='')
     Bases: object
```

This class represents a single SPEC file. The class provides methodes for updateing an already opened file which makes it particular interesting for interactive use.

Parse()

Parses the file from the starting at last offset and adding found scans to the scan list.

```
Save2HDF5 (h5f, comp=True)
```

Save the entire file in an HDF5 file. For that purpose a group is set up in the root group of the file with the name of the file without extension and leading path. If the method is called after an previous update only the scans not written to the file meanwhile are saved.

required arguments:

h5fa HDF5 file object or its filename

optional keyword arguments:

```
compactivate compression - true by default
```

Update()

reread the file and add newly added files. The parsing starts at the data offset of the last scan gathered during the last parsing run.

```
class xrayutilities.io.spec.SPECLog(filename, prompt, path='')
    Bases: object
    Parse()
    Update()
```

class xrayutilities.io.spec.SPECMCA(nchan, roistart, roistop)

Bases: object

SPECMCA - represents an MCA object in a SPEC file. This class is an abstract class not itended for being used directly. Instead use one of the derived classes SPECMCAFile or SPECMCAInline.

```
class xrayutilities.io.spec.SPECMCAFile
    Bases: xrayutilities.io.spec.SPECMCA
    ReadData()
```

class xrayutilities.io.spec.SPECMCAInline
 Bases: xrayutilities.io.spec.SPECMCA

ReadData()

Bases: object

Represents a single SPEC scan.

ClearData()

Delete the data stored in a scan after it is no longer used.

ReadData()

Set the data attribute of the scan class.

```
Save2HDF5 (h5f, group='/', title='', desc='', optattrs={}, comp=True)
```

Save a SPEC scan to an HDF5 file. The method creates a group with the name of the scan and stores the data there as a table object with name "data". By default the scan group is created under the root group of the HDF5 file. The title of the scan group is ususally the scan command. Metadata of the scan are stored as attributes to the scan group. Additional custom attributes to the scan group can be passed as a dictionary via the optatrs keyword argument.

input arguments:

h5fa HDF5 file object or its filename

optional keyword arguments:

groupname or group object of the HDF5 group where to store the data

titlea string with the title for the data, defaults to the name of scan if empty

desca string with the description of the data, defaults to the scan command if empty

optattrsa dictionary with optional attributes to store for the data

compactivate compression - true by default

SetMCAParams (mca_column_format, mca_channels, mca_start, mca_stop)

Set the parameters used to save the MCA data to the file. This method calculates the number of lines used to store the MCA data from the number of columns and the

required input aguments:

mca_column_formatnumber of columns used to save the data

mca_channelsnumber of MCA channels stored

mca_startfirst channel that is stored

mca stoplast channel that is stored

```
plot (*args, **keyargs)
```

Plot scan data to a matplotlib figure. If newfig=True a new figure instance will be created. If logy=True (default is False) the y-axis will be plotted with a logarithmic scale.

Parameters

*args: arguments for the plot: first argument is the name of x-value columnthe following pairs of arguments are the y-value names and plot styles allowed are 3,5,7,... number of arguments

**keyargs:

newfigif True a new figure instance will be created otherwise an existing one will be used

logyif True a semilogy plot will be done

```
xrayutilities.io.spec.geth5_scan (h5f, scans, *args, **kwargs)
```

function to obtain the angular cooridinates as well as intensity values saved in an HDF5 file, which was created from a spec file by the Save2HDF5 method. Especially usefull for reciprocal space map measurements.

further more it is possible to obtain even more positions from the data file if more than two string arguments with its names are given

Parameters

h5ffile object of a HDF5 file opened using pytables or its filename

scans number of the scans of the reciprocal space map (int,tuple or list)

*args: names of the motors (optional) (strings) to read reciprocal space maps measured in coplanar diffraction give: :omname: e.g. name of the omega motor (or its equivalent) :ttname: e.g. name of the two theta motor (or its equivalent)

**kwargs (optional):

samplenamestring with the hdf5-group containing the scan data if ommitted the first child node of h5f.root will be used

Returns

MAP

or

[ang1,ang2,...],MAP:angular positions of the center channel of the position sensitive detector (numpy.ndarray 1D) together with all the data values as stored in the data file (includes the intensities e.g. MAP['MCA']).

Example

```
>>> [om,tt], MAP = xu.io.geth5_scan(h5file,36,'omega','gamma')
```

spectra Module

module to handle spectra data

Bases: object

Represents a SPECTRA data file. The file is read during the Constructor call. This class should work for data stored at beamlines P08 and BW2 at HASYLAB.

Required constructor arguments:

filenamea string with the name of the SPECTRA file

Optional keyword arguments:

mcatmptemplate for the MCA files

mcastart,mcastopstart and stop index for the MCA files, if not given, the class tries to determine the start and stop index automatically.

Read()

Read the data from the file.

ReadMCA()

Save2HDF5 (h5file, name, group='/', description='SPECTRA scan', mcaname='MCA')

Saves the scan to an HDF5 file. The scan is saved to a seperate group of name "name". h5file is either a string for the file name or a HDF5 file object. If the mca attribute is not None mca data will be stored to an chunked array of with name mcaname.

required input arguments:

h5filestring or HDF5 file object

namename of the group where to store the data

optional keyword arguments:

grouproot group where to store the data

description string with a description of the scan

Return value: The method returns None in the case of everything went fine, True otherwise.

```
class xrayutilities.io.spectra.SPECTRAFileComments
```

Bases: dict

Class that describes the comments in the header of a SPECTRA file. The different comments are accessible via the comment keys.

```
class xrayutilities.io.spectra.SPECTRAFileData
```

Bases: object append (col)

class xrayutilities.io.spectra.SPECTRAFileDataColumn (index, name, unit, type)

Bases: object

 ${\bf class} \; {\tt xrayutilities.io.spectra.SPECTRAFileParameters}$

Bases: dict

class xrayutilities.io.spectra.Spectra(data_dir)

Bases: object

abs_corr (data, f, **keyargs)

Perform absorber correction. Data can be either a 1 dimensional data (point detector) or a 2D MCA array. In the case of an array the data array should be of shape (N,NChannels) where N is the number of points in the scan an NChannels the number of channels of the MCA. The absorber values are passed to the function as a 1D array of N elements.

By default the absorber values are taken form a global variable stored in the module called _absorver_factors. Despite this, costume values can be passed via optional keyword arguments.

required input arguments:

mcamatrix with the MCA data

ffilter values along the scan

optional keyword arguments:

ffcustome filter factors

return value: Array with the same shape as mca with the corrected MCA data.

recarray2hdf5 (h5g, rec, name, desc)

Save a record array in an HDF5 file. A pytables table object is used to store the data.

required input arguments:

h5gHDF5 group object or path

recrecord array

namename of the table in the file

desc description of the table in the file

return value:

taba HDF5 table object

set_abs_factors(ff)

Set the global absorber factors in the module.

spectra2hdf5 (dir, fname, mcatemp, name='', desc='SPECTRA data')

Convert SPECTRA scan data to a HDF5 format.

required input arguments:

dirdirectory where the scan is stored

fnamename of the SPECTRA data file

mcatemptemplate for the MCA file names

optional keyword arguments:

nameoptional name under which to save the data if empty the basename of the filename will be used

descoptional description of the scan

```
xrayutilities.io.spectra.get_spectra_files(dirname)
```

Return a list of spectra files within a directory.

required input arguments:

dirnamename of the directory to search

return values: list with filenames

```
xrayutilities.io.spectra_geth5_spectra_map(h5file, scans, *args, **kwargs)
```

function to obtain the omega and twotheta as well as intensity values for a reciprocal space map saved in an HDF5 file, which was created from a spectra file by the Save2HDF5 method.

further more it is possible to obtain even more positions from the data file if more than two string arguments with its names are given

Parameters

h5ffile object of a HDF5 file opened using pytables

scans number of the scans of the reciprocal space map (int,tuple or list)

*args: arbitrary number of motor names (strings)

omnamename of the omega motor (or its equivalent)

ttnamename of the two theta motor (or its equivalent)

**kwargs (optional):

mcaname of the mca data (if available) otherwise None (default: "MCA")

samplenamestring with the hdf5-group containing the scan data if ommited the first child node of h5f.root will be used to determine the sample name

Returns

[ang1,ang2,...],MAP:angular positions of the center channel of the position sensitive detector (numpy.ndarray 1D) together with all the data values as stored in the data file (includes the intensities e.g. MAP['MCA']).

xrayutilities.io.spectra.read_data(fname)

Read a spectra data file (a file with now MCA data).

required input arguments:

fnamename of the file to read

return values: (data,hdr)

datanumpy record array where the keys are the column names

hdra dictionary with header information

xrayutilities.io.spectra.read_mca(fname)

Read a single SPECTRA MCA file.

required input arguments:

fnamename of the file to read

return value:

data numpy array with the MCA data

 $\verb|xrayutilities.io.spectra.read_mca_dir| (\textit{dirname}, \textit{filetemp}, \textit{sort=True})|$

Read all MCA files within a directory

xrayutilities.io.spectra.read_mcas (ftemp, cntstart, cntstop)

Read MCA data from a SPECTRA MCA directory. The filename is passed as a generic

materials Package

materials Package

```
_create_database Module
```

script to create the HDF5 database from the raw data of XOP this file is only needed for administration

```
_create_database_alt Module
```

script to create the HDF5 database from the raw data of XOP this file is only needed for administration

cif Module

```
class xrayutilities.materials.cif.CIFFile (filename)
    Bases: object
```

class for parsing CIF (Crystallographic Information File) files. The class aims to provide an additional way of creating material classes instead of manual entering of the information the lattice constants and unit cell structure are parsed from the CIF file

Lattice()

returns a lattice object with the structure from the CIF file

Parse (

function to parse a CIF file. The function reads the space group symmetry operations and the basic atom positions as well as the lattice constants and unit cell angles

SymStruct()

function to obtain the list of different atom positions in the unit cell for the different types of atoms. The data are obtained from the data parsed from the CIF file.

database Module

module to handle access to the optical parameters database

```
{\bf class} \; {\tt xrayutilities.materials.database.DataBase} \; ({\it fname})
```

Bases: object

Close()

Close an opend database file.

Create (dbname, dbdesc)

Creates a new database. If the database file already exists its content is delete.

required input arguments:

dbnamename of the database

dbdesca short description of the database

CreateMaterial (name, description)

This method creates a new material. If the material group already exists the procedure is aborted.

required input arguments:

namea string with the name of the material

description a string with a description of the material

GetF0(q)

Obtain the f0 scattering factor component for a particular momentum transfer q.

required input argument:

qsingle float value or numpy array

GetF1 (en)

Return the second, energy dependent, real part of the scattering factor for a certain energy en.

required input arguments:

enfloat or numpy array with the energy

GetF2 (en)

Return the imaginary part of the scattering factor for a certain energy en.

required input arguments:

enfloat or numpy array with the energy

Open (mode='r')

Open an existing database file.

SetF0 (parameters)

Save f0 fit parameters for the set material. The fit parameters are stored in the following order: c,a1,b1,....,a4,b4

required input argument:

parameters list or numpy array with the fit parameters

```
SetF1(en, fl)
          Set f1 tabels values for the active material.
          required input arguments:
                  enlist or numpy array with energy in (eV)
                  f1list or numpy array with f1 values
     SetF2 (en, f2)
          Set f2 tabels values for the active material.
          required input arguments:
                  enlist or numpy array with energy in (eV)
                  f2list or numpy array with f2 values
     SetMaterial (name)
          Set a particular material in the database as the actual material. All operations like setting and getting
          optical constants are done for this particular material.
          requiered input arguments:
                  namestring with the name of the material
     SetWeight (weight)
          Save weight of the element as float
          required input argument:
                  weight atomic standard weight of the element (float)
xrayutilities.materials.database.add f0 from intertab(db, itabfile)
     Read f0 data from international tables of crystallography and add it to the database.
xrayutilities.materials.database.add_f0_from_xop(db, xopfile)
     Read f0 data from f0_xop.dat and add it to the database.
xrayutilities.materials.database.add_f1f2_from_ascii_file(db, asciifile, ele-
                                                                              ment)
     Read f1 and f2 data for specific element from ASCII file (3 columns) and save it to the database.
xrayutilities.materials.database.add f1f2 from henkedb(db, henkefile)
     Read f1 and f2 data from Henke database and add it to the database.
xrayutilities.materials.database.add_f1f2_from_kissel(db, kisselfile)
     Read f1 and f2 data from Henke database and add it to the database.
xrayutilities.materials.database.add_mass_from_NIST(db, nistfile)
     Read atoms standard mass and save it to the database.
xrayutilities.materials.database.init material db(db)
elements Module
lattice Module
module handling crystal lattice structures
class xrayutilities.materials.lattice.Atom (name, num)
     Bases: object
     f (q, en='config')
          function to calculate the atomic structure factor F
          Parameter
                  qmomentum transfer
```

enenergy for which F should be calculated, if omitted the value from the xrayutilities configuration is used

```
Returns
             f (float)
     f0(q)
     f1 (en='config')
    f2 (en='config')
xrayutilities.materials.lattice.BCCLattice (aa, a)
xrayutilities.materials.lattice.BCTLattice (aa, a, c)
xrayutilities.materials.lattice.BaddeleyiteLattice(aa, ab, a, b, c, beta,
                                                             deg=True)
xrayutilities.materials.lattice.CuMnAsLattice (aa, ab, ac, a, b, c)
xrayutilities.materials.lattice.CubicFm3mBaF2 (aa, ab, a)
xrayutilities.materials.lattice.CubicLattice(a)
    Returns a Lattice object representing a simple cubic lattice.
    required input arguments:
             alattice parameter
    return value: an instance of Lattice class
xrayutilities.materials.lattice.DiamondLattice(aa, a)
xrayutilities.materials.lattice.FCCLattice (aa, a)
xrayutilities.materials.lattice.GeTeRhombohedral (aa, ab, a, ang, x=0.237)
xrayutilities.materials.lattice.GeneralPrimitiveLattice(a, b, c, alpha, beta,
                                                                   gamma)
xrayutilities.materials.lattice.HCPLattice(aa, a, c)
xrayutilities.materials.lattice.Hexagonal3CLattice(aa, ab, a, c)
xrayutilities.materials.lattice.Hexagonal4HLattice (aa, ab, a, c, u=0.1875,
                                                             v1=0.25, v2=0.4375)
xrayutilities.materials.lattice.Hexagonal6HLattice (aa, ab, a, c)
class xrayutilities.materials.lattice.Lattice(a1, a2, a3, base=None)
    Bases: object
    class Lattice: This object represents a Bravais lattice. A lattice consists of a base
    ApplyStrain (eps)
         Applies a certain strain on a lattice. The result is a change in the base vectors.
         requiered input arguments:
                epsa 3x3 matrix independent strain components
     GetPoint (*args)
         determine lattice points with indices given in the argument
         >>> xu.materials.Si.lattice.GetPoint(0,0,4)
                       , 0. , 21.72416])
         array([ 0.
         or
```

```
>>> xu.materials.Si.lattice.GetPoint((1,1,1))
         array([ 5.43104, 5.43104, 5.43104])
     ReciprocalLattice()
     UnitCellVolume()
         function to calculate the unit cell volume of a lattice (angstrom^3)
class xrayutilities.materials.lattice.LatticeBase(*args, **keyargs)
     Bases: list
     The LatticeBase class implements a container for a set of points that form the base of a crystal lattice. An
     instance of this class can be treated as a simple container object.
     append (atom, pos, occ=1.0, b=0.0)
         add new Atom to the lattice base
         Parameter
                 atomatom object to be added
                 posposition of the atom
                 occoccupancy (default=1.0)
                 bb-factor of the atom used as \exp(-b*q**2/(4*pi)**2) to reduce the intensity of this
                   atom (only used in case of temp=0 in StructureFactor and chi calculation)
xrayutilities.materials.lattice.NaumanniteLattice (aa, ab, a, b, c)
xrayutilities.materials.lattice.NiAsLattice (aa, ab, a, c, biso=0.0)
xrayutilities.materials.lattice.PerovskiteTypeRhombohedral(aa, ab, ac, a, ang)
xrayutilities.materials.lattice.QuartzLattice(aa, ab, a, b, c)
xrayutilities.materials.lattice.RockSaltLattice(aa, ab, a)
xrayutilities.materials.lattice.RockSalt_Cubic_Lattice(aa, ab, a)
xrayutilities.materials.lattice.RutileLattice (aa, ab, a, c, u)
xrayutilities.materials.lattice.TetragonalIndiumLattice(aa, a, c)
xrayutilities.materials.lattice.TetragonalTinLattice (aa, a, c)
xrayutilities.materials.lattice.TrigonalR3mh (aa, a, c)
xrayutilities.materials.lattice.WurtziteLattice(aa, ab, a, c, u=0.375, biso=0.0)
xrayutilities.materials.lattice.ZincBlendeLattice(aa, ab, a)
material Module
class module implements a certain material
class xrayutilities.materials.material.Alloy (matA, matB, x)
     Bases: xrayutilities.materials.material.Material
     RelaxationTriangle (hkl, sub, exp)
         function which returns the relaxation triangle for a Alloy of given composition. Reciprocal space
         coordinates are calculated using the user-supplied experimental class
         Parameter
                 hklMiller Indices
                 subsubstrate material or lattice constant (Instance of Material class or float)
                 expExperiment class from which the Transformation object and ndir are needed
```

Returns

qy,qzreciprocal space coordinates of the corners of the relaxation triangle

lattice_const_AB (latA, latB, x)

method to set the composition of the Alloy. x is the atomic fraction of the component B

x

```
xrayutilities.materials.material.Cij2Cijkl(cij)
```

Converts the elastic constants matrix (tensor of rank 2) to the full rank 4 cijkl tensor.

required input arguments:

cij(6,6) cij matrix as a numpy array

return value:

cijkl(3,3,3,3) cijkl tensor as numpy array

```
xrayutilities.materials.material.Cijkl2Cij(cijkl)
```

Converts the full rank 4 tensor of the elastic constants to the (6,6) matrix of elastic constants.

required input arguments:

cijkl(3,3,3,3) cijkl tensor as numpy array

return value:

cij(6,6) cij matrix as a numpy array

```
{f class} xrayutilities.materials.material.CubicAlloy (matA, matB, x)
```

Bases: xrayutilities.materials.material.Alloy

ContentBasym (q_inp, q_perp, hkl, sur)

function that determines the content of B in the alloy from the reciprocal space position of an asymmetric peak and also sets the content in the current material

Parameter

- \mathbf{q} _inpinplane peak position of reflection hkl of the alloy in reciprocal space
- q_perpperpendicular peak position of the reflection hkl of the alloy in reciprocal space

hklMiller indices of the measured asymmetric reflection

surMiller indices of the surface (determines the perpendicular direction)

Returns

content,[a_inplane,a_perp,a_bulk_perp(x), eps_inplane, eps_perp] :the content of B in the alloy determined from the input variables and the lattice constants calculated from the reciprocal space positions as well as the strain (eps) of the layer

ContentBsym (*q_perp*, *hkl*, *inpr*, *asub*, *relax*)

function that determines the content of B in the alloy from the reciprocal space position of a symetric peak. As an additional input the substrates lattice parameter and the degree of relaxation must be given

Parameter

q_perpperpendicular peak position of the reflection hkl of the alloy in reciprocal space

hklMiller indices of the measured symmetric reflection (also defines the surface normal

inprMiller indices of a Bragg peak defining the inplane reference direction

asubsubstrate lattice constant

relaxdegree of relaxation (needed to obtain the content from symmetric reciprocal space position)

```
Returns
```

```
contentthe content of B in the alloy determined from the input variables
```

```
xrayutilities.materials.material.CubicElasticTensor(c11, c12, c44)
```

Assemble the 6x6 matrix of elastic constants for a cubic material from the three independent components of a cubic crystal

Parameter

c11,c12,c44independent components of the elastic tensor of cubic materials

Returns

6x6 materix with elastic constants

```
xrayutilities.materials.material.GeneralUC(a=4, b=4, c=4, alpha=90, beta=90, gamma=90, name='General')
```

general material with primitive unit cell but possibility for different a,b,c and alpha,beta,gamma

Parameters

a,b,cunit cell extensiions (Angstrom)

alphaangle between unit cell vectors b,c

betaangle between unit cell vectors a,c

gammaangle between unit cell vectors a,b

returns a Material object with the specified properties

```
xrayutilities.materials.material.HexagonalElasticTensor(c11, c12, c13, c33,
```

Assemble the 6x6 matrix of elastic constants for a hexagonal material from the five independent components of a hexagonal crystal

Parameter

c11,c12,c13,c33,c44independent components of the elastic tensor of a hexagonal material

Returns

6x6 materix with elastic constants

```
class xrayutilities.materials.material.Material(name, lat, cij=None, thetaDe-bye=None)
```

Bases: object

ApplyStrain (strain, **keyargs)

в

GetMismatch (mat)

Calculate the mismatch strain between the material and a second material

Q (*hkl)

Return the Q-space position for a certain material.

required input arguments:

hkllist or numpy array with the Miller indices (or Q(h,k,l) is also possible)

```
StructureFactor (q, en='config', temp=0)
```

caluclates the structure factor of a material for a certain momentum transfer and energy at a certain temperature of the material

Parameter

 ${\bf q} vectorial\ momentum\ transfer\ (vectors\ as\ list, tuple\ or\ numpy\ array\ are\ valid)$

enenergy in eV, if omitted the value from the xrayutilities configuration is used

```
Returns
          the complex structure factor
StructureFactorForEnergy (q0, en, temp=0)
     caluclates the structure factor of a material for a certain momentum transfer and a bunch of energies
     Parameter
              q0vectorial momentum transfer (vectors as list, tuple or numpy array are valid)
              enlist, tuple or array of energy values in eV
              temptemperature used for Debye-Waller-factor calculation
     Returns
          complex valued structure factor array
StructureFactorForQ (q, en\theta = 'config', temp = \theta)
     caluclates the structure factor of a material for a bunch of momentum transfers and a certain energy
     Parameter
              qvectorial momentum transfers; list of vectores (list, tuple or array) of length 3 e.g.:
                 (Si.Q(0,0,4),Si.Q(0,0,4.1),...) or numpy.array([Si.Q(0,0,4),Si.Q(0,0,4.1)])
              en0energy value in eV, if omitted the value from the xrayutilities configuration is
                 used
              temptemperature used for Debye-Waller-factor calculation
     Returns
          complex valued structure factor array
a1
a2
a3
b1
b2
b3
beta (en='config')
     function to calculate the imaginary part of the deviation of the refractive index from 1 (n=1-
     delta+i*beta)
     Parameter
              enx-ray energy eV, if omitted the value from the xrayutilities configuration is used
     Returns
          beta (float)
chi0 (en='config')
     calculates the complex chi_0 values often needed in simulations. They are closely related to delta and
     beta (n = 1 + chi_r0/2 + i*chi_i0/2 \text{ vs. } n = 1 - delta + i*beta)
chih (q, en='config', temp=0, polarization='S')
     calculates the complex polarizability of a material for a certain momentum transfer and energy
     Parameter
              qmomentum transfer in (1/A)
              enxray energy in eV, if omitted the value from the xrayutilities configuration is used
```

temptemperature used for Debye-Waller-factor calculation

```
temptemperature used for Debye-Waller-factor calculation
              polarizationeither 'S' (default) sigma or 'P' pi polarization
     Returns
          (abs(chih_real),abs(chih_imag)) complex polarizability
critical_angle (en='config', deg=True)
     calculate critical angle for total external reflection
     Parameter
              enenergy of the x-rays, if omitted the value from the xrayutilities configuration is
              degreturn angle in degree if True otherwise radians (default:True)
     Returns
          Angle of total external reflection
dTheta (Q, en='config')
     function to calculate the refractive peak shift
     Parameter
              Qmomentum transfer (1/A)
              enx-ray energy (eV), if omitted the value from the xrayutilities configuration is used
     Returns
              deltaThetapeak shift in degree
delta(en='config')
     function to calculate the real part of the deviation of the refractive index from 1 (n=1-delta+i*beta)
     Parameter
              enx-ray energy eV, if omitted the value from the xrayutilities configuration is used
     Returns
          delta (float)
distances()
     function to obtain distances of atoms in the crystal up to the unit cell size (largest value of a,b,c is the
     returns a list of tuples with distance d and number of occurence n [(d1,n1),(d2,n2),...]
     Note: Note: if the base of the material is empty the list will be empty
idx refraction(en='config')
     function to calculate the complex index of refraction of a material in the x-ray range
     Parameter
              enenergy of the x-rays, if omitted the value from the xrayutilities configuration is
                 used
     Returns
          n (complex)
lam
mu
nu
```

```
xrayutilities.materials.material.PseudomorphicMaterial(submat, layermat)
     This function returns a material whos lattice is pseudomorphic on a particular substrate material. This
     function works meanwhile only for cubic materials on (001) substrates
     required input arguments:
              submatsubstrate material
              layermatbulk material of the layer
     return value: An instance of Material holding the new pseudomorphically strained material.
xrayutilities.materials.material.index_map_ij2ijkl(ij)
xrayutilities.materials.material.index_map_ijkl2ij(i, j)
predefined_materials Module
class xrayutilities.materials.predefined materials.SiGe (x)
     Bases: xrayutilities.materials.material.CubicAlloy
     lattice_const_AB (latA, latB, x)
          method to calculate the lattice parameter of the SiGe alloy with composition Si_{1-x}Ge_x
     x
math Package
math Package
fit Module
module with a function wrapper to scipy optimize leastsq for fitting of a 2D function to a peak or a 1D Gauss fit
with the odr package
xrayutilities.math.fit.fit_peak2d(x, y, data, start, drange, fit_function, maxfev=2000)
     fit a two dimensional function to a two dimensional data set e.g. a reciprocal space map
     Parameters
              x,ydata coordinates (do NOT need to be regularly spaced)
              datadata set used for fitting (e.g. intensity at the data coords)
              startset of starting parameters for the fit used as first parameter of function fit function
              drangelimits for the data ranges used in the fitting algorithm e.g. it is clever to use only
                  a small region around the peak which should be fitted: [xmin,xmax,ymin,ymax]
              fit_function function which should be fitted must accept the parameters (x,y,*params)
     Returns
              (fitparam,cov)the set of fitted parameters and covariance matrix
xrayutilities.math.fit.gauss_fit(xdata, ydata, iparams=| |, maxit=200)
                     function
                                 using
                                          odr-pack
                                                      wrapper
                                                                        scipy
                                                                                 similar
                                                                                                 :https:
     //github.com/tiagopereira/python_tips/wiki/Scipy%3A-curve-fitting
     Parameters
              xdataxcoordinates of the data to be fitted
              ydataycoordinates of the data which should be fit
     keyword parameters:
```

iparamsinitial paramters for the fit (determined automatically if nothing is given **maxit**maximal iteration number of the fit

Returns

params,sd_params,itlim

the Gauss parameters as defined in function Gauss1d(x, *param) and their errors of the fit, as well as a boolean flag which is false in the case of a successful fit

 $\verb|xrayutilities.math.fit.multGaussFit| (*args, **kwargs)|$

convenience function to keep API stable see multPeakFit for documentation

xrayutilities.math.fit.multGaussPlot(*args, **kwargs)

convenience function to keep API stable see multPeakPlot for documentation

xrayutilities.math.fit.multPeakFit(x, data, peakpos, peakwidth, dranges=None, peaktype='Gaussian')

function to fit multiple Gaussian/Lorentzian peaks with linear background to a set of data

Parameters

xx-coordinate of the data

datadata array with same length as x

peakposinitial parameters for the peak positions

peakwidthinitial values for the peak width

drangeslist of tuples with (min,max) value of the data ranges to use. does not need to have the same number of entries as peakpos

peaktypetype of peaks to be used: can be either 'Gaussian' or 'Lorentzian'

Returns

pos,sigma,amp,background

Pos list of peak positions derived by the fit

Sigma list of peak width derived by the fit

Amp list of amplitudes of the peaks derived by the fit

Background array of background values at positions x

function to plot multiple Gaussian/Lorentz peaks with background values given by an array

Parameters

xx-coordinate of the data

fposlist of positions of the peaks

fwidthlist of width of the peaks

famplist of amplitudes of the peaks

backgroundarray with background values

drangeslist of tuples with (min,max) value of the data ranges to use. does not need to have the same number of entries as fpos

peaktypetype of peaks to be used: can be either 'Gaussian' or 'Lorentzian'

figmatplotlib figure number or name

fact factor to use as multiplicator in the plot

functions Module

```
module with several common function needed in xray data analysis
xrayutilities.math.functions.Debye1 (x)
     function to calculate the first Debye function as needed for the calculation of the thermal Debye-Waller-
     factor by numerical integration
     for definition see: :http://en.wikipedia.org/wiki/Debye_function
     D1(x) = (1/x) int_0^x t/(exp(t)-1) dt
     Parameters
              xargument of the Debye function (float)
     Returns
              D1(x)float value of the Debye function
xrayutilities.math.functions.Gauss1d(x, *p)
     function to calculate a general one dimensional Gaussian
     Parameters
              plist of parameters of the Gaussian [XCEN,SIGMA,AMP,BACKGROUND] for infor-
                   mation: SIGMA = FWHM / (2*sqrt(2*log(2)))
              xcoordinate(s) where the function should be evaluated
     Returns
     the value of the Gaussian described by the parameters p at position x
xrayutilities.math.functions.Gauss1d_der_p (x, *p)
     function to calculate the derivative of a Gaussian with respect the parameters p
     for parameter description see Gauss1d
xrayutilities.math.functions.Gauss1d_der_x (x, *p)
     function to calculate the derivative of a Gaussian with respect to x
     for parameter description see Gauss1d
xrayutilities.math.functions.Gauss2d (x, y, *p)
     function to calculate a general two dimensional Gaussian
     Parameters
              plist of parameters of the Gauss-function [XCEN, YCEN, SIGMAX, SIGMAY, AMP, BACKGROUND, ANGLE]
                  SIGMA = FWHM / (2*sqrt(2*log(2))) ANGLE = rotation of the X,Y direction of
                  the Gaussian in radians
              x,ycoordinate(s) where the function should be evaluated
     Returns
     the value of the Gaussian described by the parameters p at position (x,y)
xrayutilities.math.functions.Gauss3d (x, y, z, *p)
     function to calculate a general three dimensional Gaussian
     Parameters
               plist of parameters of the Gauss-function [XCEN, YCEN, ZCEN, SIGMAX, SIGMAY, SIGMAZ, AMP, BACKGROUN
                  SIGMA = FWHM / (2*sqrt(2*log(2)))
```

4.2. xrayutilities Package

Returns

x,y,zcoordinate(s) where the function should be evaluated

the value of the Gaussian described by the parameters p at positions (x,y,z)

```
xrayutilities.math.functions.Lorentz1d(x, *p)
     function to calculate a general one dimensional Lorentzian
     Parameters
               plist of parameters of the Lorentz-function [XCEN,FWHM,AMP,BACKGROUND]
               x,ycoordinate(s) where the function should be evaluated
     Returns
     the value of the Lorentian described by the parameters p at position (x,y)
xrayutilities.math.functions.Lorentz1d_der_p (x, *p)
     function to calculate the derivative of a Gaussian with respect the parameters p
     for parameter description see Lorentz1d
xrayutilities.math.functions.Lorentz1d_der_\mathbf{x} (x, *p)
     function to calculate the derivative of a Gaussian with respect to x
     for parameter description see Lorentz1d
xrayutilities.math.functions.Lorentz2d(x, y, *p)
     function to calculate a general two dimensional Lorentzian
     Parameters
               plist of parameters of the Lorentz-function [XCEN,YCEN,FWHMX,FWHMY,AMP,BACKGROUND,ANGLE]
                   ANGLE = rotation of the X,Y direction of the Lorentzian in radians
               x,ycoordinate(s) where the function should be evaluated
     Returns
     the value of the Lorentian described by the parameters p at position (x,y)
xrayutilities.math.functions.PseudoVoigt1d(x, *p)
     function to calculate a pseudo Voigt function as linear combination of a Gauss and Lorentz peak
     Parameters
               plist of parameters of the Lorentz-function [XCEN,FWHM,AMP,BACKGROUND,ETA]
                   :ETA: 0 ... 1 0 means pure Gauss and 1 means pure Lorentz
               x,ycoordinate(s) where the function should be evaluated
     Returns
     the value of the PseudoVoigt described by the parameters p at position (x,y)
xrayutilities.math.functions.TwoGauss2d(x, y, *p)
     function to calculate two general two dimensional Gaussians
     Parameters
               plist of parameters of the Gauss-function [XCEN1, YCEN1, SIGMAX1, SIGMAY1, AMP1, ANGLE1, XCEN2, YCEN
                  SIGMA = FWHM / (2*sqrt(2*log(2))) ANGLE = rotation of the X,Y direction of
                   the Gaussian in radians
               x,ycoordinate(s) where the function should be evaluated
     Return
     the value of the Gaussian described by the parameters p at position (x,y)
xrayutilities.math.functions.kill_spike(data, threshold=2.0)
     function to smooth **single** data points which differ from the average of the neighboring data points by
     more than the threshold factor. Such spikes will be replaced by the mean value of the next neighbors.
       Warning: Use this function carefully not to manipulate your data!
```

Parameters

data1d numpy array with experimental data

threshold factor to identify strange data points

Returns

1d data-array with spikes removed

```
xrayutilities.math.functions.smooth (x, n)
```

function to smooth an array of data by averaging N adjacent data points

Parameters

x1D data array

nnumber of data points to average

Returns

xsmoothsmoothed array with same length as x

transforms Module

```
class xrayutilities.math.transforms.AxisToZ (newzaxis)
```

Bases: xrayutilities.math.transforms.CoordinateTransform

Creates a coordinate transformation to move a certain axis to the z-axis. The rotation is done along the great circle. The x-axis of the new coordinate frame is created to be normal to the new and original z-axis. The new y-axis is create in order to obtain a right handed coordinate system.

```
xrayutilities.math.transforms.Cij2Cijkl(cij)
```

Converts the elastic constants matrix (tensor of rank 2) to the full rank 4 cijkl tensor.

required input arguments:

cij(6,6) cij matrix as a numpy array

return value:

cijkl(3,3,3,3) cijkl tensor as numpy array

```
xrayutilities.math.transforms.Cijkl2Cij(cijkl)
```

Converts the full rank 4 tensor of the elastic constants to the (6,6) matrix of elastic constants.

required input arguments:

cijkl(3,3,3,3) cijkl tensor as numpy array

return value:

cij(6,6) cij matrix as a numpy array

```
class xrayutilities.math.transforms.CoordinateTransform(v1, v2, v3)
```

```
Bases: xrayutilities.math.transforms.Transform
```

Create a Transformation object which transforms a point into a new coordinate frame. The new frame is determined by the three vectors v1/norm(v1), v2/norm(v2) and v3/norm(v3), which need to be orthogonal!

```
class xrayutilities.math.transforms.Transform(matrix)
```

Bases: object

inverse(*args)

performs inverse transformation a vector, matrix or tensor of rank 4

Parameters

*args: object to transform, list or numpy array of shape(n,) (n,n), (n,n,n,n) where n is the rank of the transformation matrix

```
xrayutilities.math.transforms.XRotation(alpha, deg=True)
```

Returns a transform that represents a rotation about the x-axis by an angle alpha. If deg=True the angle is assumed to be in degree, otherwise the function expects radiants.

```
xrayutilities.math.transforms.YRotation(alpha, deg=True)
```

Returns a transform that represents a rotation about the y-axis by an angle alpha. If deg=True the angle is assumed to be in degree, otherwise the function expects radiants.

```
xrayutilities.math.transforms.ZRotation(alpha, deg=True)
```

Returns a transform that represents a rotation about the z-axis by an angle alpha. If deg=True the angle is assumed to be in degree, otherwise the function expects radiants.

```
xrayutilities.math.transforms.index map ij2ijkl(ij)
xrayutilities.math.transforms.index_map_ijkl2ij(i, j)
xrayutilities.math.transforms.mycross(vec, mat)
```

function implements the cross-product of a vector with each column of a matrix

```
xrayutilities.math.transforms.rotarb(vec, axis, ang, deg=True)
```

function implements the rotation around an arbitrary axis by an angle ang positive rotation is anti-clockwise when looking from positive end of axis vector

Parameter

```
vecnumpy.array or list of length 3
axisnumpy.array or list of length 3
angrotation angle in degree (deg=True) or in rad (deg=False)
degboolean which determines the input format of ang (default: True)
```

Returns

rotvecrotated vector as numpy.array

Example

```
>>> rotarb([1,0,0],[0,0,1],90)
array([ 6.12323400e-17, 1.00000000e+00,
                                            0.00000000e+001)
```

```
xrayutilities.math.transforms.tensorprod(vec1, vec2)
```

function implements an elementwise multiplication of two vectors

vector Module

module with vector operations, mostly numpy functionality is used for the vector operation itself, however custom error checking is done to ensure vectors of length 3.

```
xrayutilities.math.vector.VecAngle(v1, v2, deg=False)
    calculate the angle between two vectors.
                                                  The following formula is used v1.v2 =
    norm(v1)*norm(v2)*cos(alpha)
     alpha = acos((v1.v2)/(norm(v1)*norm(v2)))
```

required input arguments:

v1vector as numpy array or list v2vector as numpy array or list

optional keyword arguments:

deg(default: false) return result in degree otherwise in radiants

return value:float value with the angle inclined by the two vectors

```
xrayutilities.math.vector.VecDot(v1, v2)
     Calculate the vector dot product.
     required input arguments:
              v1vector as numpy array or list
              v2vector as numpy array or list
     return value:float value
xrayutilities.math.vector.VecNorm(v)
     Calculate the norm of a vector.
     required input arguments:
              vvector as list or numpy array
     return value: float holding the vector norm
xrayutilities.math.vector.VecUnit(v)
     Calculate the unit vector of v.
     required input arguments:
              vvector as list or numpy array
     return value:numpy array with the unit vector
```

xrayutilities.math.vector.getSyntax(vec)

returns vector direction in the syntax 'x+' 'z-' or equivalents therefore works only for principle vectors of the coordinate system like e.g. [1,0,0] or [0,2,0]

Parameters

string[xyz][+-]

Returns

vector along the given direction as numpy array

 $\verb|xrayutilities.math.vector.getVector| (string)$

returns unit vector along a rotation axis given in the syntax 'x+' 'z-' or equivalents

Parameters

string[xyz][+-]

Returns

vector along the given direction as numpy array

4.3 analysis Package

4.3.1 analysis Package

xrayutilities.analysis is a package for assisting with the analysis of x-ray diffraction data, mainly reciprocal space maps

Routines for obtaining line cuts from gridded reciprocal space maps are offered, with the ability to integrate the intensity perpendicular to the line cut direction.

4.3.2 line_cuts Module

```
xrayutilities.analysis.line_cuts.fwhm_exp(pos, data)
```

function to determine the full width at half maximum value of experimental data. Please check the obtained value visually (noise influences the result)

```
Parameter
               posposition of the data points
               datadata values
     Returns
          fwhm value (single float)
xrayutilities.analysis.line_cuts.get_omega_scan_ang(qx, qz, intensity, omcenter,
                                                                        ttcenter, omrange, npoints,
                                                                        **kwargs)
     extracts an omega scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               omcenteromega-position at which the omega scan should be extracted
               ttcenter2theta-position at which the omega scan should be extracted
               omrangerange of the omega scan to extract
               npointsnumber of points of the omega scan
      **kwargs: possible keyword arguments:
               qrangeintegration range perpendicular to scan direction
               Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative omega positions are returned (default: True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               om,omintomega scan coordinates and intensities (bounds=False)
               om,omint,(qxb,qzb)omega scan coordinates and intensities + reciprocal space bounds
                   of the extraced scan (bounds=True)
     Example
     >>> omcut, intcut = get_omega_scan(qx,qz,intensity,0.0,5.0,2.0,200)
xrayutilities.analysis.line_cuts.get_omega_scan_bounds_ang(omcenter,
                                                                                                 tt-
                                                                                  center,
                                                                                               om-
                                                                                  range,
                                                                                           npoints,
                                                                                  **kwargs)
     return reciprocal space boundaries of omega scan
     Parameters
               omcenteromega-position at which the omega scan should be extracted
               ttcenter2theta-position at which the omega scan should be extracted
               omrangerange of the omega scan to extract
               npoints number of points of the omega scan
      **kwargs: possible keyword arguments:
```

qrangeintegration range perpendicular to scan direction

lamwavelength for use in the conversion to angular coordinates

Returns

qx,qzreciprocal space coordinates of the omega scan boundaries

Example

```
>>> qxb,qzb = get_omega_scan_bounds_ang(1.0,4.0,2.4,240,qrange=0.1)
```

```
xrayutilities.analysis.line_cuts.get_omega_scan_q(qx, qz, intensity, qxcenter, qzcenter, omrange, npoints, **kwargs)
```

extracts an omega scan from a gridded reciprocal space map

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qxcenterqx-position at which the omega scan should be extracted

qzcenterqz-position at which the omega scan should be extracted

omrangerange of the omega scan to extract

npointsnumber of points of the omega scan

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

Nintnumber of subscans used for the integration (optionally)

lamwavelength for use in the conversion to angular coordinates

relativedetermines if absolute or relative omega positions are returned (default: True)

boundsflag to specify if the scan bounds should be returned (default: False)

Returns

om,omintomega scan coordinates and intensities (bounds=False)

om,omint,(**qxb,qzb**)omega scan coordinates and intensities + reciprocal space bounds of the extraced scan (bounds=True)

Example

```
>>> omcut, intcut = get_omega_scan(qx,qz,intensity,0.0,5.0,2.0,200)
```

```
xrayutilities.analysis.line_cuts.get_qx_scan (qx, qz, intensity, qzpos, **kwargs) extract qx line scan at position qzpos from a gridded reciprocal space map by taking the closest line of the intensity matrix, or summing up a given range along qz
```

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qzposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

qmin,qmaxminimum and maximum value of extracted scan axis

boundsflag to specify if the scan bounds of the extracted scan should be returned (default:False)

Returns

qx,qxintqx scan coordinates and intensities (bounds=False)

qx,qxint,(qxb,qyb)qx scan coordinates and intensities + scan bounds for plotting

Example

```
>>> qxcut,qxcut_int = qet_qx_scan(qx,qz,inten,5.0,qrange=0.03)
```

xrayutilities.analysis.line_cuts.**get_qz_scan** (*qx*, *qz*, *intensity*, *qxpos*, **kwargs) extract qz line scan at position qxpos from a gridded reciprocal space map by taking the closest line of the intensity matrix, or summing up a given range along qx

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qxposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

qmin,qmaxminimum and maximum value of extracted scan axis

Returns

qz,qzintqz scan coordinates and intensities

Example

```
>>> qzcut,qzcut_int = get_qz_scan(qx,qz,inten,1.5,qrange=0.03)
```

extracts a qz scan from a gridded reciprocal space map with integration along omega (sample rocking angle) or 2theta direction

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qxposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

angrangeintegration range in angular direction

qmin,qmaxminimum and maximum value of extracted scan axis

boundsflag to specify if the scan bounds of the extracted scan should be returned (default:False)

intdirintegration direction 'omega': sample rocking angle (default) '2theta': scattering angle

Returns

```
qz,qzintqz scan coordinates and intensities (bounds=False)
               qz,qzint,(qzb,qzb)qz scan coordinates and intensities + scan bounds for plotting
     Example
     >>> qzcut,qzcut_int = get_qz_scan_int(qx,qz,inten,5.0,omrange=0.3)
xrayutilities.analysis.line_cuts.get_radial_scan_ang(qx, qz, intensity, omcenter,
                                                                          ttcenter, ttrange, npoints,
                                                                          **kwargs)
     extracts a radial scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               omcenterom-position at which the radial scan should be extracted
               ttcentertt-position at which the radial scan should be extracted
               ttrangetwo theta range of the radial scan to extract
               npoints number of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range perpendicular to scan direction
               Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relative determines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               om,tt,radintomega,two theta scan coordinates and intensities (bounds=False)
               om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space
                   bounds of the extraced scan (bounds=True)
     Example
     >>> omc,ttc,cut_int = get_radial_scan_ang(qx,qz,intensity,32.0,64.0,30.0,800,omrange=0.2)
xrayutilities.analysis.line_cuts.get_radial_scan_bounds_ang(omcenter,
                                                                                    ttcenter.
                                                                                    ttrange, npoints,
                                                                                    **kwargs)
     return reciprocal space boundaries of radial scan
     Parameters
               omcenterom-position at which the radial scan should be extracted
               ttcentertt-position at which the radial scan should be extracted
               ttrangetwo theta range of the radial scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range perpendicular to scan direction
```

```
lamwavelength for use in the conversion to angular coordinates
     Returns
               qxrad,qzradreciprocal space boundaries of radial scan
     Example
      >>>
xrayutilities.analysis.line\_cuts.get\_radial\_scan\_q(qx, qz, intensity, qxcenter,
                                                                       qzcenter, ttrange, npoints,
                                                                        **kwargs)
     extracts a radial scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               qxcenterqx-position at which the radial scan should be extracted
               qzcenterqz-position at which the radial scan should be extracted
               ttrangetwo theta range of the radial scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range perpendicular to scan direction
               Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
      Returns
               om,tt,radintomega,two theta scan coordinates and intensities (bounds=False)
               om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space
                   bounds of the extraced scan (bounds=True)
     Example
      >>> omc,ttc,cut_int = get_radial_scan_q(qx,qz,intensity,0.0,5.0,1.0,100,omrange=0.01)
xrayutilities.analysis.line_cuts.get_ttheta_scan_ang(qx, qz, intensity, omcenter,
                                                                          ttcenter, ttrange, npoints,
                                                                           **kwargs)
     extracts a twotheta scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               omcenterom-position at which the 2theta scan should be extracted
               ttcentertt-position at which the 2theta scan should be extracted
               ttrangetwo theta range of the scan to extract
```

npoints number of points of the radial scan

```
**kwargs: possible keyword arguments:
```

omrangeintegration range in omega direction

Nintnumber of subscans used for the integration (optionally)

lamwavelength for use in the conversion to angular coordinates

relativedetermines if absolute or relative two theta positions are returned (default=True)

boundsflag to specify if the scan bounds should be returned (default: False)

Returns

tt,ttinttwo theta scan coordinates and intensities (bounds=False)

tt,ttint,(qxb,qzb)2theta scan coordinates and intensities + reciprocal space bounds of the extraced scan (bounds=True)

Example

```
>>> ttc,cut_int = get_ttheta_scan_ang(qx,qz,intensity,32.0,64.0,4.0,400)
```

return reciprocal space boundaries of 2theta scan

Parameters

omcenterom-position at which the 2theta scan should be extracted

ttcentertt-position at which the 2theta scan should be extracted

ttrangetwo theta range of the 2theta scan to extract

npointsnumber of points of the 2theta scan

**kwargs: possible keyword arguments:

omrangeintegration range in omega direction

lamwavelength for use in the conversion to angular coordinates

Returns

qxtt,qzttreciprocal space boundaries of 2theta scan (bounds=False)

tt,ttint,(qxb,qzb)2theta scan coordinates and intensities + reciprocal space bounds of the extraced scan (bounds=True)

Example

>>>

extracts a twotheta scan from a gridded reciprocal space map

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

```
qxcenterqx-position at which the 2theta scan should be extracted
qzcenterqz-position at which the 2theta scan should be extracted
ttrangetwo theta range of the scan to extract
npointsnumber of points of the radial scan
```

**kwargs: possible keyword arguments:

omrangeintegration range in omega direction

Nintnumber of subscans used for the integration (optionally)

lamwavelength for use in the conversion to angular coordinates

relativedetermines if absolute or relative two theta positions are returned (default=True)

bounds flag to specify if the scan bounds should be returned (default: False)

Returns

tt,ttinttwo theta scan coordinates and intensities (bounds=False)

om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space bounds of the extraced scan (bounds=True)

Example

```
>>> ttc,cut_int = get_ttheta_scan_q(qx,qz,intensity,0.0,4.0,4.4,440)
```

```
xrayutilities.analysis.line_cuts.getindex(x, y, xgrid, ygrid)
```

gives the indices of the point x,y in the grid given by xgrid ygrid xgrid,ygrid must be arrays containing equidistant points

Parameters

x,ycoordinates of the point of interest (float)

xgrid, **ygrid** grid coordinates in x and y direction (array)

Returns

ix,iyindex of the closest gridpoint (lower left) of the point (x,y)

4.3.3 line cuts3d Module

extract qx line scan at position y,z from a gridded reciprocal space map by taking the closest line of the intensity matrix, or summing up a given area around this position

Parameters

gridder3d xrayutilities.Gridder3D object containing the data

qypos,qzposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

qmin,qmaxminimum and maximum value of extracted scan axis

Returns

qx,qxintqx scan coordinates and intensities

Example

```
>>> qxcut,qxcut_int = get_qx_scan3d(gridder,0,0,qrange=0.03)
xrayutilities.analysis.line cuts3d.qet qy scan3d(gridder,
                                                                                axpos,
                                                                                            qzpos,
                                                                   **kwargs)
     extract qy line scan at position x,z from a gridded reciprocal space map by taking the closest line of the
     intensity matrix, or summing up a given area around this position
     Parameters
               gridder3d xrayutilities.Gridder3D object containing the data
               qxpos,qzposposition at which the line scan should be extracted
     **kwargs: possible keyword arguments:
               qrangeintegration range perpendicular to scan direction
               qmin,qmaxminimum and maximum value of extracted scan axis
     Returns
               qy,qyintqy scan coordinates and intensities
     Example
     >>> qycut,qycut_int = get_qy_scan3d(gridder,0,0,qrange=0.03)
xrayutilities.analysis.line_cuts3d.get_qz_scan3d(gridder,
                                                                                qxpos,
                                                                                            qypos,
                                                                   **kwargs)
     extract qz line scan at position x,y from a gridded reciprocal space map by taking the closest line of the
     intensity matrix, or summing up a given area around this position
     Parameters
               gridder3d xrayutilities.Gridder3D object containing the data
               qxpos,qyposposition at which the line scan should be extracted
      **kwargs: possible keyword arguments:
               qrangeintegration range perpendicular to scan direction
               qmin,qmaxminimum and maximum value of extracted scan axis
     Returns
               qz,qzintqz scan coordinates and intensities
     Example
     >>> qzcut,qzcut_int = get_qz_scan3d(gridder,0,0,qrange=0.03)
xrayutilities.analysis.line cuts3d.qetindex3d(x, y, z, xgrid, ygrid, zgrid)
     gives the indices of the point x,y,z in the grid given by xgrid ygrid zgrid xgrid,ygrid,zgrid must be arrays
     containing equidistant points
     Parameters
               x,y,zcoordinates of the point of interest (float)
               xgrid,ygrid,zgridgrid coordinates in x,y,z direction (array)
     Returns
               ix,iy,izindex of the closest gridpoint (lower left) of the point (x,y,z)
```

4.3.4 misc Module

```
miscellaneous functions helpful in the analysis and experiment

xrayutilities.analysis.misc.getangles (peak, sur, inp)
calculates the chi and phi angles for a given peak

Parameter

peakarray which gives hkl for the peak of interest
surhkl of the surface
inpinplane reference peak or direction

Returns

[chi,phi] for the given peak on surface sur with inplane direction inp as reference

Example

To get the angles for the -224 peak on a 111 surface type[chi,phi] = getangles([-2,2,4],[1,1,1],[2,2,4])
```

4.3.5 sample_align Module

functions to help with experimental alignment during experiments, especially for experiments with linear detectors

```
xrayutilities.analysis.sample_align.area_detector_calib (angle1, angle2, ccdimages, detaxis, r_i, plot=True, cut_off=0.7, start=(0, 0, 0, 0), fix=(False, False, False, False, False), fig=None, wl=None)
```

function to calibrate the detector parameters of an area detector it determines the detector tilt possible rotations and offsets in the detector arm angles

parameters

```
angle1outer detector arm angle
angle2inner detector arm angle
ccdimagesimages of the ccd taken at the angles given above
detaxisdetector arm rotation axis :default: ['z+','y-']
r_iprimary beam direction [xyz][+-] default 'x+'
```

Keyword_arguments

```
plotflag to determine if results and intermediate results should be plotted :default: True
```

cut_offcut off intensity to decide if image is used for the determination or not :default: 0.7 = 70%

startsequence of start values of the fit for parameters, which can not be estimated automatically these are: tiltazimuth,tilt,detector_rotation,outerangle_offset. By default (0,0,0,0) is used.

fixfix parameters of start (default: (False,False,False,False))

figmatplotlib figure used for plotting the error :default: None (creates own figure)

wlwavelength of the experiment in Angstrom (default: config.WAVELENGTH) value does not matter here and does only affect the scaling of the error

```
xrayutilities.analysis.sample_align.area_detector_calib_hkl (sampleang,
                                                                                angle1, angle2,
                                                                                ccdimages, hkls,
                                                                                experiment, ma-
                                                                                terial, detaxis,
                                                                                r_i, plot=True,
                                                                                cut\_off=0.1,
                                                                                start=(0, 0, 0,
                                                                                0, 0, 0,  'con-
                                                                               fig'), fix=(False,
                                                                                False,
                                                                                         False,
                                                                                False,
                                                                                         False,
                                                                                False,
                                                                                         False),
                                                                                fig=None)
```

function to calibrate the detector parameters of an area detector it determines the detector tilt possible rotations and offsets in the detector arm angles

in this variant not only scans through the primary beam but also scans at a set of symmetric reflections can be used for the detector parameter determination. for this not only the detector parameters but in addition the sample orientation and wavelength need to be fit.

parameters

sampleangsample rocking angle (needed to align the reflections (same rotation direction as inner detector rotation)) other sample angle are not allowed to be changed during the scans

angle1outer detector arm angle

angle2inner detector arm angle

ccdimagesimages of the ccd taken at the angles given above

hklsarray/list of hkl values for every image

material material used as reference crystal

detaxisdetector arm rotation axis :default: ['z+','y-']

r_iprimary beam direction [xyz][+-] default 'x+'

Keyword_arguments

plotflag to determine if results and intermediate results should be plotted :default: True

cut_offcut off intensity to decide if image is used for the determination or not :default: 0.7 = 70%

startsequence of start values of the fit for parameters, which can not be estimated automatically these are: tiltazimuth,tilt,detector_rotation,outerangle_offset, stilt,stazimuth, wavelength. By default (0,0,0,0,0,0,config') is used.

fixfix parameters of start (default: (False,Fals

figmatplotlib figure used for plotting the error :default: None (creates own figure)

```
xrayutilities.analysis.sample_align.fit_bragg_peak (om, tt, psd, omalign, ttalign, exphxrd, frange=(0.03,\ 0.03), plot=True)
```

helper function to determine the Bragg peak position in a reciprocal space map used to obtain the position needed for correction of the data. the determination is done by fitting a two dimensional Gaussian (xrayutilities.math.Gauss2d)

PLEASE ALWAYS CHECK THE RESULT CAREFULLY!

Parameter

om,ttangular coordinates of the measurement (numpy.ndarray) either with size of psd or of psd.shape[0]

psdintensity values needed for fitting

omalignaligned omega value, used as first guess in the fit

ttalignaligned two theta values used as first guess in the fit these values are also used to set the range for the fit: the peak should be within +/-frangeAA^{-1} of those values

exphxrdexperiment class used for the conversion between angular and reciprocal space.

frangedata range used for the fit in both directions (see above for details default: (0.03,0.03) unit: AA^{-1})

plotif True (default) function will plot the result of the fit in comparison with the measurement.

Returns

Omfit,ttfit,params,covariance fitted angular values, and the fit parameters (of the Gaussian) as well as their errors

```
xrayutilities.analysis.sample_align.linear_detector_calib(angle,
```

mca_spectra,
**keyargs)

function to calibrate the detector distance/channel per degrees for a straight linear detector mounted on a detector arm

parameters

anglearray of angles in degree of measured detector spectra **mca_spectra**corresponding detector spectra :(shape: (len(angle),Nchannels)

**keyargs passed to psd_chdeg function used for the modelling, additional options are:

r_iprimary beam direction as vector [xyz][+-]; default: 'y+'

detaxisdetector arm rotation axis [xyz][+-] e.g. 'x+'; default: 'x+'

selected options from psd_chdeg:

plotflag to specify if a visualization of the fit should be done

usetiltwhether to use model considering a detector tilt (deviation angle of the pixel direction from orthogonal to the primary beam) (default: True)

Note: Note: see help of psd_chdeg for more options

returns

pixelwidth (at one meter distance) , center_channel[, detector_tilt]

Note: Note: L/pixelwidth*pi/180 ~= channel/degree, with the sample detector distance L

pixelwidth is negative in case the hit channel number decreases upon an increase of the detector angle The function also prints out how a linear detector can be initialized using the results obtained from this calibration. Carefully check the results

function to calculate the miscut direction and miscut angle of a sample by fitting a sinusoidal function to the variation of the aligned omega values of more than two reflections. The function can also be used to fit reflectivity alignment values in various azimuths.

Parameters

phiazimuths in which the reflection was aligned (deg)

aomegaaligned omega values (deg)

zeros(optional) angles at which surface is parallel to the beam (deg). For the analysis the angles (aomega-zeros) are used.

omega0if specified the nominal value of the reflection is not included as fit parameter, but is fixed to the specified value. This value is MANDATORY if ONLY TWO AZIMUTHs are given.

plotflag to specify if a visualization of the fit is wanted. :default: True

Returns

[omega0,phi0,miscut]

list with fitted values for

omega0the omega value of the reflection should be close to the nominal one
 phi0the azimuth in which the primary beam looks upstairs
 miscutamplitude of the sinusoidal variation == miscut angle

function to determine the channels per degree using a linear fit of the function nchannel = center_ch+chdeg*tan(angles) or the equivalent including a detector tilt

Parameters

angles detector angles for which the position of the beam was measured

channels detector channels where the beam was found

keyword arguments:

stdevstandard deviation of the beam position

plotflag to specify if a visualization of the fit should be done

usetiltwhether to use model considering a detector tilt (deviation angle of the pixel direction from orthogonal to the primary beam) (default: True)

datapplot format of data points

modellineplot format of modelline

modeltiltplot format of modeltilt

fignumfigure number to use for the plot

mlabellabel of the model w/o tilt to be used in the plot

mtiltlabellabel of the model with tilt to be used in the plot

dlabellabel of the data line to be used in the plot

figtitleboolean to tell if the figure title should show the fit parameters

Returns

(pixelwidth,centerch,tilt)

Pixelwidth the width of one detector channel @ 1m distance, which is negative in case the hit channel number decreases upon an increase of the detector angle.

Centerch center channel of the detector

Tilt tilt of the detector from perpendicular to the beam (will be zero in case of usetilt=False)

Note: Note: L/pixelwidth*pi/180 = channel/degree for large detector distance with the sample detector disctance L

```
xrayutilities.analysis.sample_align.psd_refl_align(primarybeam, angles, chan-
nels, plot=True)
```

function which calculates the angle at which the sample is parallel to the beam from various angles and detector channels from the reflected beam. The function can be used during the half beam alignment with a linear detector.

Parameters

primary beam channel number

angles list or numpy.array with angles

channelslist or numpy.array with corresponding detector channels

plotflag to specify if a visualization of the fit is wanted :default: True

Returns

omegaangle at which the sample is parallel to the beam

Example

```
>>> psd_refl_align(500,[0,0.1,0.2,0.3],[550,600,640,700])
```

4.4 io Package

4.4.1 io Package

4.4.2 edf Module

Parses a directory for EDF files, which can be stored to a HDF5 file for further usage

```
Save2HDF5 (h5, group='', comp=True)
```

Saves the data stored in the EDF files in the specified directory in a HDF5 file as a HDF5 arrays in a subgroup. By default the data is stored in a group given by the foldername - this can be changed by passing the name of a target group or a path to the target group via the "group" keyword argument.

required arguments. :h5: a HDF5 file object

optional keyword arguments: :group: group where to store the data (defaults to pathname if group is empty string) :comp: activate compression - true by default

ReadData()

Read the CCD data into the .data object this function is called by the initialization

```
Save2HDF5 (h5, group='/', comp=True)
```

Saves the data stored in the EDF file in a HDF5 file as a HDF5 array. By default the data is stored in the root group of the HDF5 file - this can be changed by passing the name of a target group or a path to the target group via the "group" keyword argument.

required arguments. :h5: a HDF5 file object

optional keyword arguments: :group: group where to store the data (default to the root of the file) :comp: activate compression - true by default

4.4.3 imagereader Module

Bases: object

parse CCD frames in the form of tiffs or binary data (*.bin) to numpy arrays. ignore the header since it seems to contain no useful data

The routine was tested so far with Roper Scientific files with 4096x4096 pixels created at Hasylab Hamburg, which save an 16bit integer per point. Perkin Elmer images created at Hasylab Hamburg with 2048x2048 pixels.

readImage (filename)

read image file and correct for dark- and flatfield in case the necessary data are available.

returned data = ((image data)-(darkfield))/flatfield*average(flatfield)

Parameter

filenamefilename of the image to be read. so far only single filenames are supported. The data might be compressed. supported extensions: .tiff, .bin and .bin.xz

```
class xrayutilities.io.imagereader.PerkinElmer(**keyargs)
     Bases: xrayutilities.io.imagereader.ImageReader
```

parse PerkinElmer CCD frames (*.bin) to numpy arrays Ignore the header since it seems to contain no useful data

The routine was tested only for files with 2048x2048 pixel images created at Hasylab Hamburg which save an 32bit float per point.

```
class xrayutilities.io.imagereader.RoperCCD(**keyargs)
    Bases: xrayutilities.io.imagereader.ImageReader
```

parse RoperScientific CCD frames (*.bin) to numpy arrays Ignore the header since it seems to contain no useful data

The routine was tested only for files with 4096x4096 pixel images created at Hasylab Hamburg which save an 16bit integer per point.

4.4.4 panalytical_xml Module

Panalytical XML (www.XRDML.com) data file parser

based on the native python xml.dom.minidom module. want to keep the number of dependancies as small as possible

4.4. io Package 89

```
class to handle XRDML data files. The class is supplied with a file name and uses the XRDMLScan class
     to parse the xrdMeasurement in the file
class xrayutilities.io.panalytical_xml.XRDMLMeasurement (measurement)
     Bases: object
     class to handle scans in a XRDML datafile
xrayutilities.io.panalytical_xml.getOmPixcel(omraw, ttraw)
     function to reshape the Omega values into a form needed for further treatment with xrayutilities
xrayutilities.io.panalytical_xml.getxrdml_map(filetemplate, scannrs=None, path='.',
                                                             roi=None)
     parses multiple XRDML file and concatenates the results for parsing the xrayutilities.io.XRDMLFile class
     is used. The function can be used for parsing maps measured with the PIXCel and point detector.
     Parameter
              filetemplate string for the file names, can contain a %d which is replaced by
                  the scan number or be a list of filenames
              scannrsint or list of scan numbers
              pathcommon path to the filenames
              roiregion of interest for the PIXCel detector, for other measurements this i not usefull!
     Returns
              om,tt,psdas flattened numpy arrays
     Example
     >>> om,tt,psd = xrayutilities.io.getxrdml_map("samplename_%d.xrdml",[1,2],path="./data")
4.4.5 radicon Module
python module for converting radicon data to HDF5
xrayutilities.io.radicon.hst2hdf5 (h5, hstfile, nofchannels, h5path='/', hstpath='.')
     Converts a HST file to an HDF5 file.
     Required input arguments:
```

h5HDF5 object where to store the data

hstfilename of the HST file

nofchannelsnumber of channels

optional input arguments:

h5pathPath in the HDF5 file where to store the data

hstpathpath where the HST file is located (default is the current working directory)

```
xrayutilities.io.radicon.rad2hdf5(h5, rdcfile, h5path='/', rdcpath='.')
     Converts a RDC file to an HDF5 file.
```

Required input arguments:

h5HDF5 object where to store the data

rdcfilename of the RDC file

optional input arguments:

h5pathPath in the HDF5 file where to store the data (default to root)

rdcpathpath where the RDC file is located (default is the current working directory)

```
xrayutilities.io.radicon.selecthst(et_limit, mca_info, mca_array)
```

Select historgrams form the complete set of recorded MCA data and stores it into a new numpy array. The selection is done due to a exposure time limit. Spectra below this limit are ignored.

required input arguments:

```
et_limitexposure time limitmca_infopytables table with the exposure datamca_arrayarray with all the MCA spectra
```

return value: a numpy array with the selected mca spectra of shape (hstnr,channels).

4.4.6 rotanode_alignment Module

parser for the alignment log file of the rotating anode

class to parse the data file created by the alignment routine (tpalign) at the rotating anode spec installation

this routine does an iterative alignment procedure and saves the center of mass values were it moves after each scan. It iterates between two different peaks and iteratively aligns at each peak between two different motors (om/chi at symmetric peaks, om/phi at asymmetric peaks)

```
Parse()
```

parser to read the alignment log and obtain the aligned values at every iteration.

```
get (key)
```

keys () returns a list of keys for which aligned values were parsed

plot (pname)

function to plot the alignment history for a given peak

Parameters

pnamepeakname for which the alignment should be plotted

4.4.7 seifert Module

a set of routines to convert Seifert ASCII files to HDF5 in fact there exist two posibilities how the data is stored (depending on the use detector):

- 1. as a simple line scan (using the point detector)
- 2. as a map using the PSD

In the first case the data ist stored

```
class xrayutilities.io.seifert.SeifertHeader
    Bases: object
    save_h5_attribs (obj)

class xrayutilities.io.seifert.SeifertMultiScan (filename, m_scan, m2, path=None)
    Bases: object
    dump2hdf5 (h5, iname='INT', group='/')
```

Saves the content of a multi-scan file to a HDF5 file. By default the data is stored in the root group of the file. To save data somewhere else the keyword argument "group" must be used.

required arguments:

h5a HDF5 file object

4.4. io Package 91

```
optional keyword arguments:
```

inamename for the intensity matrix

grouppath to the HDF5 group where to store the data

```
dump2mlab (fname, *args)
```

Store the data in a matlab file.

parse()

 ${\bf class} \; {\tt xrayutilities.io.seifert.SeifertScan} \; ({\it filename, path=None})$

Bases: object

dump2h5 (*h5*, **args*, ***keyargs*)

Save the data stored in the Seifert ASCII file to a HDF5 file.

required input arguments:

h5HDF5 file object

optional arguments:

names to use to store the motors. The first must be the name for the intensity array. The number of names must be equal to the second element of the shape of the data object.

optional keyword arguments:

groupHDF5 group object where to store the data.

dump2mlab (fname, *args)

Save the data from a Seifert scan to a matlab file.

required input arugments:

fnamename of the matlab file

optional position arguments:

names to use to store the motors. The first must be the name for the intensity array. The number of names must be equal to the second element of the shape of the data object.

parse()

```
xrayutilities.io.seifert.getSeifert_map (filetemplate, scannrs=None, path='.', scant-
ype='map', Nchannels=1280)
```

parses multiple Seifert *.nja files and concatenates the results. for parsing the xrayutilities.io.SeifertMultiScan class is used. The function can be used for parsing maps measured with the Meteor1D and point detector.

Parameter

filetemplatetemplate string for the file names, can contain a %d which is replaced by the scan number or be a list of filenames

scannrsint or list of scan numbers

pathcommon path to the filenames

scantypetype of datafile: "map": reciprocal space map measured with a regular Seifert job "tsk": MCA spectra measured using the TaskInterpreter

Nchannelsnumber of channels of the MCA (needed for "tsk" measurements)

Returns

om,tt,psdas flattened numpy arrays

Example

```
>>> om,tt,psd = xrayutilities.io.getSeifert_map("samplename_%d.xrdml",[1,2],path="./data")
```

```
xrayutilities.io.seifert.repair_key(key)
```

Repair a key string in the sense that the string is changed in a way that it can be used as a valid Python identifier. For that purpose all blanks within the string will be replaced by _ and leading numbers get an preceeding _.

4.4.8 spec Module

a threaded class for observing a SPEC data file

Motivation

SPEC files can become quite large. Therefore, subsequently reading the entire file to extract a single scan is a quite cumbersome procedure. This module is a proof of concept code to write a file observer starting a reread of the file starting from a stored offset (last known scan position)

```
class xrayutilities.io.spec.SPECCmdLine (n, prompt, cmdl, out)
    Bases: object
    Save2HDF5 (h5, **keyargs)
class xrayutilities.io.spec.SPECFile (filename, path='')
    Bases: object
```

This class represents a single SPEC file. The class provides methodes for updateing an already opened file which makes it particular interesting for interactive use.

```
Parse()
```

Parses the file from the starting at last_offset and adding found scans to the scan list.

```
Save2HDF5 (h5f, comp=True)
```

Save the entire file in an HDF5 file. For that purpose a group is set up in the root group of the file with the name of the file without extension and leading path. If the method is called after an previous update only the scans not written to the file meanwhile are saved.

required arguments:

h5fa HDF5 file object or its filename

optional keyword arguments:

compactivate compression - true by default

```
Update()
```

reread the file and add newly added files. The parsing starts at the data offset of the last scan gathered during the last parsing run.

```
class xrayutilities.io.spec.SPECLog (filename, prompt, path='')
    Bases: object
    Parse()
    Update()
class xrayutilities.io.spec.SPECMCA (nchan, roistart, roistop)
    Bases: object
```

SPECMCA - represents an MCA object in a SPEC file. This class is an abstract class not itended for being used directly. Instead use one of the derived classes SPECMCAFile or SPECMCAInline.

```
class xrayutilities.io.spec.SPECMCAFile
    Bases: xrayutilities.io.spec.SPECMCA
    ReadData()

class xrayutilities.io.spec.SPECMCAInline
    Bases: xrayutilities.io.spec.SPECMCA
    ReadData()
```

4.4. io Package 93

Bases: object

Represents a single SPEC scan.

ClearData()

Delete the data stored in a scan after it is no longer used.

ReadData()

Set the data attribute of the scan class.

```
Save2HDF5 (h5f, group='/', title='', desc='', optattrs={}, comp=True)
```

Save a SPEC scan to an HDF5 file. The method creates a group with the name of the scan and stores the data there as a table object with name "data". By default the scan group is created under the root group of the HDF5 file. The title of the scan group is ususally the scan command. Metadata of the scan are stored as attributes to the scan group. Additional custom attributes to the scan group can be passed as a dictionary via the optattrs keyword argument.

input arguments:

h5fa HDF5 file object or its filename

optional keyword arguments:

groupname or group object of the HDF5 group where to store the data

title a string with the title for the data, defaults to the name of scan if empty

desca string with the description of the data, defaults to the scan command if empty

optattrsa dictionary with optional attributes to store for the data

compactivate compression - true by default

SetMCAParams (mca_column_format, mca_channels, mca_start, mca_stop)

Set the parameters used to save the MCA data to the file. This method calculates the number of lines used to store the MCA data from the number of columns and the

required input aguments:

mca column formatnumber of columns used to save the data

mca_channelsnumber of MCA channels stored

mca startfirst channel that is stored

mca_stoplast channel that is stored

plot (*args, **keyargs)

Plot scan data to a matplotlib figure. If newfig=True a new figure instance will be created. If logy=True (default is False) the y-axis will be plotted with a logarithmic scale.

Parameters

*args: arguments for the plot: first argument is the name of x-value columnthe following pairs of arguments are the y-value names and plot styles allowed are 3,5,7,... number of arguments

**keyargs:

newfigif True a new figure instance will be created otherwise an existing one will be used

logyif True a semilogy plot will be done

```
xrayutilities.io.spec.geth5_scan (h5f, scans, *args, **kwargs)
```

function to obtain the angular cooridinates as well as intensity values saved in an HDF5 file, which was created from a spec file by the Save2HDF5 method. Especially usefull for reciprocal space map measurements.

further more it is possible to obtain even more positions from the data file if more than two string arguments with its names are given

Parameters

h5ffile object of a HDF5 file opened using pytables or its filename

scansnumber of the scans of the reciprocal space map (int,tuple or list)

*args: names of the motors (optional) (strings) to read reciprocal space maps measured in coplanar diffraction give: :omname: e.g. name of the omega motor (or its equivalent) :ttname: e.g. name of the two theta motor (or its equivalent)

**kwargs (optional):

samplenamestring with the hdf5-group containing the scan data if ommitted the first child node of h5f.root will be used

Returns

MAP

or

[ang1,ang2,...],MAP:angular positions of the center channel of the position sensitive detector (numpy.ndarray 1D) together with all the data values as stored in the data file (includes the intensities e.g. MAP['MCA']).

Example

```
>>> [om,tt], MAP = xu.io.geth5_scan(h5file,36,'omega','gamma')
```

4.4.9 spectra Module

module to handle spectra data

Bases: object

Represents a SPECTRA data file. The file is read during the Constructor call. This class should work for data stored at beamlines P08 and BW2 at HASYLAB.

Required constructor arguments:

filenamea string with the name of the SPECTRA file

Optional keyword arguments:

```
mcatmptemplate for the MCA files
```

mcastart,mcastopstart and stop index for the MCA files, if not given, the class tries to determine the start and stop index automatically.

Read()

Read the data from the file.

ReadMCA()

```
Save2HDF5 (h5file, name, group='/', description='SPECTRA scan', mcaname='MCA')
```

Saves the scan to an HDF5 file. The scan is saved to a seperate group of name "name". h5file is either a string for the file name or a HDF5 file object. If the mca attribute is not None mca data will be stored to an chunked array of with name mcaname.

required input arguments:

h5filestring or HDF5 file object

namename of the group where to store the data

4.4. io Package 95

optional keyword arguments:

grouproot group where to store the data

description string with a description of the scan

Return value: The method returns None in the case of everything went fine, True otherwise.

class xrayutilities.io.spectra.SPECTRAFileComments

Bases: dict

Class that describes the comments in the header of a SPECTRA file. The different comments are accessible via the comment keys.

class xrayutilities.io.spectra.SPECTRAFileData

Bases: object append (col)

class xrayutilities.io.spectra.SPECTRAFileDataColumn (index, name, unit, type)

Bases: object

class xrayutilities.io.spectra.SPECTRAFileParameters

Bases: dict

class xrayutilities.io.spectra.Spectra(data_dir)

Bases: object

abs corr (*data*, *f*, ***keyargs*)

Perform absorber correction. Data can be either a 1 dimensional data (point detector) or a 2D MCA array. In the case of an array the data array should be of shape (N,NChannels) where N is the number of points in the scan an NChannels the number of channels of the MCA. The absorber values are passed to the function as a 1D array of N elements.

By default the absorber values are taken form a global variable stored in the module called _absorver_factors. Despite this, costume values can be passed via optional keyword arguments.

required input arguments:

mcamatrix with the MCA data

ffilter values along the scan

optional keyword arguments:

ffcustome filter factors

return value: Array with the same shape as mca with the corrected MCA data.

```
recarray2hdf5 (h5g, rec, name, desc)
```

Save a record array in an HDF5 file. A pytables table object is used to store the data.

required input arguments:

h5gHDF5 group object or path

recrecord array

namename of the table in the file

descdescription of the table in the file

return value:

taba HDF5 table object

set_abs_factors(ff)

Set the global absorber factors in the module.

spectra2hdf5 (dir, fname, mcatemp, name='', desc='SPECTRA data')

Convert SPECTRA scan data to a HDF5 format.

required input arguments:

dirdirectory where the scan is stored

fnamename of the SPECTRA data file

mcatemptemplate for the MCA file names

optional keyword arguments:

nameoptional name under which to save the data if empty the basename of the filename will be used

descoptional description of the scan

```
xrayutilities.io.spectra.get_spectra_files(dirname)
```

Return a list of spectra files within a directory.

required input arguments:

dirnamename of the directory to search

return values: list with filenames

```
xrayutilities.io.spectra.geth5_spectra_map(h5file, scans, *args, **kwargs)
```

function to obtain the omega and twotheta as well as intensity values for a reciprocal space map saved in an HDF5 file, which was created from a spectra file by the Save2HDF5 method.

further more it is possible to obtain even more positions from the data file if more than two string arguments with its names are given

Parameters

h5ffile object of a HDF5 file opened using pytables

scansnumber of the scans of the reciprocal space map (int,tuple or list)

*args: arbitrary number of motor names (strings)

omnamename of the omega motor (or its equivalent)

ttnamename of the two theta motor (or its equivalent)

**kwargs (optional):

mcaname of the mca data (if available) otherwise None (default: "MCA")

samplenamestring with the hdf5-group containing the scan data if ommitted the first child node of h5f.root will be used to determine the sample name

Returns

[ang1,ang2,...],MAP:angular positions of the center channel of the position sensitive detector (numpy.ndarray 1D) together with all the data values as stored in the data file (includes the intensities e.g. MAP['MCA']).

```
xrayutilities.io.spectra.read_data(fname)
```

Read a spectra data file (a file with now MCA data).

required input arguments:

fnamename of the file to read

return values: (data,hdr)

datanumpy record array where the keys are the column names

hdra dictionary with header information

xrayutilities.io.spectra.read_mca(fname)

Read a single SPECTRA MCA file.

required input arguments:

fnamename of the file to read

4.4. io Package 97

return value:

data a numpy array with the MCA data

```
xrayutilities.io.spectra.read_mca_dir (dirname, filetemp, sort=True)
   Read all MCA files within a directory
```

xrayutilities.io.spectra.read_mcas (ftemp, cntstart, cntstop)

Read MCA data from a SPECTRA MCA directory. The filename is passed as a generic

4.5 materials Package

4.5.1 materials Package

4.5.2 _create_database Module

script to create the HDF5 database from the raw data of XOP this file is only needed for administration

4.5.3 _create_database_alt Module

script to create the HDF5 database from the raw data of XOP this file is only needed for administration

4.5.4 cif Module

```
class xrayutilities.materials.cif.CIFFile (filename)
    Bases: object
```

class for parsing CIF (Crystallographic Information File) files. The class aims to provide an additional way of creating material classes instead of manual entering of the information the lattice constants and unit cell structure are parsed from the CIF file

Lattice()

returns a lattice object with the structure from the CIF file

Parse()

function to parse a CIF file. The function reads the space group symmetry operations and the basic atom positions as well as the lattice constants and unit cell angles

SymStruct()

function to obtain the list of different atom positions in the unit cell for the different types of atoms. The data are obtained from the data parsed from the CIF file.

4.5.5 database Module

module to handle access to the optical parameters database

Close()

Close an opend database file.

Create (dbname, dbdesc)

Creates a new database. If the database file already exists its content is delete.

required input arguments:

dbnamename of the database

dbdesca short description of the database

CreateMaterial (name, description)

This method creates a new material. If the material group already exists the procedure is aborted.

required input arguments:

namea string with the name of the material

description a string with a description of the material

GetF0(q)

Obtain the f0 scattering factor component for a particular momentum transfer q.

required input argument:

qsingle float value or numpy array

GetF1 (en)

Return the second, energy dependent, real part of the scattering factor for a certain energy en.

required input arguments:

enfloat or numpy array with the energy

GetF2 (en)

Return the imaginary part of the scattering factor for a certain energy en.

required input arguments:

enfloat or numpy array with the energy

Open (mode='r')

Open an existing database file.

SetF0 (parameters)

Save f0 fit parameters for the set material. The fit parameters are stored in the following order: c,a1,b1,.....,a4,b4

required input argument:

parameters list or numpy array with the fit parameters

SetF1 (*en*, *f1*)

Set f1 tabels values for the active material.

required input arguments:

enlist or numpy array with energy in (eV)

f1list or numpy array with f1 values

$\mathbf{SetF2}\;(\mathit{en},\mathit{f2})$

Set f2 tabels values for the active material.

required input arguments:

enlist or numpy array with energy in (eV)

f2list or numpy array with f2 values

SetMaterial (name)

Set a particular material in the database as the actual material. All operations like setting and getting optical constants are done for this particular material.

requiered input arguments:

namestring with the name of the material

SetWeight (weight)

Save weight of the element as float

required input argument:

weight atomic standard weight of the element (float)

```
xrayutilities.materials.database.add_f0_from_intertab(db, itabfile)
     Read f0 data from international tables of crystallography and add it to the database.
xrayutilities.materials.database.add_f0_from_xop(db, xopfile)
     Read f0 data from f0 xop.dat and add it to the database.
xrayutilities.materials.database.add_f1f2_from_ascii_file(db, asciifile, ele-
     Read f1 and f2 data for specific element from ASCII file (3 columns) and save it to the database.
xrayutilities.materials.database.add_f1f2_from_henkedb(db, henkefile)
     Read f1 and f2 data from Henke database and add it to the database.
xrayutilities.materials.database.add_f1f2_from_kissel(db, kisselfile)
     Read f1 and f2 data from Henke database and add it to the database.
xrayutilities.materials.database.add_mass_from_NIST(db, nistfile)
     Read atoms standard mass and save it to the database.
xrayutilities.materials.database.init_material_db (db)
4.5.6 elements Module
4.5.7 lattice Module
module handling crystal lattice structures
class xrayutilities.materials.lattice.Atom(name, num)
     Bases: object
     f (q, en='config')
         function to calculate the atomic structure factor F
         Parameter
                 qmomentum transfer
                 enenergy for which F should be calculated, if omitted the value from the xrayutilities
                   configuration is used
         Returns
             f (float)
     f0(q)
     f1 (en='config')
     f2 (en='config')
xrayutilities.materials.lattice.BCCLattice(aa, a)
xrayutilities.materials.lattice.BCTLattice (aa, a, c)
xrayutilities.materials.lattice.BaddeleyiteLattice(aa, ab, a, b, c, beta,
                                                                deg=True)
xrayutilities.materials.lattice.CuMnAsLattice (aa, ab, ac, a, b, c)
xrayutilities.materials.lattice.CubicFm3mBaF2(aa, ab, a)
xrayutilities.materials.lattice.CubicLattice(a)
     Returns a Lattice object representing a simple cubic lattice.
     required input arguments:
             alattice parameter
     return value: an instance of Lattice class
```

```
xrayutilities.materials.lattice.DiamondLattice (aa, a)
xrayutilities.materials.lattice.FCCLattice(aa, a)
xrayutilities.materials.lattice.GeTeRhombohedral (aa, ab, a, ang, x=0.237)
xrayutilities.materials.lattice.GeneralPrimitiveLattice(a, b, c, alpha, beta,
                                                                      gamma)
xrayutilities.materials.lattice.HCPLattice(aa, a, c)
xrayutilities.materials.lattice.Hexagonal3CLattice (aa, ab, a, c)
xrayutilities.materials.lattice.Hexagonal4HLattice (aa, ab, a, c, u=0.1875,
                                                               v1=0.25, v2=0.4375)
xrayutilities.materials.lattice.Hexagonal6HLattice (aa, ab, a, c)
class xrayutilities.materials.lattice.Lattice(a1, a2, a3, base=None)
     Bases: object
     class Lattice: This object represents a Bravais lattice. A lattice consists of a base
     ApplyStrain (eps)
         Applies a certain strain on a lattice. The result is a change in the base vectors.
         requiered input arguments:
                 epsa 3x3 matrix independent strain components
     GetPoint (*args)
         determine lattice points with indices given in the argument
         Examples
         >>> xu.materials.Si.lattice.GetPoint(0,0,4)
                        , 0. , 21.72416])
         array([ 0.
         or
         >>> xu.materials.Si.lattice.GetPoint((1,1,1))
         array([ 5.43104, 5.43104, 5.43104])
     ReciprocalLattice()
     UnitCellVolume()
         function to calculate the unit cell volume of a lattice (angstrom^3)
class xrayutilities.materials.lattice.LatticeBase(*args, **keyargs)
     Bases: list
     The LatticeBase class implements a container for a set of points that form the base of a crystal lattice. An
     instance of this class can be treated as a simple container object.
     append (atom, pos, occ=1.0, b=0.0)
         add new Atom to the lattice base
         Parameter
                 atomatom object to be added
                 posposition of the atom
                 occoccupancy (default=1.0)
                 bb-factor of the atom used as \exp(-b*q**2/(4*pi)**2) to reduce the intensity of this
                   atom (only used in case of temp=0 in StructureFactor and chi calculation)
xrayutilities.materials.lattice.NaumanniteLattice (aa, ab, a, b, c)
xrayutilities.materials.lattice.NiAsLattice(aa, ab, a, c, biso=0.0)
xrayutilities.materials.lattice.PerovskiteTypeRhombohedral(aa, ab, ac, a, ang)
```

```
xrayutilities.materials.lattice.QuartzLattice(aa, ab, a, b, c)
xrayutilities.materials.lattice.RockSaltLattice(aa, ab, a)
xrayutilities.materials.lattice.RockSalt_Cubic_Lattice(aa, ab, a)
xrayutilities.materials.lattice.RutileLattice (aa, ab, a, c, u)
xrayutilities.materials.lattice.TetragonalIndiumLattice(aa, a, c)
xrayutilities.materials.lattice.TetragonalTinLattice (aa, a, c)
xrayutilities.materials.lattice.TrigonalR3mh (aa, a, c)
xrayutilities.materials.lattice.WurtziteLattice (aa, ab, a, c, u=0.375, biso=0.0)
xrayutilities.materials.lattice.ZincBlendeLattice(aa, ab, a)
4.5.8 material Module
class module implements a certain material
class xrayutilities.materials.material.Alloy (matA, matB, x)
     Bases: xrayutilities.materials.material.Material
     RelaxationTriangle (hkl, sub, exp)
          function which returns the relaxation trianlge for a Alloy of given composition. Reciprocal space
         coordinates are calculated using the user-supplied experimental class
         Parameter
                 hklMiller Indices
                 subsubstrate material or lattice constant (Instance of Material class or float)
                 expExperiment class from which the Transformation object and ndir are needed
          Returns
                 qy,qzreciprocal space coordinates of the corners of the relaxation triangle
     lattice_const_AB (latA, latB, x)
          method to set the composition of the Alloy. x is the atomic fraction of the component B
xrayutilities.materials.material.Cij2Cijkl(cij)
     Converts the elastic constants matrix (tensor of rank 2) to the full rank 4 cijkl tensor.
     required input arguments:
             cij(6,6) cij matrix as a numpy array
     return value:
             cijkl(3,3,3,3) cijkl tensor as numpy array
xrayutilities.materials.material.Cijkl2Cij (cijkl)
     Converts the full rank 4 tensor of the elastic constants to the (6,6) matrix of elastic constants.
     required input arguments:
             cijkl(3,3,3,3) cijkl tensor as numpy array
     return value:
             cij(6,6) cij matrix as a numpy array
class xrayutilities.materials.material.CubicAlloy (matA, matB, x)
     Bases: xravutilities.materials.material.Allov
```

ContentBasym (q_inp, q_perp, hkl, sur)

function that determines the content of B in the alloy from the reciprocal space position of an asymmetric peak and also sets the content in the current material

Parameter

q inpinplane peak position of reflection hkl of the alloy in reciprocal space

q_perpperpendicular peak position of the reflection hkl of the alloy in reciprocal space

hklMiller indices of the measured asymmetric reflection

surMiller indices of the surface (determines the perpendicular direction)

Returns

content,[a_inplane,a_perp,a_bulk_perp(x), eps_inplane, eps_perp] :the content of B in the alloy determined from the input variables and the lattice constants calculated from the reciprocal space positions as well as the strain (eps) of the layer

ContentBsym (*q_perp*, *hkl*, *inpr*, *asub*, *relax*)

function that determines the content of B in the alloy from the reciprocal space position of a symetric peak. As an additional input the substrates lattice parameter and the degree of relaxation must be given

Parameter

q_perpperpendicular peak position of the reflection hkl of the alloy in reciprocal space

hklMiller indices of the measured symmetric reflection (also defines the surface normal

inprMiller indices of a Bragg peak defining the inplane reference direction

asubsubstrate lattice constant

relaxdegree of relaxation (needed to obtain the content from symmetric reciprocal space position)

Returns

content the content of B in the alloy determined from the input variables

```
xrayutilities.materials.material.CubicElasticTensor(c11, c12, c44)
```

Assemble the 6x6 matrix of elastic constants for a cubic material from the three independent components of a cubic crystal

Parameter

c11,c12,c44independent components of the elastic tensor of cubic materials

Returns

6x6 materix with elastic constants

```
xrayutilities.materials.material.GeneralUC(a=4, b=4, c=4, alpha=90, beta=90, gamma=90, name='General')
```

general material with primitive unit cell but possibility for different a,b,c and alpha,beta,gamma

Parameters

a,b,cunit cell extensions (Angstrom)

alphaangle between unit cell vectors b,c

betaangle between unit cell vectors a,c

gammaangle between unit cell vectors a,b

returns a Material object with the specified properties

```
xrayutilities.materials.material.HexagonalElasticTensor(c11, c12, c13, c33,
      Assemble the 6x6 matrix of elastic constants for a hexagonal material from the five independent components
     of a hexagonal crystal
     Parameter
               c11,c12,c13,c33,c44independent components of the elastic tensor of a hexagonal ma-
                   terial
      Returns
           6x6 materix with elastic constants
class xrayutilities.materials.material.Material(name,
                                                                          lat,
                                                                                cij=None,
                                                                                             thetaDe-
                                                                 bye=None)
     Bases: object
     ApplyStrain (strain, **keyargs)
     В
     GetMismatch (mat)
           Calculate the mismatch strain between the material and a second material
     Q (*hkl)
           Return the Q-space position for a certain material.
           required input arguments:
                   hkllist or numpy array with the Miller indices ( or Q(h,k,l) is also possible)
      StructureFactor (q, en='config', temp=0)
           caluclates the structure factor of a material for a certain momentum transfer and energy at a certain
           temperature of the material
           Parameter
                   qvectorial momentum transfer (vectors as list, tuple or numpy array are valid)
                   enenergy in eV, if omitted the value from the xrayutilities configuration is used
                   temptemperature used for Debye-Waller-factor calculation
           Returns
               the complex structure factor
      StructureFactorForEnergy (q0, en, temp=0)
           caluclates the structure factor of a material for a certain momentum transfer and a bunch of energies
           Parameter
                   q0vectorial momentum transfer (vectors as list,tuple or numpy array are valid)
                   enlist, tuple or array of energy values in eV
                   temptemperature used for Debye-Waller-factor calculation
           Returns
               complex valued structure factor array
      StructureFactorForQ (q, en0='config', temp=0)
           caluclates the structure factor of a material for a bunch of momentum transfers and a certain energy
           Parameter
                   qvectorial momentum transfers; list of vectores (list, tuple or array) of length 3 e.g.:
                      (Si.Q(0,0,4),Si.Q(0,0,4.1),...) or numpy.array([Si.Q(0,0,4),Si.Q(0,0,4.1)])
                   en0energy value in eV, if omitted the value from the xrayutilities configuration is
                      used
```

```
temptemperature used for Debye-Waller-factor calculation
     Returns
          complex valued structure factor array
a1
a2
a3
b1
b2
b3
beta (en='config')
     function to calculate the imaginary part of the deviation of the refractive index from 1 (n=1-
     delta+i*beta)
     Parameter
              enx-ray energy eV, if omitted the value from the xrayutilities configuration is used
     Returns
          beta (float)
chi0 (en='config')
     calculates the complex chi_0 values often needed in simulations. They are closely related to delta and
     beta (n = 1 + chi_r0/2 + i*chi_i0/2 \text{ vs. } n = 1 - delta + i*beta)
chih (q, en='config', temp=0, polarization='S')
     calculates the complex polarizability of a material for a certain momentum transfer and energy
     Parameter
              qmomentum transfer in (1/A)
              enxray energy in eV, if omitted the value from the xrayutilities configuration is used
              temptemperature used for Debye-Waller-factor calculation
              polarizationeither 'S' (default) sigma or 'P' pi polarization
     Returns
          (abs(chih_real),abs(chih_imag)) complex polarizability
critical_angle (en='config', deg=True)
     calculate critical angle for total external reflection
     Parameter
              enenergy of the x-rays, if omitted the value from the xrayutilities configuration is
                 used
              degreturn angle in degree if True otherwise radians (default:True)
     Returns
          Angle of total external reflection
dTheta (Q, en='config')
     function to calculate the refractive peak shift
     Parameter
              Qmomentum transfer (1/A)
              enx-ray energy (eV), if omitted the value from the xrayutilities configuration is used
     Returns
```

```
deltaThetapeak shift in degree
     delta (en='config')
          function to calculate the real part of the deviation of the refractive index from 1 (n=1-delta+i*beta)
          Parameter
                   enx-ray energy eV, if omitted the value from the xrayutilities configuration is used
          Returns
              delta (float)
     distances()
          function to obtain distances of atoms in the crystal up to the unit cell size (largest value of a,b,c is the
          cut-off)
          returns a list of tuples with distance d and number of occurence n [(d1,n1),(d2,n2),...]
          Note: Note: if the base of the material is empty the list will be empty
     idx_refraction(en='config')
          function to calculate the complex index of refraction of a material in the x-ray range
          Parameter
                  enenergy of the x-rays, if omitted the value from the xrayutilities configuration is
                     used
          Returns
              n (complex)
     lam
     mu
     nu
xrayutilities.materials.material.PseudomorphicMaterial(submat, layermat)
     This function returns a material whos lattice is pseudomorphic on a particular substrate material. This
     function works meanwhile only for cubic materials on (001) substrates
     required input arguments:
              submatsubstrate material
              layermatbulk material of the layer
     return value: An instance of Material holding the new pseudomorphically strained material.
xrayutilities.materials.material.index_map_ij2ijkl(ij)
xrayutilities.materials.material.index_map_ijkl2ij(i, j)
4.5.9 predefined_materials Module
class xrayutilities.materials.predefined_materials.SiGe (x)
     Bases: xrayutilities.materials.material.CubicAlloy
     lattice_const_AB (latA, latB, x)
          method to calculate the lattice parameter of the SiGe alloy with composition Si_{1-x}Ge_x
     x
```

4.6 math Package

4.6.1 math Package

4.6.2 fit Module

module with a function wrapper to scipy.optimize.leastsq for fitting of a 2D function to a peak or a 1D Gauss fit with the odr package

```
xrayutilities.math.fit.fit_peak2d(x, y, data, start, drange, fit_function, maxfev=2000) fit a two dimensional function to a two dimensional data set e.g. a reciprocal space map
```

Parameters

x,ydata coordinates (do NOT need to be regularly spaced)

datadata set used for fitting (e.g. intensity at the data coords)

startset of starting parameters for the fit used as first parameter of function fit_function

drangelimits for the data ranges used in the fitting algorithm e.g. it is clever to use only a small region around the peak which should be fitted: [xmin,xmax,ymin,ymax]

fit_function function which should be fitted must accept the parameters (x,y,*params)

Returns

(fitparam,cov)the set of fitted parameters and covariance matrix

```
xrayutilities.math.fit.gauss_fit (xdata, ydata, iparams=[], maxit=200)
Gauss fit function using odr-pack wrapper in scipy similar to :https://github.com/tiagopereira/python_tips/wiki/Scipy%3A-curve-fitting
```

Parameters

xdataxcoordinates of the data to be fitted

ydataycoordinates of the data which should be fit

keyword parameters:

iparamsinitial paramters for the fit (determined automatically if nothing is given **maxit**maximal iteration number of the fit

Returns

```
params,sd_params,itlim
```

the Gauss parameters as defined in function Gauss1d(x, *param) and their errors of the fit, as well as a boolean flag which is false in the case of a successful fit

type='Gaussian')

function to fit multiple Gaussian/Lorentzian peaks with linear background to a set of data

Parameters

xx-coordinate of the data

datadata array with same length as x

peakposinitial parameters for the peak positions

4.6. math Package 107

peakwidthinitial values for the peak width

drangeslist of tuples with (min,max) value of the data ranges to use. does not need to have the same number of entries as peakpos

peaktypetype of peaks to be used: can be either 'Gaussian' or 'Lorentzian'

Returns

pos,sigma,amp,background

Pos list of peak positions derived by the fit

Sigma list of peak width derived by the fit

Amp list of amplitudes of the peaks derived by the fit

Background array of background values at positions x

function to plot multiple Gaussian/Lorentz peaks with background values given by an array

Parameters

xx-coordinate of the data

fposlist of positions of the peaks

fwidthlist of width of the peaks

famplist of amplitudes of the peaks

backgroundarray with background values

drangeslist of tuples with (min,max) value of the data ranges to use. does not need to have the same number of entries as fpos

peaktypetype of peaks to be used: can be either 'Gaussian' or 'Lorentzian'

figmatplotlib figure number or name

fact factor to use as multiplicator in the plot

4.6.3 functions Module

module with several common function needed in xray data analysis

```
xrayutilities.math.functions.Debye1(x)
```

function to calculate the first Debye function as needed for the calculation of the thermal Debye-Waller-factor by numerical integration

for definition see: :http://en.wikipedia.org/wiki/Debye_function

 $D1(x) = (1/x) int_0^x t/(exp(t)-1) dt$

Parameters

xargument of the Debye function (float)

Returns

D1(x)float value of the Debye function

```
xrayutilities.math.functions.Gaussld(x, *p)
```

function to calculate a general one dimensional Gaussian

Parameters

plist of parameters of the Gaussian [XCEN,SIGMA,AMP,BACKGROUND] for information: SIGMA = FWHM / (2*sqrt(2*log(2)))

```
xcoordinate(s) where the function should be evaluated
     Returns
     the value of the Gaussian described by the parameters p at position x
xrayutilities.math.functions.Gauss1d_der_p (x, *p)
     function to calculate the derivative of a Gaussian with respect the parameters p
     for parameter description see Gauss 1d
xrayutilities.math.functions.Gauss1d_der_x (x, *p)
     function to calculate the derivative of a Gaussian with respect to x
     for parameter description see Gauss1d
xrayutilities.math.functions.Gauss2d(x, y, *p)
     function to calculate a general two dimensional Gaussian
     Parameters
              plist of parameters of the Gauss-function [XCEN, YCEN, SIGMAX, SIGMAY, AMP, BACKGROUND, ANGLE]
                  SIGMA = FWHM / (2*sqrt(2*log(2))) ANGLE = rotation of the X,Y direction of
                  the Gaussian in radians
              x,ycoordinate(s) where the function should be evaluated
     Returns
     the value of the Gaussian described by the parameters p at position (x,y)
xrayutilities.math.functions.Gauss3d (x, y, z, *p)
     function to calculate a general three dimensional Gaussian
     Parameters
              plist of parameters of the Gauss-function [XCEN,YCEN,ZCEN,SIGMAX,SIGMAY,SIGMAZ,AMP,BACKGROUN
                   SIGMA = FWHM / (2*sqrt(2*log(2)))
              x,y,zcoordinate(s) where the function should be evaluated
     Returns
     the value of the Gaussian described by the parameters p at positions (x,y,z)
xrayutilities.math.functions.Lorentz1d(x, *p)
     function to calculate a general one dimensional Lorentzian
     Parameters
              plist of parameters of the Lorentz-function [XCEN,FWHM,AMP,BACKGROUND]
              x,ycoordinate(s) where the function should be evaluated
     Returns
     the value of the Lorentian described by the parameters p at position (x,y)
xrayutilities.math.functions.Lorentz1d der p(x, *p)
     function to calculate the derivative of a Gaussian with respect the parameters p
     for parameter description see Lorentz1d
xrayutilities.math.functions.Lorentz1d_der_\mathbf{x}(x, *p)
     function to calculate the derivative of a Gaussian with respect to x
     for parameter description see Lorentz1d
xrayutilities.math.functions.Lorentz2d(x, y, *p)
     function to calculate a general two dimensional Lorentzian
```

4.6. math Package 109

Parameters

plist of parameters of the Lorentz-function [XCEN,YCEN,FWHMX,FWHMY,AMP,BACKGROUND,ANGLE]

ANGLE = rotation of the X,Y direction of the Lorentzian in radians

x,ycoordinate(s) where the function should be evaluated

Returns

the value of the Lorentian described by the parameters p at position (x,y)

```
xrayutilities.math.functions.PseudoVoigt1d (x, *p)
```

function to calculate a pseudo Voigt function as linear combination of a Gauss and Lorentz peak

Parameters

plist of parameters of the Lorentz-function [XCEN,FWHM,AMP,BACKGROUND,ETA] :ETA: 0 ...1 0 means pure Gauss and 1 means pure Lorentz

x,ycoordinate(s) where the function should be evaluated

Returns

the value of the PseudoVoigt described by the parameters p at position (x,y)

```
xrayutilities.math.functions.TwoGauss2d(x, y, *p)
```

function to calculate two general two dimensional Gaussians

Parameters

```
plist of parameters of the Gauss-function [XCEN1,YCEN1,SIGMAX1,SIGMAY1,AMP1,ANGLE1,XCEN2,YCEN SIGMA = FWHM / (2*sqrt(2*log(2))) ANGLE = rotation of the X,Y direction of the Gaussian in radians
```

x,ycoordinate(s) where the function should be evaluated

Return

the value of the Gaussian described by the parameters p at position (x,y)

```
xrayutilities.math.functions.kill_spike(data, threshold=2.0)
```

function to smooth **single** data points which differ from the average of the neighboring data points by more than the threshold factor. Such spikes will be replaced by the mean value of the next neighbors.

Warning: Use this function carefully not to manipulate your data!

Parameters

data1d numpy array with experimental data

threshold factor to identify strange data points

Returns

1d data-array with spikes removed

```
xrayutilities.math.functions.smooth (x, n)
```

function to smooth an array of data by averaging N adjacent data points

Parameters

x1D data array

nnumber of data points to average

Returns

 $\boldsymbol{xsmooth}$ smoothed array with same length as \boldsymbol{x}

4.6.4 transforms Module

```
class xrayutilities.math.transforms.AxisToZ (newzaxis)
     Bases: xrayutilities.math.transforms.CoordinateTransform
     Creates a coordinate transformation to move a certain axis to the z-axis. The rotation is done along the great
     circle. The x-axis of the new coordinate frame is created to be normal to the new and original z-axis. The
     new y-axis is create in order to obtain a right handed coordinate system.
xrayutilities.math.transforms.Cij2Cijkl(cij)
     Converts the elastic constants matrix (tensor of rank 2) to the full rank 4 cijkl tensor.
     required input arguments:
              cij(6,6) cij matrix as a numpy array
     return value:
              cijkl(3,3,3,3) cijkl tensor as numpy array
xrayutilities.math.transforms.Cijkl2Cij(cijkl)
     Converts the full rank 4 tensor of the elastic constants to the (6,6) matrix of elastic constants.
     required input arguments:
              cijkl(3,3,3,3) cijkl tensor as numpy array
     return value:
              cij(6,6) cij matrix as a numpy array
class xrayutilities.math.transforms.CoordinateTransform (vI, v2, v3)
     Bases: xrayutilities.math.transforms.Transform
     Create a Transformation object which transforms a point into a new coordinate frame. The new frame is
     determined by the three vectors v1/norm(v1), v2/norm(v2) and v3/norm(v3), which need to be orthogonal!
class xrayutilities.math.transforms.Transform(matrix)
     Bases: object
     inverse (*args)
          performs inverse transformation a vector, matrix or tensor of rank 4
          Parameters
              *args: object to transform, list or numpy array of shape(n,) (n,n), (n,n,n,n) where n is the
                  rank of the transformation matrix
xrayutilities.math.transforms.XRotation(alpha, deg=True)
     Returns a transform that represents a rotation about the x-axis by an angle alpha. If deg=True the angle is
     assumed to be in degree, otherwise the function expects radiants.
xrayutilities.math.transforms.YRotation(alpha, deg=True)
     Returns a transform that represents a rotation about the y-axis by an angle alpha. If deg=True the angle is
     assumed to be in degree, otherwise the function expects radiants.
xrayutilities.math.transforms.ZRotation(alpha, deg=True)
     Returns a transform that represents a rotation about the z-axis by an angle alpha. If deg=True the angle is
     assumed to be in degree, otherwise the function expects radiants.
xrayutilities.math.transforms.index_map_ij2ijkl(ij)
xrayutilities.math.transforms.index_map_ijkl2ij(i, j)
xrayutilities.math.transforms.mycross(vec, mat)
     function implements the cross-product of a vector with each column of a matrix
xrayutilities.math.transforms.rotarb(vec, axis, ang, deg=True)
     function implements the rotation around an arbitrary axis by an angle ang positive rotation is anti-clockwise
```

4.6. math Package 111

when looking from positive end of axis vector

```
Parameter
              vecnumpy.array or list of length 3
              axisnumpy.array or list of length 3
              angrotation angle in degree (deg=True) or in rad (deg=False)
              degboolean which determines the input format of ang (default: True)
     Returns
              rotvecrotated vector as numpy.array
     Example
     >>> rotarb([1,0,0],[0,0,1],90)
     array([ 6.12323400e-17, 1.00000000e+00,
                                                           0.00000000e+00])
xrayutilities.math.transforms.tensorprod(vec1, vec2)
     function implements an elementwise multiplication of two vectors
4.6.5 vector Module
module with vector operations, mostly numpy functionality is used for the vector operation itself, however custom
error checking is done to ensure vectors of length 3.
xrayutilities.math.vector.VecAngle(v1, v2, deg=False)
     calculate the angle between two vectors.
                                                        The following formula is used v1.v2 =
     norm(v1)*norm(v2)*cos(alpha)
     alpha = acos((v1.v2)/(norm(v1)*norm(v2)))
     required input arguments:
              v1vector as numpy array or list
              v2vector as numpy array or list
     optional keyword arguments:
              deg(default: false) return result in degree otherwise in radiants
     return value: float value with the angle inclined by the two vectors
xrayutilities.math.vector.VecDot(v1, v2)
     Calculate the vector dot product.
     required input arguments:
              v1vector as numpy array or list
              v2vector as numpy array or list
     return value:float value
xrayutilities.math.vector.VecNorm(v)
     Calculate the norm of a vector.
     required input arguments:
              vvector as list or numpy array
     return value:float holding the vector norm
xrayutilities.math.vector.VecUnit(v)
     Calculate the unit vector of v.
     required input arguments:
```

vvector as list or numpy array

return value: numpy array with the unit vector

```
xrayutilities.math.vector.getSyntax(vec)
```

returns vector direction in the syntax 'x+' 'z-' or equivalents therefore works only for principle vectors of the coordinate system like e.g. [1,0,0] or [0,2,0]

Parameters

string[xyz][+-]

Returns

vector along the given direction as numpy array

```
xrayutilities.math.vector.getVector(string)
```

returns unit vector along a rotation axis given in the syntax 'x+' 'z-' or equivalents

Parameters

string[xyz][+-]

Returns

vector along the given direction as numpy array

4.7 xrayutilities

4.7.1 xrayutilities Package

xrayutilities Package

xrayutilities is a Python package for assisting with x-ray diffraction experiments. Its the python package included in *xrayutilities*.

It helps with planning experiments as well as analyzing the data.

Authors Dominik Kriegner <dominik.kriegner@gmail.com> and Eugen Wintersberger <eugen.wintersberger@desy.de>

config Module

module to parse xrayutilities user-specific config file the parsed values are provide as global constants for the use in other parts of xrayutilities. The config file with the default constants is found in the python installation path of xrayutilities. It is however not recommended to change things there, instead the user-specific config file ~/.xrayutilities.conf or the local xrayutilities.conf file should be used.

exception Module

xrayutilities derives its own exceptions which are raised upon wrong input when calling one of xrayutilities functions. none of the pre-defined exceptions is made for that purpose.

```
exception xrayutilities.exception.InputError(msg)
Bases: exceptions.Exception
```

Exception raised for errors in the input. Either wrong datatype not handled by TypeError or missing mandatory keyword argument (Note that the obligation to give keyword arguments might depend on the value of the arguments itself)

Attibutesexpr - input expression in which the error occurred :msg: - explanation of the error

experiment Module

module helping with planning and analyzing experiments

various classes are provided for

* describing experiments * calculating angular coordinates of Bragg reflections * converting angular coordinates to Q-space and vice versa * simulating powder diffraction patterns for materials

```
class xrayutilities.experiment.Experiment(ipdir, ndir, **keyargs)
```

Bases: object

base class for describing experiments users should use the derived classes: HXRD, GID, Powder

Ang2HKL (*args, **kwargs)

angular to (h,k,l) space conversion. It will set the UB argument to Ang2Q and pass all other parameters unchanged. See Ang2Q for description of the rest of the arguments.

Parameters

**kwargs: optional keyword arguments

Breciprocal space conversion matrix of a Material. you can specify the matrix B (default identity matrix) shape needs to be (3,3)

matMaterial object to use to obtain a B matrix (e.g. xu.materials.Si) can be used as alternative to the B keyword argument B is favored in case both are given

Uorientation matrix U can be given if none is given the orientation defined in the Experiment class is used.

dettypedetector type: one of ('point', 'linear', 'area') decides which routine of Ang2Q to call default 'point'

Returns

H K L coordinates as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input (*args)

Q2Ang(qvec)

TiltAngle (q, deg=True)

TiltAngle(q,deg=True): Return the angle between a q-space position and the surface normal.

Parameters

qlist or numpy array with the reciprocal space position

optional keyword arguments:

degTrue/False whether the return value should be in degree or radians :(default: True)

Transform (v)

transforms a vector, matrix or tensor of rank 4 (e.g. elasticity tensor) to the coordinate frame of the Experiment class.

Parameters

vobject to transform, list or numpy array of shape (n,) (n,n), (n,n,n,n) where n is the rank of the transformation matrix

Returns

transformed object of the same shape as v

energy

wavelength

```
class xrayutilities.experiment.GID (idir, ndir, **keyargs)
```

Bases: xrayutilities.experiment.Experiment

class describing grazing incidence x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as it helps with analyzing measured data

the class describes a four circle (alpha_i,azimuth,twotheta,beta) goniometer to help with GID experiments at the ROTATING ANODE. 3D data can be treated with the use of linear and area detectors. see help self.Ang2Q

Ang2Q (ai, phi, tt, beta, **kwargs)

angular to momentum space conversion for a point detector. Also see help GID.Ang2Q for procedures which treat line and area detectors

Parameters

ai,phi,tt,betasample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 4. used angles are than ai,phi,tt,beta - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

Q2Ang (Q, trans=True, deg=True, **kwargs)

calculate the GID angles needed in the experiment the inplane reference direction defines the direction were the reference direction is parallel to the primary beam (i.e. lattice planes perpendicular to the beam)

Parameters

Qa list or numpy array of shape (3) with q-space vector components

optional keyword arguments:

transTrue/False apply coordinate transformation on Q

degTrue/Flase (default True) determines if the angles are returned in radians or degrees

Returns

a numpy array of shape (4) with the four GID scattering angles which are [al-pha_i,azimuth,twotheta,beta]

alpha_iincidence angle to surface (at the moment always 0)

azimuthsample rotation with respect to the inplane reference direction

twothetascattering angle

betaexit angle from surface (at the moment always 0)

class describing grazing incidence x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as it helps with analyzing measured data

the class describes a four circle (theta,omega,delta,gamma) goniometer to help with GID experiments at ID10B / ESRF. 3D data can be treated with the use of linear and area detectors. see help self.Ang2Q

Ang2Q (th, om, delta, gamma, **kwargs)

angular to momentum space conversion for a point detector. Also see help GID_ID10B.Ang2Q for procedures which treat line and area detectors

Parameters

th,om,delta,gammasample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 4. used angles are than th,om,delta,gamma - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

```
Q2Ang (Q, trans=True, deg=True, **kwargs)
```

calculate the GID angles needed in the experiment the inplane reference direction defines the direction were the reference direction is parallel to the primary beam (i.e. lattice planes perpendicular to the beam)

Parameters

Qa list or numpy array of shape (3) with q-space vector components

optional keyword arguments:

transTrue/False apply coordinate transformation on Q

degTrue/Flase (default True) determines if the angles are returned in radians or degrees

Returns

a numpy array of shape (4) with the four GID scattering angles which are (theta,omega,delta,gamma)

thetaincidence angle to surface (at the moment always 0)

omegasample rotation with respect to the inplane reference direction

deltaexit angle from surface (at the moment always 0)

gammascattering angle

```
class xrayutilities.experiment.GISAXS (idir, ndir, **keyargs)
```

```
Bases: xrayutilities.experiment.Experiment
```

class describing grazing incidence x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as it helps with analyzing measured data

the class describes a three circle (alpha_i,twotheta,beta) goniometer to help with GISAXS experiments at the ROTATING ANODE. 3D data can be treated with the use of linear and area detectors. see help self.Ang2Q

```
Ang2Q (ai, tt, beta, **kwargs)
```

angular to momentum space conversion for a point detector. Also see help GISAXS.Ang2Q for procedures which treat line and area detectors

Parameters

ai,tt,betasample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 3. used angles are than ai,tt,beta - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

Q2Ang (Q, trans=True, deg=True, **kwargs)

```
class xrayutilities.experiment.HXRD(idir, ndir, geometry='hi_lo', **keyargs)
    Bases: xrayutilities.experiment.Experiment
```

class describing high angle x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as helps with analyzing measured data

the class describes a two circle (omega,twotheta) goniometer to help with coplanar x-ray diffraction experiments. Nevertheless 3D data can be treated with the use of linear and area detectors. see help self.Ang2Q

Ang2Q(om, tt, **kwargs)

angular to momentum space conversion for a point detector. Also see help HXRD.Ang2Q for procedures which treat line and area detectors

Parameters

om,ttsample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 2. used angles are than om,tt - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (* , 3) where * corresponds to the number of points given in the input

Q2Ang (*Q, **keyargs)

Convert a reciprocal space vector Q to COPLANAR scattering angles. The keyword argument trans determines whether Q should be transformed to the experimental coordinate frame or not.

Parameters

Qa list, tuple or numpy array of shape (3) with q-space vector components or 3 separate lists with qx,qy,qz

optional keyword arguments:

transTrue/False apply coordinate transformation on Q (default True)

degTrue/Flase (default True) determines if the angles are returned in radians or degrees **geometry**determines the scattering geometry:

- •"hi_lo" high incidence and low exit
- •"lo hi" low incidence and high exit
- •"real" general geometry with angles determined by q-coordinates (azimuth); this and upper geometry
 - -"realTilt" general geometry with angles determined by q-coordinates (tilt); returns [omega,chi,phi,twotheta]

defaultself.geometry

refracboolean to determine if refraction is taken into account :default: False if True then also a material must be given

matMaterial object; needed to obtain its optical properties for refraction correction, otherwise not used

full_outputboolean to determine if additional output is given to determine scattering angles more accurately in case refraction is set to True :default: False

fi,fdif refraction correction is applied one can optionally specify the facet through which the beam enters (fi) and exits (fd) fi, fd must be the surface normal vectors (not transformed & not necessarily normalized). If omitted the normal direction of the experiment is used.

Returns

a numpy array of shape (4) with four scattering angles which are [omega,chi,phi,twotheta]

omegaincidence angle with respect to surface

chisample tilt for the case of non-coplanar geometry

phisample azimuth with respect to inplane reference direction

twothetascattering angle/detector angle

if full_output: a numpy array of shape (6) with five angles which are [omega,chi,phi,twotheta,psi_i,psi_d]

psi_ioffset of the incidence beam from the scattering plane due to refraction

pdi_doffset of the diffracted beam from the scattering plane due to refraction

```
class xrayutilities.experiment.NonCOP (idir, ndir, **keyargs)
```

```
Bases: xrayutilities.experiment.Experiment
```

class describing high angle x-ray diffraction experiments the class helps with calculating the angles of Bragg reflections as well as helps with analyzing measured data for NON-COPLANAR measurements, where the tilt is used to align asymmetric peaks, like in the case of a polefigure measurement.

the class describes a four circle (omega,twotheta) goniometer to help with x-ray diffraction experiments. Linear and area detectors can be treated as described in "help self.Ang2Q"

```
Ang2Q (om, chi, phi, tt, **kwargs)
```

angular to momentum space conversion for a point detector. Also see help NonCOP.Ang2Q for procedures which treat line and area detectors

Parameters

om,chi,phi,ttsample and detector angles as numpy array, lists or Scalars must be given. all arguments must have the same shape or length

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of length 4. used angles are than om,chi,phi,tt - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: identity matrix)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of points given in the input

Q2Ang (*Q, **keyargs)

Convert a reciprocal space vector Q to NON-COPLANAR scattering angles. The keyword argument trans determines whether Q should be transformed to the experimental coordinate frame or not.

Parameters

Qa list, tuple or numpy array of shape (3) with q-space vector components or 3 separate lists with qx,qy,qz

optional keyword arguments:

transTrue/False apply coordinate transformation on Q (default True)

degTrue/Flase (default True) determines if the angles are returned in radians or degree

Returns

a numpy array of shape (4) with four scattering angles which are [omega,chi,phi,twotheta]

omegasample rocking angle

chisample tilt

phisample azimuth

twothetascattering angle (detector)

```
class xrayutilities.experiment.Powder (mat, **keyargs)
```

```
Bases: \verb|xrayutilities.experiment.Experiment|\\
```

Experimental class for powder diffraction This class is able to simulate a powder spectrum for the given material

Convolute (stepwidth, width, min=0, max=None)

Convolutes the intensity positions with Gaussians with width in momentum space of "width". returns array of angular positions with corresponding intensity

thetaarray with angular positions

intintensity at the positions ttheta

PowderIntensity (tt_cutoff=180)

Calculates the powder intensity and positions up to an angle of tt_cutoff (deg) and stores the result in:

dataarray with intensities

angangular position of intensities

qposreciprocal space position of intensities

Q2Ang(qpos, deg=True)

Converts reciprocal space values to theta angles

Class for the conversion of angular coordinates to momentum space for arbitrary goniometer geometries

the class is configured with the initialization and does provide three distinct routines for conversion to momentum space for

* point detector: point(...) or __call__() * linear detector: linear(...) * area detector: area(...)

linear() and area() can only be used after the init linear() or init area() routines were called

UВ

area(*args, **kwargs)

angular to momentum space conversion for a area detector the center pixel defined by the init_area routine must be in direction of self.r_i when detector angles are zero

the detector geometry must be initialized by the init_area(...) routine

Parameters

*args: sample and detector angles as numpy array, lists or Scalars

in total len(self.sampleAxis)+len(detectorAxis) must be given always starting with the outer most circle all arguments must have the same shape or length

sAnglessample circle angles, number of arguments must correspond to len(self.sampleAxis)

dAnglesdetector circle angles, number of arguments must correspond to len(self.detectorAxis)

**kwargs: possible keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of len(*args) used angles are than *args - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: self.UB)

roiregion of interest for the detector pixels; e.g. [100,900,200,800] :(default: self._area_roi)

Navnumber of channels to average to reduce data size e.g. [2,2] :(default: self._area_nav)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space position of all detector pixels in a numpy.ndarray of shape ($(*)*(self_area_roi[1]-self_area_roi[0]+1)*(self_area_roi[3]-self_area_roi[2]+1)$, 3) were detectorDir1 is the fastest varing

detectorAxis

property handler for _detectorAxis

Returns

list of detector axis following the syntax /[xyz][+-]/

energy

initialization routine for area detectors detector direction as well as distance and pixel size or channels

per degree must be given. Two separate pixel sizes and channels per degree for the two orthogonal directions can be given

Parameters

detectorDir1direction of the detector (along the pixel direction 1); e.g. 'z+' means higher pixel numbers at larger z positions

detectorDir2direction of the detector (along the pixel direction 2); e.g. 'x+'

cch1,2center pixel, in direction of self.r_i at zero detectorAngles

Nch1number of detector pixels along direction 1

Nch2number of detector pixels along direction 2

distance distance of center pixel from center of rotation

pwidth1,2width of one pixel (same unit as distance)

chpdeg1,2channels per degree (only absolute value is relevant) sign determined through detectorDir1,2

detrotangle of the detector rotation around primary beam direction (used to correct misalignments)

tiltazimuthdirection of the tilt vector in the detector plane (in degree)

tilttilt of the detector plane around an axis normal to the direction given by the tiltazimuth

Note: Note: Either distance and pwidth1,2 or chpdeg1,2 must be given!!

Note: Note: the channel numbers run from 0 .. NchX-1

**kwargs: optional keyword arguments

Navnumber of channels to average to reduce data size (default: [1,1])

roiregion of interest for the detector pixels; e.g. [100,900,200,800]

initialization routine for linear detectors detector direction as well as distance and pixel size or channels per degree must be given.

Parameters

detectorDirdirection of the detector (along the pixel array); e.g. 'z+'

cchcenter channel, in direction of self.r i at zero detectorAngles

Nchanneltotal number of detector channels

distance distance of center channel from center of rotation

pixelwidthwidth of one pixel (same unit as distance)

chpdegchannels per degree (only absolute value is relevant) sign determined through detectorDir

!! Either distance and pixelwidth or chpdeg must be given !!

tilttilt of the detector axis from the detectorDir (in degree)

Note: Note: the channel numbers run from 0 .. Nchannel-1

**kwargs: optional keyword arguments

Navnumber of channels to average to reduce data size (default: 1)

roiregion of interest for the detector pixels; e.g. [100,900]

linear(*args, **kwargs)

angular to momentum space conversion for a linear detector the cch of the detector must be in direction of self.r_i when detector angles are zero

the detector geometry must be initialized by the init_linear(...) routine

Parameters

*args: sample and detector angles as numpy array, lists or Scalars

in total len(self.sampleAxis)+len(detectorAxis) must be given always starting with the outer most circle all arguments must have the same shape or length

sAnglessample circle angles, number of arguments must correspond to len(self.sampleAxis)

dAnglesdetector circle angles, number of arguments must correspond to len(self.detectorAxis)

**kwargs: possible keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of len(*args) used angles are than *args - delta

UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q but (hkl) :(default: self.UB)

Navnumber of channels to average to reduce data size (default: self._linear_nav)

roiregion of interest for the detector pixels; e.g. [100,900] (default: self._linear_roi)

wlx-ray wavelength in angstroem (default: self._wl)

degflag to tell if angles are passed as degree (default: True)

Returns

reciprocal space position of all detector pixels in a numpy.ndarray of shape ($(*)*(self_linear_roi[1]-self_linear_roi[0]+1)$, 3)

point (*args, **kwargs)

angular to momentum space conversion for a point detector located in direction of self.r_i when detector angles are zero

Parameters

*args: sample and detector angles as numpy array, lists

or Scalars in total len(self.sampleAxis)+len(detectorAxis) must be given, always starting with the outer most circle. all arguments must have the same shape or length

sAnglessample circle angles, number of arguments must correspond to len(self.sampleAxis)

dAnglesdetector circle angles, number of arguments must correspond to len(self.detectorAxis)

**kwargs: optional keyword arguments

deltagiving delta angles to correct the given ones for misalignment delta must be an numpy array or list of len(*args) used angles are than *args - delta

```
UBmatrix for conversion from (hkl) coordinates to Q of sample used to determine not Q
                       but (hkl) :(default: self.UB)
                     wlx-ray wavelength in angstroem (default: self._wl)
                    degflag to tell if angles are passed as degree :(default: True)
          Returns
          reciprocal space positions as numpy.ndarray with shape (*, 3) where * corresponds to the number of
          points given in the input
     sampleAxis
          property handler for _sampleAxis
          Returns
          list of sample axis following the syntax /[xyzk][+-]/
     wavelength
gridder Module
class xrayutilities.gridder.Gridder
     Bases: object
     KeepData (bool)
     Normalize (bool)
class xrayutilities.gridder.Gridder1D (nx)
     Bases: xrayutilities.gridder.Gridder
     Clear()
     data
          Returns the xaxis of the gridder the returned values correspond to the center of the data bins used by
          the numpy.histogram function
xrayutilities.gridder.axis (min_value, max_value, n)
     Compute the a grid axis.
     Parameters
          Min_value axis minimum value
          Max_value axis maximum value
          N number of steps
xrayutilities.gridder.check_array(a, dtype)
     Check if an array fits the requirements for the C-code and returns it back to the callee. Such arrays must be
     aligned and C_CONTIGUOUS which means that they have to follow C-ordering.
     Parameters
          A array to check
          Dtype numpy data type
xrayutilities.gridder.delta(min_value, max_value, n)
     Compute the stepsize along an axis of a grid.
     Parameters
          Min_value axis minimum value
          Max_value axis maximum value
```

```
N number of steps
xrayutilities.gridder.ones(*args)
     Compute ones for matrix generation. The shape is determined by the number of input arguments.
gridder2d Module
class xrayutilities.gridder2d.Gridder2D (nx, ny)
     Bases: xrayutilities.gridder.Gridder
     Clear()
     SetResolution (nx, ny)
          Reset the resolution of the gridder. In this case the original data stored in the object will be deleted.
              Nx number of points in x-direction
              Ny number of points in y-direction
     data
     xaxis
     xmatrix
     yaxis
     ymatrix
gridder3d Module
class xrayutilities.gridder3d.Gridder3D (nx, ny, nz)
     Bases: xrayutilities.gridder.Gridder
     SetResolution (nx, ny, nz)
     xaxis
     xmatrix
     yaxis
     ymatrix
     zaxis
     zmatrix
normalize Module
module to provide functions that perform block averaging of intensity arrays to reduce the amount of data (mainly
for PSD and CCD measurements
provide functions for normalizing intensities for
* count time * absorber (user-defined function) * monitor * flatfield correction
```

generic class for correction of intensity (point detector, or MCA, single CCD frames) for count time and absorber factors the class must be supplied with a absorber correction function and works with data structures provided by xrayutilities.io classes or the corresponding objects from hdf5 files read by pytables

class xrayutilities.normalize.IntensityNormalizer(det, **keyargs)

Bases: object

absfun

absfun property handler returns the costum correction function or None

avmon

av_mon property handler returns the value of the average monitor or None if average is calculated from the monitor field

darkfield

flatfield property handler returns the current set darkfield of the detector or None if not set

det

det property handler returns the detector field name

flatfield

flatfield property handler returns the current set flatfield of the detector or None if not set

mon

mon property handler returns the monitor field name or None if not set

time

time property handler returns the count time or the field name of the count time or None if time is not set

xrayutilities.normalize.blockAverage1D (data, Nav)

perform block average for 1D array/list of Scalar values all data are used. at the end of the array a smaller cell may be used by the averaging algorithm

Parameter

datadata which should be contracted (length N)

Navnumber of values which should be averaged

Returns

block averaged numpy array of data type numpy.double (length ceil(N/Nav))

xrayutilities.normalize.blockAverage2D (data2d, Nav1, Nav2, **kwargs)

perform a block average for 2D array of Scalar values all data are used therefore the margin cells may differ in size

Parameter

data2darray of 2D data shape (N,M)

Nav1,2a field of (Nav1 x Nav2) values is contracted

**kwargs: optional keyword argument

roiregion of interest for the 2D array. e.g. [20,980,40,960] N = 980-20; M = 960-40

Returns

block averaged numpy array with type numpy.double with shape (ceil(N/Nav1), ceil(M/Nav2))

```
xrayutilities.normalize.blockAveragePSD (psddata, Nav, **kwargs)
```

perform a block average for serveral PSD spectra all data are used therefore the last cell used for averaging may differ in size

Parameter

psddataarray of 2D data shape (Nspectra, Nchannels)

Navnumber of channels which should be averaged

**kwargs: optional keyword argument

roiregion of interest for the 2D array. e.g. [20,980] Nchannels = 980-20

Returns

block averaged psd spectra as numpy array with type numpy.double of shape (Nspectra , ceil(Nchannels/Nav))

utilities Module

xrayutilities utilities contains a conglomeration of useful functions which do not fit into one of the other files

```
xrayutilities.utilities.maplog(inte, dynlow='config', dynhigh='config', **keyargs)
```

clips values smaller and larger as the given bounds and returns the log10 of the input array. The bounds are given as exponent with base 10 with respect to the maximum in the input array. The function is implemented in analogy to J. Stangl's matlab implementation.

Parameters

intenumpy.array, values to be cut in range

dynlow10^(-dynlow) will be the minimum cut off

dynhigh 10[^](-dynhigh) will be the maximum cut off

optional keyword arguments (NOT IMPLEMENTED):

```
abslow10^(abslow) will be taken as lower boundary abshigh10^(abshigh) will be taken as higher boundary
```

Returns

numpy.array of the same shape as inte, where values smaller/larger then 10^(-dynlow,dynhigh) were replaced by 10^(-dynlow,dynhigh)

Example

```
>>> lint = maplog(int,5,2)
```

utilities_noconf Module

xrayutilities utilities contains a conglomeration of useful functions this part of utilities does not need the config class

```
xrayutilities.utilities_noconf.energy(en)
```

convert common energy names to energies in eV

so far this works with CuKa1, CuKa2, CuKa12, CuKb, MoKa1

Parameter

enenergy (scalar (energy in eV will be returned unchanged) or string with name of emission line)

Returns

energy in eV as float

```
xrayutilities.utilities noconf.lam2en(inp)
```

converts the input energy in eV to a wavelength in Angstrom or the input wavelength in Angstrom to an energy in eV

Parameter

inpeither an energy in eV or an wavelength in Angstrom

Returns

float, energy in eV or wavlength in Angstrom

Examples

```
>>> lambda = lam2en(8048)
>>> energy = lam2en(1.5406)

xrayutilities.utilities_noconf.wavelength(wl)
    convert common energy names to energies in eV
    so far this works with CuKa1, CuKa2, CuKa12, CuKb, MoKa1
```

Parameter

wlwavelength (scalar (wavelength in Angstrom will be returned unchanged) or string with name of emission line)

Returns

wavelength in Angstrom as float

Subpackages

analysis Package

analysis Package xrayutilities.analysis is a package for assisting with the analysis of x-ray diffraction data, mainly reciprocal space maps

Routines for obtaining line cuts from gridded reciprocal space maps are offered, with the ability to integrate the intensity perpendicular to the line cut direction.

line_cuts Module

```
xrayutilities.analysis.line_cuts.fwhm_exp(pos, data)
```

function to determine the full width at half maximum value of experimental data. Please check the obtained value visually (noise influences the result)

Parameter

posposition of the data points

datadata values

Returns

```
fwhm value (single float)
```

extracts an omega scan from a gridded reciprocal space map

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

omcenteromega-position at which the omega scan should be extracted

ttcenter2theta-position at which the omega scan should be extracted

omrangerange of the omega scan to extract

npointsnumber of points of the omega scan

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

```
Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative omega positions are returned (default: True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               om,omintomega scan coordinates and intensities (bounds=False)
               om,omint,(qxb,qzb)omega scan coordinates and intensities + reciprocal space bounds
                   of the extraced scan (bounds=True)
     Example
     >>> omcut, intcut = get_omega_scan(qx,qz,intensity,0.0,5.0,2.0,200)
xrayutilities.analysis.line_cuts.get_omega_scan_bounds_ang(omcenter,
                                                                                                tt-
                                                                                 center,
                                                                                              om-
                                                                                          npoints.
                                                                                 range,
                                                                                 **kwargs)
     return reciprocal space boundaries of omega scan
     Parameters
               omcenteromega-position at which the omega scan should be extracted
               ttcenter2theta-position at which the omega scan should be extracted
               omrangerange of the omega scan to extract
               npointsnumber of points of the omega scan
      **kwargs: possible keyword arguments:
               grangeintegration range perpendicular to scan direction
               lamwavelength for use in the conversion to angular coordinates
     Returns
               qx,qzreciprocal space coordinates of the omega scan boundaries
     Example
     >>> qxb,qzb = get_omega_scan_bounds_ang(1.0,4.0,2.4,240,qrange=0.1)
\verb|xrayutilities.analysis.line_cuts.get_omega_scan_q| (qx, qz, intensity, qxcenter,
                                                                     qzcenter, omrange, npoints,
                                                                     **kwargs)
     extracts an omega scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               qxcenterqx-position at which the omega scan should be extracted
               qzcenterqz-position at which the omega scan should be extracted
```

**kwargs: possible keyword arguments:

omrangerange of the omega scan to extractnpointsnumber of points of the omega scan

```
qrangeintegration range perpendicular to scan direction
```

Nintnumber of subscans used for the integration (optionally)

lamwavelength for use in the conversion to angular coordinates

relativedetermines if absolute or relative omega positions are returned (default: True)

boundsflag to specify if the scan bounds should be returned (default: False)

Returns

om,omintomega scan coordinates and intensities (bounds=False)

om,omint,(**qxb,qzb**)omega scan coordinates and intensities + reciprocal space bounds of the extraced scan (bounds=True)

Example

```
>>> omcut, intcut = get_omega_scan(qx,qz,intensity,0.0,5.0,2.0,200)
```

xrayutilities.analysis.line_cuts.**get_qx_scan** (qx, qz, intensity, qzpos, **kwargs) extract qx line scan at position qzpos from a gridded reciprocal space map by taking the closest line of the intensity matrix, or summing up a given range along qz

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qzposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

qmin,qmaxminimum and maximum value of extracted scan axis

boundsflag to specify if the scan bounds of the extracted scan should be returned (default:False)

Returns

qx,qxintqx scan coordinates and intensities (bounds=False)

qx,qxint,(qxb,qyb)qx scan coordinates and intensities + scan bounds for plotting

Example

```
>>> qxcut,qxcut_int = get_qx_scan(qx,qz,inten,5.0,qrange=0.03)
```

xrayutilities.analysis.line_cuts.get_qz_scan(qx, qz, intensity, qxpos, **kwargs)

extract qz line scan at position qxpos from a gridded reciprocal space map by taking the closest line of the intensity matrix, or summing up a given range along qx

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qxposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

qrangeintegration range perpendicular to scan direction

```
qmin,qmaxminimum and maximum value of extracted scan axis
```

```
Returns
```

qz,qzintqz scan coordinates and intensities

Example

```
>>> qzcut,qzcut_int = get_qz_scan(qx,qz,inten,1.5,qrange=0.03)
```

extracts a qz scan from a gridded reciprocal space map with integration along omega (sample rocking angle) or 2theta direction

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

qxposposition at which the line scan should be extracted

**kwargs: possible keyword arguments:

angrangeintegration range in angular direction

qmin,qmaxminimum and maximum value of extracted scan axis

boundsflag to specify if the scan bounds of the extracted scan should be returned (default:False)

intdirintegration direction 'omega': sample rocking angle (default) '2theta': scattering angle

Returns

qz,qzintqz scan coordinates and intensities (bounds=False)

qz,qzint,(qzb,qzb)qz scan coordinates and intensities + scan bounds for plotting

Example

```
>>> qzcut,qzcut_int = get_qz_scan_int(qx,qz,inten,5.0,omrange=0.3)
```

extracts a radial scan from a gridded reciprocal space map

Parameters

qxequidistant array of qx momentum transfer

qzequidistant array of qz momentum transfer

intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)

omcenterom-position at which the radial scan should be extracted

ttcentertt-position at which the radial scan should be extracted

ttrangetwo theta range of the radial scan to extract

npointsnumber of points of the radial scan

**kwargs: possible keyword arguments:

omrangeintegration range perpendicular to scan direction

Nintnumber of subscans used for the integration (optionally)

```
lamwavelength for use in the conversion to angular coordinates
               relative determines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               om,tt,radintomega,two theta scan coordinates and intensities (bounds=False)
               om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space
                   bounds of the extraced scan (bounds=True)
     Example
     >>> omc,ttc,cut_int = get_radial_scan_ang(qx,qz,intensity,32.0,64.0,30.0,800,omrange=0.2)
xrayutilities.analysis.line_cuts.get_radial_scan_bounds_ang(omcenter,
                                                                                    ttrange, npoints,
                                                                                    **kwargs)
     return reciprocal space boundaries of radial scan
     Parameters
               omcenterom-position at which the radial scan should be extracted
               ttcentertt-position at which the radial scan should be extracted
               ttrangetwo theta range of the radial scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range perpendicular to scan direction
               lamwavelength for use in the conversion to angular coordinates
     Returns
               qxrad,qzradreciprocal space boundaries of radial scan
     Example
     >>>
xrayutilities.analysis.line_cuts.get_radial_scan_q(qx, qz, intensity, qxcenter,
                                                                       qzcenter, ttrange, npoints,
                                                                       **kwargs)
     extracts a radial scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               qxcenterqx-position at which the radial scan should be extracted
               qzcenterqz-position at which the radial scan should be extracted
               ttrangetwo theta range of the radial scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range perpendicular to scan direction
```

```
Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               om,tt,radintomega,two theta scan coordinates and intensities (bounds=False)
               om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space
                   bounds of the extraced scan (bounds=True)
     Example
     >>> omc,ttc,cut_int = get_radial_scan_q(qx,qz,intensity,0.0,5.0,1.0,100,omrange=0.01)
xrayutilities.analysis.line_cuts.get_ttheta_scan_ang(qx, qz, intensity, omcenter,
                                                                          ttcenter, ttrange, npoints,
                                                                          **kwargs)
     extracts a twotheta scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               omcenterom-position at which the 2theta scan should be extracted
               ttcentertt-position at which the 2theta scan should be extracted
               ttrangetwo theta range of the scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range in omega direction
               Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
     Returns
               tt,ttinttwo theta scan coordinates and intensities (bounds=False)
               tt,ttint,(qxb,qzb)2theta scan coordinates and intensities + reciprocal space bounds of
                   the extraced scan (bounds=True)
     Example
     >>> ttc,cut_int = get_ttheta_scan_ang(qx,qz,intensity,32.0,64.0,4.0,400)
xrayutilities.analysis.line cuts.qet ttheta scan bounds ang (omcenter,
                                                                                    ttcenter.
                                                                                    ttrange, npoints,
                                                                                    **kwargs)
```

return reciprocal space boundaries of 2theta scan

Parameters

omcenterom-position at which the 2theta scan should be extracted

```
ttrangetwo theta range of the 2theta scan to extract
               npoints number of points of the 2theta scan
      **kwargs: possible keyword arguments:
               omrangeintegration range in omega direction
               lamwavelength for use in the conversion to angular coordinates
     Returns
               qxtt,qzttreciprocal space boundaries of 2theta scan (bounds=False)
               tt,ttint,(qxb,qzb)2theta scan coordinates and intensities + reciprocal space bounds of
                   the extraced scan (bounds=True)
     Example
      >>>
xrayutilities.analysis.line_cuts.get_ttheta_scan_q(qx, qz, intensity, qxcenter,
                                                                        qzcenter, ttrange, npoints,
                                                                        **kwargs)
     extracts a twotheta scan from a gridded reciprocal space map
     Parameters
               qxequidistant array of qx momentum transfer
               qzequidistant array of qz momentum transfer
               intensity2D array of gridded reciprocal space intensity with shape (qx.size,qz.size)
               qxcenterqx-position at which the 2theta scan should be extracted
               qzcenterqz-position at which the 2theta scan should be extracted
               ttrangetwo theta range of the scan to extract
               npointsnumber of points of the radial scan
      **kwargs: possible keyword arguments:
               omrangeintegration range in omega direction
               Nintnumber of subscans used for the integration (optionally)
               lamwavelength for use in the conversion to angular coordinates
               relativedetermines if absolute or relative two theta positions are returned (default=True)
               boundsflag to specify if the scan bounds should be returned (default: False)
      Returns
               tt,ttinttwo theta scan coordinates and intensities (bounds=False)
               om,tt,radint,(qxb,qzb)radial scan coordinates and intensities + reciprocal space
                   bounds of the extraced scan (bounds=True)
     Example
      >>> ttc,cut_int = get_ttheta_scan_q(qx,qz,intensity,0.0,4.0,4.4,440)
xrayutilities.analysis.line_cuts.getindex(x, y, xgrid, ygrid)
      gives the indices of the point x,y in the grid given by xgrid ygrid xgrid,ygrid must be arrays containing
     equidistant points
     Parameters
```

ttcentertt-position at which the 2theta scan should be extracted

```
x,ycoordinates of the point of interest (float)
              xgrid,ygridgrid coordinates in x and y direction (array)
     Returns
              ix,iyindex of the closest gridpoint (lower left) of the point (x,y)
line_cuts3d Module
xrayutilities.analysis.line_cuts3d.get_qx_scan3d(gridder,
                                                                                           qzpos,
                                                                                gypos,
                                                                   **kwargs)
     extract qx line scan at position y,z from a gridded reciprocal space map by taking the closest line of the
     intensity matrix, or summing up a given area around this position
     Parameters
              gridder3d xrayutilities.Gridder3D object containing the data
              qypos,qzposposition at which the line scan should be extracted
      **kwargs: possible keyword arguments:
              grangeintegration range perpendicular to scan direction
              qmin,qmaxminimum and maximum value of extracted scan axis
     Returns
              qx,qxintqx scan coordinates and intensities
     Example
     >>> qxcut,qxcut_int = get_qx_scan3d(gridder,0,0,qrange=0.03)
xrayutilities.analysis.line_cuts3d.get_qy_scan3d(gridder,
                                                                                qxpos,
                                                                                           qzpos,
                                                                   **kwargs)
     extract qy line scan at position x,z from a gridded reciprocal space map by taking the closest line of the
     intensity matrix, or summing up a given area around this position
     Parameters
              gridder3d xrayutilities.Gridder3D object containing the data
              qxpos,qzposposition at which the line scan should be extracted
      **kwargs: possible keyword arguments:
              qrangeintegration range perpendicular to scan direction
              qmin,qmaxminimum and maximum value of extracted scan axis
     Returns
              qy,qyintqy scan coordinates and intensities
     Example
     >>> qycut,qycut_int = get_qy_scan3d(gridder,0,0,qrange=0.03)
xrayutilities.analysis.line_cuts3d.get_qz_scan3d(gridder,
                                                                                qxpos,
                                                                                           qypos,
                                                                   **kwargs)
```

extract qz line scan at position x,y from a gridded reciprocal space map by taking the closest line of the intensity matrix, or summing up a given area around this position

Parameters

gridder3d xrayutilities.Gridder3D object containing the data **qxpos,qypos**position at which the line scan should be extracted

```
**kwargs: possible keyword arguments:
               qrangeintegration range perpendicular to scan direction
               qmin,qmaxminimum and maximum value of extracted scan axis
      Returns
               qz,qzintqz scan coordinates and intensities
      Example
      >>> qzcut,qzcut_int = get_qz_scan3d(gridder,0,0,qrange=0.03)
xrayutilities.analysis.line_cuts3d.getindex3d(x, y, z, xgrid, ygrid, zgrid)
      gives the indices of the point x,y,z in the grid given by xgrid ygrid zgrid xgrid,ygrid,zgrid must be arrays
      containing equidistant points
      Parameters
               x,y,zcoordinates of the point of interest (float)
               xgrid,ygrid,zgridgrid coordinates in x,y,z direction (array)
      Returns
               ix,iy,iz index of the closest gridpoint (lower left) of the point (x,y,z)
misc Module miscellaneous functions helpful in the analysis and experiment
xrayutilities.analysis.misc.getangles(peak, sur, inp)
      calculates the chi and phi angles for a given peak
      Parameter
               peakarray which gives hkl for the peak of interest
               surhkl of the surface
               inpinplane reference peak or direction
      Returns
           [chi,phi] for the given peak on surface sur with inplane direction inp as reference
      Example
           To get the angles for the -224 peak on a 111 surface type[chi,phi]
                                                                                          getangles([-
               2,2,4],[1,1,1],[2,2,4])
sample align Module functions to help with experimental alignment during experiments, especially for
experiments with linear detectors
xrayutilities.analysis.sample aliqn.area detector calib(angle1,
                                                                                             angle2,
                                                                               ccdimages,
                                                                                                 de-
                                                                               taxis, r i, plot=True,
                                                                               cut_off=0.7, start=(0,
                                                                               0, 0, 0), fix=(False,
                                                                               False, False, False),
                                                                               fig=None, wl=None
      function to calibrate the detector parameters of an area detector it determines the detector tilt possible
      rotations and offsets in the detector arm angles
      parameters
               angle1outer detector arm angle
               angle2inner detector arm angle
```

```
ccdimagesimages of the ccd taken at the angles given above detaxisdetector arm rotation axis :default: ['z+','y-']

r_iprimary beam direction [xyz][+-] default 'x+'
```

Keyword_arguments

plotflag to determine if results and intermediate results should be plotted :default: True

cut_offcut off intensity to decide if image is used for the determination or not :default: 0.7 = 70%

startsequence of start values of the fit for parameters, which can not be estimated automatically these are: tiltazimuth,tilt,detector_rotation,outerangle_offset. By default (0,0,0,0) is used.

fixfix parameters of start (default: (False,False,False,False))

figmatplotlib figure used for plotting the error :default: None (creates own figure)

wlwavelength of the experiment in Angstrom (default: config.WAVELENGTH) value does not matter here and does only affect the scaling of the error

```
xrayutilities.analysis.sample_align.area_detector_calib_hkl(sampleang,
```

```
angle1, angle2,
ccdimages, hkls,
experiment, ma-
terial, detaxis,
r i, plot=True,
cut off=0.1.
start = (0, 0, 0,
0, 0, 0, con-
fig'), fix=(False,
False,
          False,
False,
          False,
False,
          False),
fig=None)
```

function to calibrate the detector parameters of an area detector it determines the detector tilt possible rotations and offsets in the detector arm angles

in this variant not only scans through the primary beam but also scans at a set of symmetric reflections can be used for the detector parameter determination. for this not only the detector parameters but in addition the sample orientation and wavelength need to be fit.

parameters

```
sampleangsample rocking angle (needed to align the reflections (same rotation direction as inner detector rotation)) other sample angle are not allowed to be changed during the scans
```

angle1outer detector arm angle

angle2inner detector arm angle

ccdimages images of the ccd taken at the angles given above

hklsarray/list of hkl values for every image

material material used as reference crystal

detaxisdetector arm rotation axis :default: ['z+','y-']

r_iprimary beam direction [xyz][+-] default 'x+'

Keyword_arguments

```
plotflag to determine if results and intermediate results should be plotted :default: True
```

cut_offcut off intensity to decide if image is used for the determination or not :default: 0.7 = 70%

startsequence of start values of the fit for parameters, which can not be estimated automatically these are: tiltazimuth,tilt,detector_rotation,outerangle_offset, stilt,stazimuth, wavelength. By default (0,0,0,0,0,0,config') is used.

fixfix parameters of start (default: (False,Fals

figmatplotlib figure used for plotting the error :default: None (creates own figure)

helper function to determine the Bragg peak position in a reciprocal space map used to obtain the position needed for correction of the data. the determination is done by fitting a two dimensional Gaussian (xrayutilities.math.Gauss2d)

PLEASE ALWAYS CHECK THE RESULT CAREFULLY!

Parameter

om,ttangular coordinates of the measurement (numpy.ndarray) either with size of psd or of psd.shape[0]

psdintensity values needed for fitting

omalignaligned omega value, used as first guess in the fit

ttalignaligned two theta values used as first guess in the fit these values are also used to set the range for the fit: the peak should be within +/-frangeAA^{-1} of those values

exphxrdexperiment class used for the conversion between angular and reciprocal space.

frangedata range used for the fit in both directions (see above for details default:(0.03,0.03) unit: AA^{-1})

plotif True (default) function will plot the result of the fit in comparison with the measurement.

Returns

Omfit,ttfit,params,covariance fitted angular values, and the fit parameters (of the Gaussian) as well as their errors

function to calibrate the detector distance/channel per degrees for a straight linear detector mounted on a detector arm

parameters

```
anglearray of angles in degree of measured detector spectramca_spectracorresponding detector spectra :(shape: (len(angle),Nchannels)
```

**keyargs passed to psd_chdeg function used for the modelling, additional options are:

```
r_iprimary beam direction as vector [xyz][+-]; default: 'y+'
```

detaxisdetector arm rotation axis [xyz][+-] e.g. 'x+'; default: 'x+'

selected options from psd_chdeg:

plotflag to specify if a visualization of the fit should be done

usetiltwhether to use model considering a detector tilt (deviation angle of the pixel direction from orthogonal to the primary beam) (default: True)

Note: Note: see help of psd_chdeg for more options

returns

pixelwidth (at one meter distance), center channel[, detector tilt]

Note: Note: L/pixelwidth*pi/180 ~= channel/degree, with the sample detector distance L

pixelwidth is negative in case the hit channel number decreases upon an increase of the detector angle The function also prints out how a linear detector can be initialized using the results obtained from this calibration. Carefully check the results

function to calculate the miscut direction and miscut angle of a sample by fitting a sinusoidal function to the variation of the aligned omega values of more than two reflections. The function can also be used to fit reflectivity alignment values in various azimuths.

Parameters

phiazimuths in which the reflection was aligned (deg)

aomega aligned omega values (deg)

zeros(optional) angles at which surface is parallel to the beam (deg). For the analysis the angles (aomega-zeros) are used.

omega0if specified the nominal value of the reflection is not included as fit parameter, but is fixed to the specified value. This value is MANDATORY if ONLY TWO AZIMUTHs are given.

plotflag to specify if a visualization of the fit is wanted. :default: True

Returns

[omega0,phi0,miscut]

list with fitted values for

omega0the omega value of the reflection should be close to the nominal one

phi0the azimuth in which the primary beam looks upstairs

miscutamplitude of the sinusoidal variation == miscut angle

```
xrayutilities.analysis.sample_align.psd_chdeg (angles, channels, stdev=None, usetilt=True, plot=True, datap='kx', modelline='r-', modeltilt='b-', fignum=None, mlabel='fit', mtilt-label='fit w/tilt', dlabel='data', figtitle=True)
```

function to determine the channels per degree using a linear fit of the function nchannel = center_ch+chdeg*tan(angles) or the equivalent including a detector tilt

Parameters

angles detector angles for which the position of the beam was measured

channels detector channels where the beam was found

keyword arguments:

```
stdevstandard deviation of the beam position
```

plotflag to specify if a visualization of the fit should be done

usetiltwhether to use model considering a detector tilt (deviation angle of the pixel direction from orthogonal to the primary beam) (default: True)

datapplot format of data points

modellineplot format of modelline

modeltiltplot format of modeltilt

fignumfigure number to use for the plot

mlabellabel of the model w/o tilt to be used in the plot

mtiltlabellabel of the model with tilt to be used in the plot

dlabellabel of the data line to be used in the plot

figtitleboolean to tell if the figure title should show the fit parameters

Returns

(pixelwidth,centerch,tilt)

Pixelwidth the width of one detector channel @ 1m distance, which is negative in case the hit channel number decreases upon an increase of the detector angle.

Centerch center channel of the detector

Tilt tilt of the detector from perpendicular to the beam (will be zero in case of usetilt=False)

Note: Note: L/pixelwidth*pi/180 = channel/degree for large detector distance with the sample detector disctance L

```
xrayutilities.analysis.sample_align.psd_refl_align(primarybeam, angles, chan-
nels, plot=True)
```

function which calculates the angle at which the sample is parallel to the beam from various angles and detector channels from the reflected beam. The function can be used during the half beam alignment with a linear detector.

Parameters

```
primary beam channel number
```

angleslist or numpy.array with angles

channels list or numpy.array with corresponding detector channels

plotflag to specify if a visualization of the fit is wanted :default: True

Returns

omegaangle at which the sample is parallel to the beam

Example

```
>>> psd_refl_align(500,[0,0.1,0.2,0.3],[550,600,640,700])
```

io Package

io Package

edf Module

```
class xrayutilities.io.edf.EDFDirectory (datapath, ext='edf', **keyargs)
```

Bases: object

Parses a directory for EDF files, which can be stored to a HDF5 file for further usage

```
Save2HDF5 (h5, group='', comp=True)
```

Saves the data stored in the EDF files in the specified directory in a HDF5 file as a HDF5 arrays in a subgroup. By default the data is stored in a group given by the foldername - this can be changed by passing the name of a target group or a path to the target group via the "group" keyword argument.

required arguments. :h5: a HDF5 file object

optional keyword arguments: :group: group where to store the data (defaults to pathname if group is empty string) :comp: activate compression - true by default

Bases: object

ReadData()

Read the CCD data into the .data object this function is called by the initialization

Save2HDF5 (h5, group='/', comp=True)

Saves the data stored in the EDF file in a HDF5 file as a HDF5 array. By default the data is stored in the root group of the HDF5 file - this can be changed by passing the name of a target group or a path to the target group via the "group" keyword argument.

required arguments. :h5: a HDF5 file object

optional keyword arguments: :group: group where to store the data (default to the root of the file) :comp: activate compression - true by default

imagereader Module

Bases: object

parse CCD frames in the form of tiffs or binary data (*.bin) to numpy arrays. ignore the header since it seems to contain no useful data

The routine was tested so far withRoperScientific files with 4096x4096 pixels created at Hasylab Hamburg, which save an 16bit integer per point. Perkin Elmer images created at Hasylab Hamburg with 2048x2048 pixels.

readImage (filename)

read image file and correct for dark- and flatfield in case the necessary data are available.

returned data = ((image data)-(darkfield))/flatfield*average(flatfield)

Parameter

filenamefilename of the image to be read. so far only single filenames are supported.

The data might be compressed. supported extensions: .tiff, .bin and .bin.xz

```
class xrayutilities.io.imagereader.PerkinElmer(**keyargs)
```

```
Bases: xrayutilities.io.imagereader.ImageReader
```

parse PerkinElmer CCD frames (*.bin) to numpy arrays Ignore the header since it seems to contain no useful data

The routine was tested only for files with 2048x2048 pixel images created at Hasylab Hamburg which save an 32bit float per point.

```
class xrayutilities.io.imagereader.RoperCCD(**keyargs)
    Bases: xrayutilities.io.imagereader.ImageReader
```

parse RoperScientific CCD frames (*.bin) to numpy arrays Ignore the header since it seems to contain no useful data

The routine was tested only for files with 4096x4096 pixel images created at Hasylab Hamburg which save an 16bit integer per point.

```
panalytical_xml Module Panalytical XML (www.XRDML.com) data file parser
```

based on the native python xml.dom.minidom module. want to keep the number of dependancies as small as possible

```
class xrayutilities.io.panalytical_xml.XRDMLFile (fname)
    Bases: object
```

class to handle XRDML data files. The class is supplied with a file name and uses the XRDMLScan class to parse the xrdMeasurement in the file

```
class xrayutilities.io.panalytical_xml.XRDMLMeasurement (measurement)
    Bases: object
```

class to handle scans in a XRDML datafile

```
xrayutilities.io.panalytical_xml.getOmPixcel(omraw, ttraw)
```

function to reshape the Omega values into a form needed for further treatment with xrayutilities

parses multiple XRDML file and concatenates the results for parsing the xrayutilities.io.XRDMLFile class is used. The function can be used for parsing maps measured with the PIXCel and point detector.

Parameter

filetemplatetemplate string for the file names, can contain a %d which is replaced by the scan number or be a list of filenames

scannrsint or list of scan numbers

pathcommon path to the filenames

roiregion of interest for the PIXCel detector, for other measurements this i not usefull!

Returns

om,tt,psdas flattened numpy arrays

Example

```
>>> om,tt,psd = xrayutilities.io.getxrdml_map("samplename_%d.xrdml",[1,2],path="./data")
```

radicon Module python module for converting radicon data to HDF5

```
xrayutilities.io.radicon.hst2hdf5 (h5, hstfile, nofchannels, h5path='/', hstpath='.')
Converts a HST file to an HDF5 file.
```

Required input arguments:

h5HDF5 object where to store the data

hstfilename of the HST file

nofchannelsnumber of channels

optional input arguments:

h5pathPath in the HDF5 file where to store the data

hstpathpath where the HST file is located (default is the current working directory)

```
xrayutilities.io.radicon.rad2hdf5 (h5, rdcfile, h5path='/', rdcpath='.')
Converts a RDC file to an HDF5 file.
```

```
Required input arguments:
```

h5HDF5 object where to store the data

rdcfilename of the RDC file

optional input arguments:

h5pathPath in the HDF5 file where to store the data (default to root)

rdcpathpath where the RDC file is located (default is the current working directory)

```
xrayutilities.io.radicon.selecthst(et_limit, mca_info, mca_array)
```

Select historgrams form the complete set of recorded MCA data and stores it into a new numpy array. The selection is done due to a exposure time limit. Spectra below this limit are ignored.

required input arguments:

et_limitexposure time limit

mca_infopytables table with the exposure data

mca_arrayarray with all the MCA spectra

return value: a numpy array with the selected mca spectra of shape (hstnr,channels).

rotanode_alignment Module parser for the alignment log file of the rotating anode

```
class xrayutilities.io.rotanode_alignment.RA_Alignment (filename)
    Bases: object
```

class to parse the data file created by the alignment routine (tpalign) at the rotating anode spec installation

this routine does an iterative alignment procedure and saves the center of mass values were it moves after each scan. It iterates between two different peaks and iteratively aligns at each peak between two different motors (om/chi at symmetric peaks, om/phi at asymmetric peaks)

Parse()

parser to read the alignment log and obtain the aligned values at every iteration.

get (key)

keys()

returns a list of keys for which aligned values were parsed

plot (pname)

function to plot the alignment history for a given peak

Parameters

pnamepeakname for which the alignment should be plotted

seifert Module a set of routines to convert Seifert ASCII files to HDF5 in fact there exist two posibilities how the data is stored (depending on the use detector):

- 1. as a simple line scan (using the point detector)
- 2. as a map using the PSD

In the first case the data ist stored

```
class xrayutilities.io.seifert.SeifertHeader
    Bases: object
```

```
save_h5_attribs(obj)
```

```
class xrayutilities.io.seifert.SeifertMultiScan (filename, m_scan, m2, path=None)
    Bases: object
```

```
dump2hdf5 (h5, iname='INT', group='/')
```

Saves the content of a multi-scan file to a HDF5 file. By default the data is stored in the root group of the file. To save data somewhere else the keyword argument "group" must be used.

required arguments:

h5a HDF5 file object

optional keyword arguments:

inamename for the intensity matrix

grouppath to the HDF5 group where to store the data

dump2mlab (fname, *args)

Store the data in a matlab file.

parse()

class xrayutilities.io.seifert.SeifertScan (filename, path=None)

Bases: object

dump2h5 (*h5*, **args*, ***keyargs*)

Save the data stored in the Seifert ASCII file to a HDF5 file.

required input arguments:

h5HDF5 file object

optional arguments:

names to use to store the motors. The first must be the name for the intensity array. The number of names must be equal to the second element of the shape of the data object.

optional keyword arguments:

groupHDF5 group object where to store the data.

dump2mlab (fname, *args)

Save the data from a Seifert scan to a matlab file.

required input arugments:

fnamename of the matlab file

optional position arguments:

names to use to store the motors. The first must be the name for the intensity array. The number of names must be equal to the second element of the shape of the data object.

parse()

```
xrayutilities.io.seifert.getSeifert_map(filetemplate, scannrs=None, path='.', scant-
```

ype='map', Nchannels=1280) parses multiple Seifert *.nja files and concatenates the results. for parsing the xrayutilities.io.SeifertMultiScan class is used. The function can be used for parsing maps measured with the Meteor1D and point detector.

Parameter

filetemplatetemplate string for the file names, can contain a %d which is replaced by the scan number or be a list of filenames

scannrsint or list of scan numbers

pathcommon path to the filenames

scantypetype of datafile: "map": reciprocal space map measured with a regular Seifert job "tsk": MCA spectra measured using the TaskInterpreter

Nchannelsnumber of channels of the MCA (needed for "tsk" measurements)

Returns

om,tt,psdas flattened numpy arrays

Example

```
>>> om,tt,psd = xrayutilities.io.getSeifert_map("samplename_%d.xrdml",[1,2],path="./data")
```

```
xrayutilities.io.seifert.repair_key(key)
```

Repair a key string in the sense that the string is changed in a way that it can be used as a valid Python identifier. For that purpose all blanks within the string will be replaced by _ and leading numbers get an preceeding _.

spec Module a threaded class for observing a SPEC data file

Motivation

SPEC files can become quite large. Therefore, subsequently reading the entire file to extract a single scan is a quite cumbersome procedure. This module is a proof of concept code to write a file observer starting a reread of the file starting from a stored offset (last known scan position)

```
class xrayutilities.io.spec.SPECCmdLine (n, prompt, cmdl, out)
    Bases: object
    Save2HDF5 (h5, **keyargs)
class xrayutilities.io.spec.SPECFile (filename, path='')
    Bases: object
```

This class represents a single SPEC file. The class provides methodes for updateing an already opened file which makes it particular interesting for interactive use.

Parse()

Parses the file from the starting at last_offset and adding found scans to the scan list.

```
Save2HDF5 (h5f, comp=True)
```

Save the entire file in an HDF5 file. For that purpose a group is set up in the root group of the file with the name of the file without extension and leading path. If the method is called after an previous update only the scans not written to the file meanwhile are saved.

required arguments:

h5fa HDF5 file object or its filename

optional keyword arguments:

compactivate compression - true by default

Update()

reread the file and add newly added files. The parsing starts at the data offset of the last scan gathered during the last parsing run.

```
class xrayutilities.io.spec.SPECLog (filename, prompt, path='')
    Bases: object
    Parse()
    Update()
class xrayutilities.io.spec.SPECMCA (nchan, roistart, roistop)
    Bases: object
```

SPECMCA - represents an MCA object in a SPEC file. This class is an abstract class not itended for being used directly. Instead use one of the derived classes SPECMCAFile or SPECMCAInline.

```
class xrayutilities.io.spec.SPECMCAFile
    Bases: xrayutilities.io.spec.SPECMCA
    ReadData()
```

class xrayutilities.io.spec.SPECMCAInline Bases: xrayutilities.io.spec.SPECMCA

ReadData()

class xrayutilities.io.spec.SPECScan(name, scannr, command, date, time, itime, colnames, hoffset, doffset, fid, imopnames, imopvalues,
scan status)

Bases: object

Represents a single SPEC scan.

ClearData()

Delete the data stored in a scan after it is no longer used.

ReadData()

Set the data attribute of the scan class.

```
Save2HDF5 (h5f, group='/', title='', desc='', optattrs={}, comp=True)
```

Save a SPEC scan to an HDF5 file. The method creates a group with the name of the scan and stores the data there as a table object with name "data". By default the scan group is created under the root group of the HDF5 file. The title of the scan group is ususally the scan command. Metadata of the scan are stored as attributes to the scan group. Additional custom attributes to the scan group can be passed as a dictionary via the optattrs keyword argument.

input arguments:

h5fa HDF5 file object or its filename

optional keyword arguments:

groupname or group object of the HDF5 group where to store the data

titlea string with the title for the data, defaults to the name of scan if empty

desca string with the description of the data, defaults to the scan command if empty

optattrsa dictionary with optional attributes to store for the data

compactivate compression - true by default

SetMCAParams (*mca_column_format*, *mca_channels*, *mca_start*, *mca_stop*)

Set the parameters used to save the MCA data to the file. This method calculates the number of lines used to store the MCA data from the number of columns and the

required input aguments:

mca_column_formatnumber of columns used to save the data

mca channels number of MCA channels stored

mca_startfirst channel that is stored

mca stoplast channel that is stored

plot (*args, **keyargs)

Plot scan data to a matplotlib figure. If newfig=True a new figure instance will be created. If logy=True (default is False) the y-axis will be plotted with a logarithmic scale.

Parameters

*args: arguments for the plot: first argument is the name of x-value columnthe following pairs of arguments are the y-value names and plot styles allowed are 3,5,7,... number of arguments

**keyargs:

newfigif True a new figure instance will be created otherwise an existing one will be used

logyif True a semilogy plot will be done

```
xrayutilities.io.spec.geth5_scan(h5f, scans, *args, **kwargs)
```

function to obtain the angular cooridinates as well as intensity values saved in an HDF5 file, which was created from a spec file by the Save2HDF5 method. Especially usefull for reciprocal space map measurements.

further more it is possible to obtain even more positions from the data file if more than two string arguments with its names are given

Parameters

h5ffile object of a HDF5 file opened using pytables or its filename

scansnumber of the scans of the reciprocal space map (int,tuple or list)

*args: names of the motors (optional) (strings) to read reciprocal space maps measured in coplanar diffraction give: :omname: e.g. name of the omega motor (or its equivalent) :ttname: e.g. name of the two theta motor (or its equivalent)

**kwargs (optional):

samplenamestring with the hdf5-group containing the scan data if ommited the first child node of h5f.root will be used

Returns

MAP

or

[ang1,ang2,...],MAP:angular positions of the center channel of the position sensitive detector (numpy.ndarray 1D) together with all the data values as stored in the data file (includes the intensities e.g. MAP['MCA']).

Example

```
>>> [om,tt], MAP = xu.io.geth5_scan(h5file,36,'omega','gamma')
```

spectra Module module to handle spectra data

Bases: object

Represents a SPECTRA data file. The file is read during the Constructor call. This class should work for data stored at beamlines P08 and BW2 at HASYLAB.

Required constructor arguments:

filenamea string with the name of the SPECTRA file

Optional keyword arguments:

mcatmptemplate for the MCA files

mcastart,mcastopstart and stop index for the MCA files, if not given, the class tries to determine the start and stop index automatically.

Read()

Read the data from the file.

 $\textbf{ReadMCA} \ (\)$

```
Save2HDF5 (h5file, name, group='/', description='SPECTRA scan', mcaname='MCA')
```

Saves the scan to an HDF5 file. The scan is saved to a seperate group of name "name". h5file is either a string for the file name or a HDF5 file object. If the mca attribute is not None mca data will be stored to an chunked array of with name mcaname.

required input arguments:

h5filestring or HDF5 file object

namename of the group where to store the data

optional keyword arguments:

grouproot group where to store the data

descriptionstring with a description of the scan

Return value: The method returns None in the case of everything went fine, True otherwise.

class xrayutilities.io.spectra.SPECTRAFileComments

Bases: dict

Class that describes the comments in the header of a SPECTRA file. The different comments are accessible via the comment keys.

 ${\bf class} \; {\tt xrayutilities.io.spectra.SPECTRAFileData}$

Bases: object

append(col)

class xrayutilities.io.spectra.SPECTRAFileDataColumn (index, name, unit, type)

Bases: object

class xrayutilities.io.spectra.SPECTRAFileParameters

Bases: dict

class xrayutilities.io.spectra.Spectra(data_dir)

Bases: object

abs_corr (data, f, **keyargs)

Perform absorber correction. Data can be either a 1 dimensional data (point detector) or a 2D MCA array. In the case of an array the data array should be of shape (N,NChannels) where N is the number of points in the scan an NChannels the number of channels of the MCA. The absorber values are passed to the function as a 1D array of N elements.

By default the absorber values are taken form a global variable stored in the module called _absorver_factors. Despite this, costume values can be passed via optional keyword arguments.

required input arguments:

mcamatrix with the MCA data

ffilter values along the scan

optional keyword arguments:

ffcustome filter factors

return value: Array with the same shape as mca with the corrected MCA data.

```
recarray2hdf5 (h5g, rec, name, desc)
```

Save a record array in an HDF5 file. A pytables table object is used to store the data.

required input arguments:

h5gHDF5 group object or path

recrecord array

namename of the table in the file

descdescription of the table in the file

return value:

taba HDF5 table object

set_abs_factors(ff)

Set the global absorber factors in the module.

spectra2hdf5 (dir, fname, mcatemp, name='', desc='SPECTRA data')

Convert SPECTRA scan data to a HDF5 format.

required input arguments:

dirdirectory where the scan is stored

fnamename of the SPECTRA data file

mcatemptemplate for the MCA file names

optional keyword arguments:

nameoptional name under which to save the data if empty the basename of the filename will be used

descoptional description of the scan

```
xrayutilities.io.spectra.get_spectra_files(dirname)
```

Return a list of spectra files within a directory.

required input arguments:

dirnamename of the directory to search

return values: list with filenames

```
xrayutilities.io.spectra.geth5_spectra_map(h5file, scans, *args, **kwargs)
```

function to obtain the omega and twotheta as well as intensity values for a reciprocal space map saved in an HDF5 file, which was created from a spectra file by the Save2HDF5 method.

further more it is possible to obtain even more positions from the data file if more than two string arguments with its names are given

Parameters

h5ffile object of a HDF5 file opened using pytables

scansnumber of the scans of the reciprocal space map (int,tuple or list)

*args: arbitrary number of motor names (strings)

omnamename of the omega motor (or its equivalent)

ttnamename of the two theta motor (or its equivalent)

**kwargs (optional):

mcaname of the mca data (if available) otherwise None (default: "MCA")

samplenamestring with the hdf5-group containing the scan data if ommited the first child node of h5f.root will be used to determine the sample name

Returns

[ang1,ang2,...],MAP:angular positions of the center channel of the position sensitive detector (numpy.ndarray 1D) together with all the data values as stored in the data file (includes the intensities e.g. MAP['MCA']).

```
xrayutilities.io.spectra.read_data(fname)
```

Read a spectra data file (a file with now MCA data).

required input arguments:

fnamename of the file to read

return values: (data,hdr)

datanumpy record array where the keys are the column names

hdra dictionary with header information

```
xrayutilities.io.spectra.read_mca(fname)
```

Read a single SPECTRA MCA file.

required input arguments:

fnamename of the file to read

return value:

data numpy array witht the MCA data

xrayutilities.io.spectra.read_mca_dir (dirname, filetemp, sort=True)
 Read all MCA files within a directory

xrayutilities.io.spectra.read_mcas(ftemp, cntstart, cntstop)

Read MCA data from a SPECTRA MCA directory. The filename is passed as a generic

materials Package

materials Package

_create_database Module script to create the HDF5 database from the raw data of XOP this file is only needed for administration

_create_database_alt Module script to create the HDF5 database from the raw data of XOP this file is only needed for administration

cif Module

```
class xrayutilities.materials.cif.CIFFile (filename)
    Bases: object
```

class for parsing CIF (Crystallographic Information File) files. The class aims to provide an additional way of creating material classes instead of manual entering of the information the lattice constants and unit cell structure are parsed from the CIF file

Lattice()

returns a lattice object with the structure from the CIF file

Parse()

function to parse a CIF file. The function reads the space group symmetry operations and the basic atom positions as well as the lattice constants and unit cell angles

SymStruct()

function to obtain the list of different atom positions in the unit cell for the different types of atoms. The data are obtained from the data parsed from the CIF file.

database Module module to handle access to the optical parameters database

```
{\bf class} \; {\tt xrayutilities.materials.database.DataBase} \; ({\it fname}) \\ {\bf Bases:} \; {\tt object}
```

Close()

Close an opend database file.

Create (dbname, dbdesc)

Creates a new database. If the database file already exists its content is delete.

required input arguments:

dbnamename of the database

dbdesca short description of the database

CreateMaterial (name, description)

This method creates a new material. If the material group already exists the procedure is aborted.

required input arguments:

```
namea string with the name of the material
```

description a string with a description of the material

GetF0(q)

Obtain the f0 scattering factor component for a particular momentum transfer q.

required input argument:

qsingle float value or numpy array

GetF1 (en)

Return the second, energy dependent, real part of the scattering factor for a certain energy en.

required input arguments:

enfloat or numpy array with the energy

GetF2 (en)

Return the imaginary part of the scattering factor for a certain energy en.

required input arguments:

enfloat or numpy array with the energy

Open (mode='r')

Open an existing database file.

SetF0 (parameters)

Save f0 fit parameters for the set material. The fit parameters are stored in the following order: c,a1,b1,.....,a4,b4

required input argument:

parameters list or numpy array with the fit parameters

SetF1 (*en*, *f1*)

Set f1 tabels values for the active material.

required input arguments:

enlist or numpy array with energy in (eV)

f1list or numpy array with f1 values

SetF2 (*en*, *f*2)

Set f2 tabels values for the active material.

required input arguments:

enlist or numpy array with energy in (eV)

f2list or numpy array with f2 values

SetMaterial (name)

Set a particular material in the database as the actual material. All operations like setting and getting optical constants are done for this particular material.

requiered input arguments:

namestring with the name of the material

SetWeight (weight)

Save weight of the element as float

required input argument:

weight atomic standard weight of the element (float)

```
xrayutilities.materials.database.add_f0_from_intertab(db, itabfile)
```

Read f0 data from international tables of crystallography and add it to the database.

```
xrayutilities.materials.database.add_f0_from_xop(db, xopfile)
     Read f0 data from f0_xop.dat and add it to the database.
xrayutilities.materials.database.add_f1f2_from_ascii_file(db, asciifile, ele-
     Read f1 and f2 data for specific element from ASCII file (3 columns) and save it to the database.
xrayutilities.materials.database.add_f1f2_from_henkedb(db, henkefile)
     Read f1 and f2 data from Henke database and add it to the database.
xrayutilities.materials.database.add_f1f2_from_kissel(db, kisselfile)
     Read f1 and f2 data from Henke database and add it to the database.
xrayutilities.materials.database.add_mass_from_NIST(db, nistfile)
     Read atoms standard mass and save it to the database.
xrayutilities.materials.database.init_material_db(db)
elements Module
lattice Module module handling crystal lattice structures
class xrayutilities.materials.lattice.Atom (name, num)
     Bases: object
     f (q, en='config')
         function to calculate the atomic structure factor F
         Parameter
                 qmomentum transfer
                 enenergy for which F should be calculated, if omitted the value from the xrayutilities
                   configuration is used
         Returns
             f (float)
     f0(q)
     f1 (en='config')
     f2 (en='config')
xrayutilities.materials.lattice.BCCLattice (aa, a)
xrayutilities.materials.lattice.BCTLattice(aa, a, c)
xrayutilities.materials.lattice.BaddeleyiteLattice(aa, ab, a, b, c, beta,
                                                               deg=True)
xrayutilities.materials.lattice.CuMnAsLattice (aa, ab, ac, a, b, c)
xrayutilities.materials.lattice.CubicFm3mBaF2 (aa, ab, a)
xrayutilities.materials.lattice.CubicLattice(a)
     Returns a Lattice object representing a simple cubic lattice.
     required input arguments:
             alattice parameter
     return value: an instance of Lattice class
xrayutilities.materials.lattice.DiamondLattice (aa, a)
xrayutilities.materials.lattice.FCCLattice(aa, a)
xrayutilities.materials.lattice.GeTeRhombohedral (aa, ab, a, ang, x=0.237)
```

```
xrayutilities.materials.lattice.GeneralPrimitiveLattice(a, b, c, alpha, beta,
                                                                      gamma)
xrayutilities.materials.lattice.HCPLattice (aa, a, c)
xrayutilities.materials.lattice.Hexagonal3CLattice(aa, ab, a, c)
xrayutilities.materials.lattice.Hexagonal4HLattice (aa, ab, a, c, u=0.1875,
                                                               v1=0.25, v2=0.4375)
xrayutilities.materials.lattice.Hexagonal6HLattice (aa, ab, a, c)
class xrayutilities.materials.lattice.Lattice(a1, a2, a3, base=None)
     Bases: object
     class Lattice: This object represents a Bravais lattice. A lattice consists of a base
     ApplyStrain (eps)
         Applies a certain strain on a lattice. The result is a change in the base vectors.
         requiered input arguments:
                 epsa 3x3 matrix independent strain components
     GetPoint (*args)
         determine lattice points with indices given in the argument
         >>> xu.materials.Si.lattice.GetPoint(0,0,4)
         array([ 0. , 0. , 21.72416])
         or
         >>> xu.materials.Si.lattice.GetPoint((1,1,1))
         array([ 5.43104, 5.43104, 5.43104])
     ReciprocalLattice()
     UnitCellVolume()
         function to calculate the unit cell volume of a lattice (angstrom^3)
class xrayutilities.materials.lattice.LatticeBase(*args, **keyargs)
     Bases: list
     The LatticeBase class implements a container for a set of points that form the base of a crystal lattice. An
     instance of this class can be treated as a simple container object.
     append (atom, pos, occ=1.0, b=0.0)
         add new Atom to the lattice base
         Parameter
                 atomatom object to be added
                 posposition of the atom
                 occoccupancy (default=1.0)
                 bb-factor of the atom used as \exp(-b*q**2/(4*pi)**2) to reduce the intensity of this
                   atom (only used in case of temp=0 in StructureFactor and chi calculation)
xrayutilities.materials.lattice.NaumanniteLattice (aa, ab, a, b, c)
xrayutilities.materials.lattice.NiAsLattice (aa, ab, a, c, biso=0.0)
xrayutilities.materials.lattice.PerovskiteTypeRhombohedral (aa, ab, ac, a, ang)
xrayutilities.materials.lattice.QuartzLattice(aa, ab, a, b, c)
xrayutilities.materials.lattice.RockSaltLattice(aa, ab, a)
xrayutilities.materials.lattice.RockSalt Cubic Lattice (aa, ab, a)
```

```
xrayutilities.materials.lattice.RutileLattice (aa, ab, a, c, u)
xrayutilities.materials.lattice.TetragonalIndiumLattice (aa, a, c)
xrayutilities.materials.lattice.TetragonalTinLattice (aa, a, c)
xrayutilities.materials.lattice.TrigonalR3mh (aa, a, c)
xrayutilities.materials.lattice.WurtziteLattice (aa, ab, a, c, u=0.375, biso=0.0)
xrayutilities.materials.lattice.ZincBlendeLattice(aa, ab, a)
material Module class module implements a certain material
class xrayutilities.materials.material.Alloy (matA, matB, x)
     Bases: xrayutilities.materials.material.Material
     RelaxationTriangle (hkl, sub, exp)
          function which returns the relaxation trianlge for a Alloy of given composition. Reciprocal space
          coordinates are calculated using the user-supplied experimental class
          Parameter
                  hklMiller Indices
                  subsubstrate material or lattice constant (Instance of Material class or float)
                  expExperiment class from which the Transformation object and ndir are needed
          Returns
                  qy,qzreciprocal space coordinates of the corners of the relaxation triangle
     lattice\_const\_AB(latA, latB, x)
          method to set the composition of the Alloy. x is the atomic fraction of the component B
     x
xrayutilities.materials.material.Cij2Cijkl(cij)
     Converts the elastic constants matrix (tensor of rank 2) to the full rank 4 cijkl tensor.
     required input arguments:
              cij(6,6) cij matrix as a numpy array
     return value:
              cijkl(3,3,3,3) cijkl tensor as numpy array
xrayutilities.materials.material.Cijkl2Cij(cijkl)
     Converts the full rank 4 tensor of the elastic constants to the (6,6) matrix of elastic constants.
     required input arguments:
              cijkl(3,3,3,3) cijkl tensor as numpy array
     return value:
              cij(6,6) cij matrix as a numpy array
class xrayutilities.materials.material.CubicAlloy (matA, matB, x)
     Bases: xrayutilities.materials.material.Alloy
     ContentBasym (q_inp, q_perp, hkl, sur)
          function that determines the content of B in the alloy from the reciprocal space position of an asym-
          metric peak and also sets the content in the current material
          Parameter
```

4.7. xrayutilities 153

q_inpinplane peak position of reflection hkl of the alloy in reciprocal space

q_perpperpendicular peak position of the reflection hkl of the alloy in reciprocal space

hklMiller indices of the measured asymmetric reflection

surMiller indices of the surface (determines the perpendicular direction)

Returns

content,[a_inplane,a_perp,a_bulk_perp(x), eps_inplane, eps_perp] :the content of B in the alloy determined from the input variables and the lattice constants calculated from the reciprocal space positions as well as the strain (eps) of the layer

ContentBsym(q perp, hkl, inpr, asub, relax)

function that determines the content of B in the alloy from the reciprocal space position of a symetric peak. As an additional input the substrates lattice parameter and the degree of relaxation must be given

Parameter

q_perpperpendicular peak position of the reflection hkl of the alloy in reciprocal space

hklMiller indices of the measured symmetric reflection (also defines the surface normal

inprMiller indices of a Bragg peak defining the inplane reference direction

asubsubstrate lattice constant

relaxdegree of relaxation (needed to obtain the content from symmetric reciprocal space position)

Returns

content the content of B in the alloy determined from the input variables

```
xrayutilities.materials.material.CubicElasticTensor(c11, c12, c44)
```

Assemble the 6x6 matrix of elastic constants for a cubic material from the three independent components of a cubic crystal

Parameter

c11,c12,c44independent components of the elastic tensor of cubic materials

Returns

6x6 materix with elastic constants

```
xrayutilities.materials.material.GeneralUC(a=4,\ b=4,\ c=4,\ alpha=90,\ beta=90,\ gamma=90,\ name='General')
```

general material with primitive unit cell but possibility for different a,b,c and alpha,beta,gamma

Parameters

a,b,cunit cell extenstions (Angstrom)

alphaangle between unit cell vectors b,c

betaangle between unit cell vectors a,c

gammaangle between unit cell vectors a,b

returns a Material object with the specified properties

```
xrayutilities.materials.material.HexagonalElasticTensor(c11, c12, c13, c33,
```

Assemble the 6x6 matrix of elastic constants for a hexagonal material from the five independent components of a hexagonal crystal

Parameter

```
c11,c12,c13,c33,c44independent components of the elastic tensor of a hexagonal material
```

Returns

6x6 materix with elastic constants

```
class xrayutilities.materials.material.Material (name, lat, cij=None, thetaDe-bye=None)
```

Bases: object

ApplyStrain (strain, **keyargs)

В

GetMismatch (mat)

Calculate the mismatch strain between the material and a second material

Q (*hkl)

Return the Q-space position for a certain material.

required input arguments:

hkllist or numpy array with the Miller indices (or Q(h,k,l) is also possible)

StructureFactor (q, en='config', temp=0)

caluclates the structure factor of a material for a certain momentum transfer and energy at a certain temperature of the material

Parameter

qvectorial momentum transfer (vectors as list,tuple or numpy array are valid)

enenergy in eV, if omitted the value from the xrayutilities configuration is used

temptemperature used for Debye-Waller-factor calculation

Returns

the complex structure factor

StructureFactorForEnergy (q0, en, temp=0)

caluclates the structure factor of a material for a certain momentum transfer and a bunch of energies

Parameter

q0vectorial momentum transfer (vectors as list,tuple or numpy array are valid)

enlist, tuple or array of energy values in eV

temptemperature used for Debye-Waller-factor calculation

Returns

complex valued structure factor array

StructureFactorForQ $(q, en\theta = 'config', temp = \theta)$

caluclates the structure factor of a material for a bunch of momentum transfers and a certain energy

Parameter

```
qvectorial momentum transfers; list of vectores (list, tuple or array) of length 3 e.g.: (Si.Q(0,0,4),Si.Q(0,0,4.1),...) or numpy.array([Si.Q(0,0,4),Si.Q(0,0,4.1)])
```

en0energy value in eV, if omitted the value from the xrayutilities configuration is used

temptemperature used for Debye-Waller-factor calculation

Returns

complex valued structure factor array

a1

```
a2
a3
b1
b2
b3
beta(en='config')
     function to calculate the imaginary part of the deviation of the refractive index from 1 (n=1-
     delta+i*beta)
     Parameter
              enx-ray energy eV, if omitted the value from the xrayutilities configuration is used
     Returns
          beta (float)
chi0 (en='config')
     calculates the complex chi_0 values often needed in simulations. They are closely related to delta and
     beta (n = 1 + chi_r0/2 + i*chi_i0/2 \text{ vs. } n = 1 - delta + i*beta)
chih (q, en='config', temp=0, polarization='S')
     calculates the complex polarizability of a material for a certain momentum transfer and energy
     Parameter
              qmomentum transfer in (1/A)
              enxray energy in eV, if omitted the value from the xrayutilities configuration is used
              temptemperature used for Debye-Waller-factor calculation
              polarizationeither 'S' (default) sigma or 'P' pi polarization
     Returns
          (abs(chih_real),abs(chih_imag)) complex polarizability
critical_angle (en='config', deg=True)
     calculate critical angle for total external reflection
     Parameter
              enenergy of the x-rays, if omitted the value from the xrayutilities configuration is
                 used
              degreturn angle in degree if True otherwise radians (default:True)
     Returns
          Angle of total external reflection
dTheta (Q, en='config')
     function to calculate the refractive peak shift
     Parameter
              Qmomentum transfer (1/A)
              enx-ray energy (eV), if omitted the value from the xrayutilities configuration is used
     Returns
              deltaThetapeak shift in degree
delta (en='config')
     function to calculate the real part of the deviation of the refractive index from 1 (n=1-delta+i*beta)
     Parameter
```

```
enx-ray energy eV, if omitted the value from the xrayutilities configuration is used
          Returns
              delta (float)
     distances()
          function to obtain distances of atoms in the crystal up to the unit cell size (largest value of a,b,c is the
          cut-off)
          returns a list of tuples with distance d and number of occurence n [(d1,n1),(d2,n2),...]
          Note: Note: if the base of the material is empty the list will be empty
      idx_refraction(en='config')
          function to calculate the complex index of refraction of a material in the x-ray range
          Parameter
                   enenergy of the x-rays, if omitted the value from the xrayutilities configuration is
                     used
          Returns
              n (complex)
     lam
     mu
     nu
xrayutilities.materials.material.PseudomorphicMaterial(submat, layermat)
     This function returns a material whos lattice is pseudomorphic on a particular substrate material. This
     function works meanwhile only for cubic materials on (001) substrates
     required input arguments:
              submatsubstrate material
              layermatbulk material of the layer
     return value: An instance of Material holding the new pseudomorphically strained material.
xrayutilities.materials.material.index_map_ij2ijkl(ij)
xrayutilities.materials.material.index_map_ijkl2ij(i, j)
predefined_materials Module
class xrayutilities.materials.predefined_materials.SiGe (x)
     Bases: xrayutilities.materials.material.CubicAlloy
     lattice_const_AB (latA, latB, x)
          method to calculate the lattice parameter of the SiGe alloy with composition Si_{1-x}Ge_x
     x
math Package
math Package
```

fit Module module with a function wrapper to scipy.optimize.leastsq for fitting of a 2D function to a peak or a 1D Gauss fit with the odr package

xrayutilities.math.fit.**fit_peak2d**(*x*, *y*, *data*, *start*, *drange*, *fit_function*, *maxfev*=2000) fit a two dimensional function to a two dimensional data set e.g. a reciprocal space map

Parameters

x,ydata coordinates (do NOT need to be regularly spaced)

datadata set used for fitting (e.g. intensity at the data coords)

startset of starting parameters for the fit used as first parameter of function fit_function

drangelimits for the data ranges used in the fitting algorithm e.g. it is clever to use only a small region around the peak which should be fitted: [xmin,xmax,ymin,ymax]

fit_function function which should be fitted must accept the parameters (x,y,*params)

Returns

(fitparam,cov)the set of fitted parameters and covariance matrix

xrayutilities.math.fit.gauss_fit (xdata, ydata, iparams=[], maxit=200)

Gauss fit function using odr-pack wrapper in scipy similar to :https://github.com/tiagopereira/python_tips/wiki/Scipy%3A-curve-fitting

Parameters

xdataxcoordinates of the data to be fitted

ydataycoordinates of the data which should be fit

keyword parameters:

iparamsinitial paramters for the fit (determined automatically if nothing is given **maxit**maximal iteration number of the fit

Returns

params,sd_params,itlim

the Gauss parameters as defined in function Gauss1d(x, *param) and their errors of the fit, as well as a boolean flag which is false in the case of a successful fit

```
xrayutilities.math.fit.multGaussFit(*args, **kwargs)
```

convenience function to keep API stable see multPeakFit for documentation

```
xrayutilities.math.fit.multGaussPlot(*args, **kwargs)
```

convenience function to keep API stable see multPeakPlot for documentation

xrayutilities.math.fit.multPeakFit(x, data, peakpos, peakwidth, dranges=None, peaktype='Gaussian')

function to fit multiple Gaussian/Lorentzian peaks with linear background to a set of data

Parameters

xx-coordinate of the data

datadata array with same length as x

peakposinitial parameters for the peak positions

peakwidthinitial values for the peak width

drangeslist of tuples with (min,max) value of the data ranges to use. does not need to have the same number of entries as peakpos

peaktypetype of peaks to be used: can be either 'Gaussian' or 'Lorentzian'

Returns

```
pos, sigma, amp, background
```

Pos list of peak positions derived by the fit

Sigma list of peak width derived by the fit

Amp list of amplitudes of the peaks derived by the fit

Background array of background values at positions x

function to plot multiple Gaussian/Lorentz peaks with background values given by an array

Parameters

xx-coordinate of the data

fposlist of positions of the peaks

fwidthlist of width of the peaks

famplist of amplitudes of the peaks

backgroundarray with background values

drangeslist of tuples with (min,max) value of the data ranges to use. does not need to have the same number of entries as fpos

peaktypetype of peaks to be used: can be either 'Gaussian' or 'Lorentzian'

figmatplotlib figure number or name

fact factor to use as multiplicator in the plot

functions Module module with several common function needed in xray data analysis

```
xrayutilities.math.functions.Debye1(x)
```

function to calculate the first Debye function as needed for the calculation of the thermal Debye-Waller-factor by numerical integration

for definition see: :http://en.wikipedia.org/wiki/Debye_function

 $D1(x) = (1/x) int_0^x t/(exp(t)-1) dt$

Parameters

xargument of the Debye function (float)

Returns

D1(**x**)float value of the Debye function

xrayutilities.math.functions.**Gauss1d**(x, *p)

function to calculate a general one dimensional Gaussian

Parameters

plist of parameters of the Gaussian [XCEN,SIGMA,AMP,BACKGROUND] for information: SIGMA = FWHM / (2*sqrt(2*log(2)))

xcoordinate(s) where the function should be evaluated

Returns

the value of the Gaussian described by the parameters p at position x

xrayutilities.math.functions.**Gauss1d_der_p** (x, *p)

function to calculate the derivative of a Gaussian with respect the parameters p

for parameter description see Gauss1d

```
xrayutilities.math.functions.Gauss1d_der_x (x, *p)
     function to calculate the derivative of a Gaussian with respect to x
     for parameter description see Gauss1d
xrayutilities.math.functions.Gauss2d(x, y, *p)
     function to calculate a general two dimensional Gaussian
     Parameters
              plist of parameters of the Gauss-function [XCEN, YCEN, SIGMAX, SIGMAY, AMP, BACKGROUND, ANGLE]
                  SIGMA = FWHM / (2*sqrt(2*log(2))) ANGLE = rotation of the X,Y direction of
                  the Gaussian in radians
              x,vcoordinate(s) where the function should be evaluated
     Returns
     the value of the Gaussian described by the parameters p at position (x,y)
xrayutilities.math.functions.Gauss3d (x, y, z, *p)
     function to calculate a general three dimensional Gaussian
     Parameters
              plist of parameters of the Gauss-function [XCEN,YCEN,ZCEN,SIGMAX,SIGMAY,SIGMAZ,AMP,BACKGROUN
                  SIGMA = FWHM / (2*sqrt(2*log(2)))
              x,y,zcoordinate(s) where the function should be evaluated
     Returns
     the value of the Gaussian described by the parameters p at positions (x,y,z)
xrayutilities.math.functions.Lorentz1d(x, *p)
     function to calculate a general one dimensional Lorentzian
     Parameters
              plist of parameters of the Lorentz-function [XCEN,FWHM,AMP,BACKGROUND]
              x,ycoordinate(s) where the function should be evaluated
     Returns
     the value of the Lorentian described by the parameters p at position (x,y)
xrayutilities.math.functions.Lorentz1d_der_p (x, *p)
     function to calculate the derivative of a Gaussian with respect the parameters p
     for parameter description see Lorentz1d
xrayutilities.math.functions.Lorentz1d_der_\mathbf{x}(x, *p)
     function to calculate the derivative of a Gaussian with respect to x
     for parameter description see Lorentz1d
xrayutilities.math.functions.Lorentz2d(x, y, *p)
     function to calculate a general two dimensional Lorentzian
     Parameters
              plist of parameters of the Lorentz-function [XCEN,YCEN,FWHMX,FWHMY,AMP,BACKGROUND,ANGLE]
                  ANGLE = rotation of the X,Y direction of the Lorentzian in radians
              x,ycoordinate(s) where the function should be evaluated
     Returns
     the value of the Lorentian described by the parameters p at position (x,y)
```

```
xrayutilities.math.functions.PseudoVoigt1d (x, *p)
```

function to calculate a pseudo Voigt function as linear combination of a Gauss and Lorentz peak

Parameters

plist of parameters of the Lorentz-function [XCEN,FWHM,AMP,BACKGROUND,ETA] :ETA: 0 ...1 0 means pure Gauss and 1 means pure Lorentz

x,ycoordinate(s) where the function should be evaluated

Returns

the value of the PseudoVoigt described by the parameters p at position (x,y)

```
xrayutilities.math.functions.TwoGauss2d (x, y, *p)
```

function to calculate two general two dimensional Gaussians

Parameters

```
plist of parameters of the Gauss-function [XCEN1,YCEN1,SIGMAX1,SIGMAY1,AMP1,ANGLE1,XCEN2,YCEN SIGMA = FWHM / (2*sqrt(2*log(2))) ANGLE = rotation of the X,Y direction of the Gaussian in radians
```

x,ycoordinate(s) where the function should be evaluated

Return

the value of the Gaussian described by the parameters p at position (x,y)

```
xrayutilities.math.functions.kill_spike(data, threshold=2.0)
```

function to smooth **single** data points which differ from the average of the neighboring data points by more than the threshold factor. Such spikes will be replaced by the mean value of the next neighbors.

Warning: Use this function carefully not to manipulate your data!

Parameters

data1d numpy array with experimental data

threshold factor to identify strange data points

Returns

1d data-array with spikes removed

```
xrayutilities.math.functions.smooth (x, n)
```

function to smooth an array of data by averaging N adjacent data points

Parameters

x1D data array

nnumber of data points to average

Returns

xsmoothsmoothed array with same length as x

transforms Module

```
{\bf class} \; {\tt xrayutilities.math.transforms.AxisToZ} \; ({\it newzaxis})
```

```
Bases: xrayutilities.math.transforms.CoordinateTransform
```

Creates a coordinate transformation to move a certain axis to the z-axis. The rotation is done along the great circle. The x-axis of the new coordinate frame is created to be normal to the new and original z-axis. The new y-axis is create in order to obtain a right handed coordinate system.

```
\verb|xrayutilities.math.transforms.Cij2Cijkl| (cij) \\
```

Converts the elastic constants matrix (tensor of rank 2) to the full rank 4 cijkl tensor.

required input arguments:

```
cij(6,6) cij matrix as a numpy array
     return value:
              cijkl(3,3,3,3) cijkl tensor as numpy array
xrayutilities.math.transforms.Cijkl2Cij(cijkl)
     Converts the full rank 4 tensor of the elastic constants to the (6,6) matrix of elastic constants.
     required input arguments:
              cijkl(3,3,3,3) cijkl tensor as numpy array
     return value:
              cij(6,6) cij matrix as a numpy array
class xrayutilities.math.transforms.CoordinateTransform(v1, v2, v3)
     Bases: xrayutilities.math.transforms.Transform
     Create a Transformation object which transforms a point into a new coordinate frame. The new frame is
     determined by the three vectors v1/norm(v1), v2/norm(v2) and v3/norm(v3), which need to be orthogonal!
class xrayutilities.math.transforms.Transform(matrix)
     Bases: object
     inverse(*args)
          performs inverse transformation a vector, matrix or tensor of rank 4
               *args: object to transform, list or numpy array of shape(n,) (n,n), (n,n,n,n) where n is the
                  rank of the transformation matrix
xrayutilities.math.transforms.XRotation(alpha, deg=True)
     Returns a transform that represents a rotation about the x-axis by an angle alpha. If deg=True the angle is
     assumed to be in degree, otherwise the function expects radiants.
xrayutilities.math.transforms.YRotation(alpha, deg=True)
     Returns a transform that represents a rotation about the y-axis by an angle alpha. If deg=True the angle is
     assumed to be in degree, otherwise the function expects radiants.
xrayutilities.math.transforms.ZRotation(alpha, deg=True)
     Returns a transform that represents a rotation about the z-axis by an angle alpha. If deg=True the angle is
     assumed to be in degree, otherwise the function expects radiants.
xrayutilities.math.transforms.index_map_ij2ijkl(ij)
xrayutilities.math.transforms.index_map_ijkl2ij(i, j)
xrayutilities.math.transforms.mycross(vec, mat)
     function implements the cross-product of a vector with each column of a matrix
xrayutilities.math.transforms.rotarb(vec, axis, ang, deg=True)
     function implements the rotation around an arbitrary axis by an angle ang positive rotation is anti-clockwise
     when looking from positive end of axis vector
     Parameter
              vecnumpy.array or list of length 3
              axisnumpy.array or list of length 3
              angrotation angle in degree (deg=True) or in rad (deg=False)
              degboolean which determines the input format of ang (default: True)
     Returns
              rotvecrotated vector as numpy.array
     Example
```

```
>>> rotarb([1,0,0],[0,0,1],90)
     array([ 6.12323400e-17, 1.00000000e+00,
                                                           0.00000000e+001)
xrayutilities.math.transforms.tensorprod(vec1, vec2)
     function implements an elementwise multiplication of two vectors
vector Module module with vector operations, mostly numpy functionality is used for the vector operation
itself, however custom error checking is done to ensure vectors of length 3.
xrayutilities.math.vector.VecAngle(v1, v2, deg=False)
     calculate the angle between two vectors.
                                                        The following formula is used v1.v2 =
     norm(v1)*norm(v2)*cos(alpha)
     alpha = acos((v1.v2)/(norm(v1)*norm(v2)))
     required input arguments:
              v1vector as numpy array or list
              v2vector as numpy array or list
     optional keyword arguments:
              deg(default: false) return result in degree otherwise in radiants
     return value: float value with the angle inclined by the two vectors
xrayutilities.math.vector.VecDot (v1, v2)
     Calculate the vector dot product.
     required input arguments:
              v1vector as numpy array or list
              v2vector as numpy array or list
     return value:float value
xrayutilities.math.vector.VecNorm(v)
     Calculate the norm of a vector.
     required input arguments:
              vvector as list or numpy array
     return value:float holding the vector norm
xrayutilities.math.vector.VecUnit(v)
     Calculate the unit vector of v.
     required input arguments:
              vvector as list or numpy array
     return value: numpy array with the unit vector
xrayutilities.math.vector.getSyntax(vec)
     returns vector direction in the syntax 'x+' 'z-' or equivalents therefore works only for principle vectors of
     the coordinate system like e.g. [1,0,0] or [0,2,0]
     Parameters
              string[xyz][+-]
     Returns
          vector along the given direction as numpy array
```

```
xrayutilities.math.vector.getVector(string)
    returns unit vector along a rotation axis given in the syntax 'x+' 'z-' or equivalents
    Parameters
    string[xyz][+-]
    Returns
```

vector along the given direction as numpy array

CHAPTER

FIVE

INDICES AND TABLES

- genindex
- modindex
- search

PYTHON MODULE INDEX

```
Χ
                                         xrayutilities.utilities_noconf, 126
xrayutilities,9
xrayutilities.__init__,113
xrayutilities.analysis, 127
xrayutilities.analysis.line_cuts, 127
xrayutilities.analysis.line_cuts3d,
      134
xrayutilities.analysis.misc, 135
xrayutilities.analysis.sample align,
      135
xrayutilities.config, 113
xrayutilities.exception, 113
xrayutilities.experiment, 114
xrayutilities.gridder, 123
xrayutilities.gridder2d, 124
xrayutilities.gridder3d, 124
xrayutilities.io, 139
xrayutilities.io.edf, 140
xrayutilities.io.imagereader, 140
xrayutilities.io.panalytical_xml, 141
xrayutilities.io.radicon, 141
xrayutilities.io.rotanode_alignment,
      142
xrayutilities.io.seifert, 142
xrayutilities.io.spec, 144
xrayutilities.io.spectra, 146
xrayutilities.materials, 149
xrayutilities.materials._create_database,
xrayutilities.materials._create_database_alt,
       149
xrayutilities.materials.cif, 149
xrayutilities.materials.database, 149
xrayutilities.materials.elements, 151
xrayutilities.materials.lattice, 151
xrayutilities.materials.material, 153
xrayutilities.materials.predefined_materials,
      157
xrayutilities.math, 157
xrayutilities.math.fit, 158
xrayutilities.math.functions, 159
xrayutilities.math.transforms, 161
xrayutilities.math.vector, 163
xrayutilities.normalize, 124
xrayutilities.utilities, 126
```

INDEX

A	area() (xrayutilities.experiment.QConversion method),
a1 (xrayutilities.materials.material.Material attribute), 67, 105, 155	30, 120 area_detector_calib() (in module xrayutili-
a2 (xrayutilities.materials.material.Material attribute), 67, 105, 155	ties.analysis.sample_align), 46, 84, 135 area_detector_calib_hkl() (in module xrayutili- ties.analysis.sample_align), 47, 85, 136
a3 (xrayutilities.materials.material.Material attribute), 67, 105, 156	Atom (class in xrayutilities.materials.lattice), 62, 100,
abs_corr() (xrayutilities.io.spectra.Spectra method), 58, 96, 147	151 avmon (xrayutilities.normalize.IntensityNormalizer at-
absfun (xrayutilities.normalize.IntensityNormalizer attribute), 35, 124	tribute), 35, 125 axis() (in module xrayutilities.gridder), 34, 123
add_f0_from_intertab() (in module xrayutilities.materials.database), 62, 99, 150	AxisToZ (class in xrayutilities.math.transforms), 73, 111, 161
add_f0_from_xop() (in module xrayutilities.materials.database), 62, 100, 150	В
add_f1f2_from_ascii_file() (in module xrayutilities.materials.database), 62, 100, 151	B (xrayutilities.materials.material.Material attribute), 66, 104, 155
add_f1f2_from_henkedb() (in module xrayutilities.materials.database), 62, 100, 151	b1 (xrayutilities.materials.material.Material attribute), 67, 105, 156
add_f1f2_from_kissel() (in module xrayutilities.materials.database), 62, 100, 151	b2 (xrayutilities.materials.material.Material attribute), 67, 105, 156
add_mass_from_NIST() (in module xrayutilities.materials.database), 62, 100, 151	b3 (xrayutilities.materials.material.Material attribute), 67, 105, 156
Alloy (class in xrayutilities.materials.material), 64, 102,	BaddeleyiteLattice() (in module xrayutilities.materials.lattice), 63, 100, 151
Ang2HKL() (xrayutilities.experiment.Experiment method), 24, 114	BCCLattice() (in module xrayutilities.materials.lattice), 63, 100, 151
Ang2Q() (xrayutilities.experiment.GID method), 25, 115	BCTLattice() (in module xrayutilities.materials.lattice), 63, 100, 151
Ang2Q() (xrayutilities.experiment.GID_ID10B method), 26, 116	beta() (xrayutilities.materials.material.Material method), 67, 105, 156
Ang2Q() (xrayutilities.experiment.GISAXS method),	blockAverage1D() (in module xrayutilities.normalize),
27, 116 Ang2Q() (xrayutilities.experiment.HXRD method), 28,	36, 125 blockAverage2D() (in module xrayutilities.normalize),
Ang2Q() (xrayutilities.experiment.NonCOP method),	36, 125 blockAveragePSD() (in module xrayutilities.normalize), 36, 125
29, 118 append() (xrayutilities.io.spectra.SPECTRAFileData method), 58, 96, 147	C
append() (xrayutilities.materials.lattice.LatticeBase method), 64, 101, 152	check_array() (in module xrayutilities.gridder), 34, 123 chi0() (xrayutilities.materials.material.Material
ApplyStrain() (xrayutilities.materials.lattice.Lattice	method), 67, 105, 156
method), 63, 101, 152 ApplyStrain() (xrayutilities.materials.material.Material	chih() (xrayutilities.materials.material.Material method), 67, 105, 156
method), 66, 104, 155	CIFFile (class in xrayutilities.materials.cif), 60, 98, 149

Cij2Cijkl() (in module xrayutilities.materials.material), 65, 102, 153	det (xrayutilities.normalize.IntensityNormalizer attribute), 35, 125
Cij2Cijkl() (in module xrayutilities.math.transforms), 73, 111, 161	detectorAxis (xrayutilities.experiment.QConversion attribute), 31, 120
Cijkl2Cij() (in module xrayutilities.materials.material), 65, 102, 153	DiamondLattice() (in module xrayutilities.materials.lattice), 63, 100, 151
Cijkl2Cij() (in module xrayutilities.math.transforms), 73, 111, 162	distances() (xrayutilities.materials.material.Material method), 68, 106, 157
Clear() (xrayutilities.gridder.Gridder1D method), 34,	dTheta() (xrayutilities.materials.material.Material method), 68, 105, 156
Clear() (xrayutilities.gridder2d.Gridder2D method), 34,	dump2h5() (xrayutilities.io.seifert.SeifertScan method), 54, 92, 143
ClearData() (xrayutilities.io.spec.SPECScan method), 56, 94, 145	dump2hdf5() (xrayutilities.io.seifert.SeifertMultiScan method), 54, 91, 142
Close() (xrayutilities.materials.database.DataBase method), 61, 98, 149	dump2mlab() (xrayutilities.io.seifert.SeifertMultiScan method), 54, 92, 143
ContentBasym() (xrayutili-	dump2mlab() (xrayutilities.io.seifert.SeifertScan
ties.materials.material.CubicAlloy method), 65, 102, 153	method), 54, 92, 143
ContentBsym() (xrayutili-	E
ties.materials.material.CubicAlloy method), 65, 103, 154	EDFDirectory (class in xrayutilities.io.edf), 51, 88, 140 EDFFile (class in xrayutilities.io.edf), 51, 88, 140
Convolute() (xrayutilities.experiment.Powder method), 30, 119	energy (xrayutilities.experiment.Experiment attribute), 25, 114
CoordinateTransform (class in xrayutilities.math.transforms), 73, 111, 162	energy (xrayutilities.experiment.QConversion attribute), 31, 120
Create() (xrayutilities.materials.database.DataBase method), 61, 98, 149	energy() (in module xrayutilities.utilities_noconf), 37, 126
CreateMaterial() (xrayutili-	Experiment (class in xrayutilities.experiment), 24, 114
ties.materials.database.DataBase method), 61, 98, 149	F
critical_angle() (xrayutili- ties.materials.material.Material method),	f() (xrayutilities.materials.lattice.Atom method), 62, 100, 151
68, 105, 156 CubicAlloy (class in xrayutilities.materials.material),	f0() (xrayutilities.materials.lattice.Atom method), 63,
65, 102, 153 CubicElasticTensor() (in module xrayutili-	100, 151 f1() (xrayutilities.materials.lattice.Atom method), 63,
ties.materials.material), 66, 103, 154	100, 151 f2() (xrayutilities.materials.lattice.Atom method), 63,
CubicFm3mBaF2() (in module xrayutilities.materials.lattice), 63, 100, 151	100, 151 FCCLattice() (in module xrayutilities.materials.lattice),
CubicLattice() (in module xrayutilities.materials.lattice), 63, 100, 151	63, 101, 151
CuMnAsLattice() (in module xrayutilities.materials.lattice), 63, 100, 151	fit_bragg_peak() (in module xrayutilities.analysis.sample_align), 48, 85, 137
	fit_peak2d() (in module xrayutilities.math.fit), 69, 107, 158
D	flatfield (xrayutilities.normalize.IntensityNormalizer
darkfield (xrayutilities.normalize.IntensityNormalizer attribute), 35, 125	attribute), 36, 125 fwhm_exp() (in module xrayutili-
data (xrayutilities.gridder.Gridder1D attribute), 34, 123	ties.analysis.line_cuts), 38, 75, 127
data (xrayutilities.gridder2d.Gridder2D attribute), 35, 124	G
DataBase (class in xrayutilities.materials.database), 61, 98, 149	Gauss1d() (in module xrayutilities.math.functions), 71,
Debye1() (in module xrayutilities.math.functions), 71, 108, 159	Gauss1d_der_p() (in module xrayutili-
delta() (in module xrayutilities.gridder), 34, 123 delta() (xrayutilities.materials.material.Material	ties.math.functions), 71, 109, 159 Gauss1d_der_x() (in module xrayutilities.math.functions), 71, 109, 159
method), 68, 106, 156	105.11um.rumenonoj, /1, 107, 137

170 Index

Gauss2d() (in module xrayutilities.math.functions), 71, getindex() (in module xrayutilities.analysis.line_cuts), 109, 160 44, 82, 133 Gauss3d() (in module xrayutilities.math.functions), 71, getindex3d() (in module xrayutili-109, 160 ties.analysis.line_cuts3d), 46, 83, 135 gauss_fit() (in module xrayutilities.math.fit), 69, 107, GetMismatch() (xrayutili-158 ties.materials.material.Material method), GeneralPrimitiveLattice() 66, 104, 155 (in module xrayutilities.materials.lattice), 63, 101, 151 getOmPixcel() (in module xrayutilities.io.panalytical xml), 52, 90, 141 GeneralUC() (in module xrayutilities.materials.material), 66, 103, 154 GetPoint() (xrayutilities.materials.lattice.Lattice get() (xrayutilities.io.rotanode_alignment.RA_Alignment method), 63, 101, 152 getSeifert_map() (in module xrayutilities.io.seifert), 54, method), 53, 91, 142 92, 143 get_omega_scan_ang() (in module xrayutilities.analysis.line_cuts), 38, 76, 127 getSyntax() (in module xrayutilities.math.vector), 75, get_omega_scan_bounds_ang() (in module xrayutili-113, 163 ties.analysis.line_cuts), 39, 76, 128 getVector() (in module xrayutilities.math.vector), 75, get_omega_scan_q() (in module xrayutili-113, 163 xrayutilities.analysis.line_cuts), 39, 77, 128 getxrdml_map() module (in ties.io.panalytical_xml), 52, 90, 141 get_qx_scan() (in module xrayutilities.analysis.line_cuts), 40, 77, 129 GID (class in xrayutilities.experiment), 25, 114 get_qx_scan3d() (in module xrayutili-GID_ID10B (class in xrayutilities.experiment), 26, 115 ties.analysis.line_cuts3d), 45, 82, 134 GISAXS (class in xrayutilities.experiment), 27, 116 get_qy_scan3d() Gridder (class in xrayutilities.gridder), 34, 123 (in module xrayutilities.analysis.line_cuts3d), 45, 83, 134 Gridder1D (class in xrayutilities.gridder), 34, 123 (in module xrayutili-Gridder2D (class in xrayutilities.gridder2d), 34, 124 get_qz_scan() Gridder3D (class in xrayutilities.gridder3d), 35, 124 ties.analysis.line_cuts), 40, 78, 129 get_qz_scan3d() (in module xrayutili-Н ties.analysis.line cuts3d), 45, 83, 134 get_qz_scan_int() (in module xrayutili-HCPLattice() (in module xrayutilities.materials.lattice), ties.analysis.line cuts), 41, 78, 130 63, 101, 152 get_radial_scan_ang() (in module xrayutili-Hexagonal3CLattice() module xrayutili-(in ties.analysis.line_cuts), 41, 79, 130 ties.materials.lattice), 63, 101, 152 get_radial_scan_bounds_ang() (in module xrayutili-Hexagonal4HLattice() module xrayutili-(in ties.analysis.line_cuts), 42, 79, 131 ties.materials.lattice), 63, 101, 152 get_radial_scan_q() (in module xrayutili-Hexagonal6HLattice() (in module xrayutilities.analysis.line_cuts), 42, 80, 131 ties.materials.lattice), 63, 101, 152 get_spectra_files() (in module xrayutilities.io.spectra), HexagonalElasticTensor() (in module xrayutili-59, 97, 148 ties.materials.material), 66, 103, 154 get_ttheta_scan_ang() module xrayutili-(in hst2hdf5() (in module xrayutilities.io.radicon), 52, 90, ties.analysis.line_cuts), 43, 80, 132 get_ttheta_scan_bounds_ang() (in module xrayutili-HXRD (class in xrayutilities.experiment), 28, 117 ties.analysis.line_cuts), 43, 81, 132 get_ttheta_scan_q() (in module xrayutilities.analysis.line_cuts), 44, 81, 133 idx refraction() (xrayutiligetangles() (in module xrayutilities.analysis.misc), 46, ties.materials.material.Material method), 84, 135 68, 106, 157 GeTeRhombohedral() (in module xrayutili-ImageReader (class in xrayutilities.io.imagereader), 51, ties.materials.lattice), 63, 101, 151 89, 140 (xrayutilities.materials.database.DataBase GetF0() index_map_ij2ijkl() module xrayutili-(in method), 61, 99, 150 ties.materials.material), 69, 106, 157 GetF1() (xrayutilities.materials.database.DataBase xrayutiliindex_map_ij2ijkl() (in module method), 61, 99, 150 ties.math.transforms), 74, 111, 162 GetF2() (xrayutilities.materials.database.DataBase index_map_ijkl2ij() (in module xrayutilimethod), 61, 99, 150 ties.materials.material), 69, 106, 157 geth5_scan() (in module xrayutilities.io.spec), 57, 94, index_map_ijkl2ij() (in module xrayutili-145 ties.math.transforms), 74, 111, 162 geth5_spectra_map() (in module xrayutiliinit_area() (xrayutilities.experiment.QConversion ties.io.spectra), 59, 97, 148

171 Index

method), 31, 120

	multGaussFit() (in module xrayutilities.math.fit), 70,
method), 32, 121 init_material_db() (in module xrayutili-	107, 158 multGaussPlot() (in module xrayutilities.math.fit), 70,
ties.materials.database), 62, 100, 151 InputError, 24, 113	107, 158 multPeakFit() (in module xrayutilities.math.fit), 70,
IntensityNormalizer (class in xrayutilities.normalize), 35, 124	107, 158 multPeakPlot() (in module xrayutilities.math.fit), 70,
inverse() (xrayutilities.math.transforms.Transform method), 73, 111, 162	108, 159 mycross() (in module xrayutilities.math.transforms),
K	74, 111, 162
KeepData() (xrayutilities.gridder.Gridder method), 34,	N
123 keys() (xrayutilities.io.rotanode_alignment.RA_Alignme	NaumanniteLattice() (in module xrayutilint ties.materials.lattice), 64, 101, 152
method), 53, 91, 142	NiAsLattice() (in module xrayutili-
kill_spike() (in module xrayutilities.math.functions), 72, 110, 161	ties.materials.lattice), 64, 101, 152 NonCOP (class in xrayutilities.experiment), 29, 118 Normalize() (xrayutilities.gridder.Gridder method), 34,
L	123
lam (xrayutilities.materials.material.Material attribute), 68, 106, 157	nu (xrayutilities.materials.material.Material attribute), 68, 106, 157
lam2en() (in module xrayutilities.utilities_noconf), 37, 126	0
Lattice (class in xrayutilities.materials.lattice), 63, 101, 152	ones() (in module xrayutilities.gridder), 34, 124 Open() (xrayutilities.materials.database.DataBase
Lattice() (xrayutilities.materials.cif.CIFFile method), 60, 98, 149	method), 61, 99, 150
lattice_const_AB() (xrayutili-	P
ties.materials.material.Alloy method), 65, 102, 153	Parse() (xrayutilities.io.rotanode_alignment.RA_Alignment method), 53, 91, 142
lattice_const_AB() (xrayutili- ties.materials.predefined_materials.SiGe	parse() (xrayutilities.io.seifert.SeifertMultiScan method), 54, 92, 143
method), 69, 106, 157 LatticeBase (class in xrayutilities.materials.lattice), 64,	parse() (xrayutilities.io.seifert.SeifertScan method), 54,
101, 152	92, 143 Parse() (xrayutilities.io.spec.SPECFile method), 55, 93,
linear() (xrayutilities.experiment.QConversion method), 32, 122	Parse() (xrayutilities.io.spec.SPECLog method), 56, 93,
linear_detector_calib() (in module xrayutilities.analysis.sample_align), 48, 86, 137	144
Lorentz1d() (in module xrayutilities.math.functions),	Parse() (xrayutilities.materials.cif.CIFFile method), 61, 98, 149
71, 109, 160 Lorentz1d_der_p() (in module xrayutili-	PerkinElmer (class in xrayutilities.io.imagereader), 51, 89, 140
ties.math.functions), 72, 109, 160 Lorentz1d_der_x() (in module xrayutili-	PerovskiteTypeRhombohedral() (in module xrayutilities.materials.lattice), 64, 101, 152
ties.math.functions), 72, 109, 160 Lorentz2d() (in module xrayutilities.math.functions),	$plot() (xrayutilities.io.rotanode_alignment.RA_Alignment$
72, 109, 160	method), 53, 91, 142 plot() (xrayutilities.io.spec.SPECScan method), 57, 94,
M	point() (xrayutilities.experiment.QConversion method),
maplog() (in module xrayutilities.utilities), 37, 126	33, 122
Material (class in xrayutilities.materials.material), 66, 104, 155	Powder (class in xrayutilities.experiment), 30, 119 PowderIntensity() (xrayutilities.experiment.Powder
miscut_calc() (in module xrayutili-	method), 30, 119
ties.analysis.sample_align), 49, 86, 138	psd_chdeg() (in module xrayutili-
mon (xrayutilities.normalize.IntensityNormalizer attribute), 36, 125	ties.analysis.sample_align), 49, 87, 138 psd_refl_align() (in module xrayutili-
mu (xrayutilities.materials.material.Material attribute), 68, 106, 157	ties.analysis.sample_align), 50, 88, 139
00, 100, 107	

172 Index

PseudomorphicMaterial() xrayutili-101, 152 (in module ties.materials.material), 68, 106, 157 RelaxationTriangle() (xrayutili-PseudoVoigt1d() (in module xrayutilities.materials.material.Alloy method), ties.math.functions), 72, 110, 160 64, 102, 153 repair_key() (in module xrayutilities.io.seifert), 55, 92, Q RockSalt Cubic Lattice() (in module Q() (xrayutilities.materials.material.Material method), xrayutilities.materials.lattice), 64, 102, 152 66, 104, 155 RockSaltLattice() (in module xrayutili-(xrayutilities.experiment.Experiment Q2Ang() ties.materials.lattice), 64, 102, 152 method), 25, 114 RoperCCD (class in xrayutilities.io.imagereader), 52, Q2Ang() (xrayutilities.experiment.GID method), 26, rotarb() (in module xrayutilities.math.transforms), 74, Q2Ang() (xrayutilities.experiment.GID_ID10B 111, 162 method), 27, 116 RutileLattice() (in module xrayutili-Q2Ang() (xrayutilities.experiment.GISAXS method), ties.materials.lattice), 64, 102, 152 28, 117 Q2Ang() (xrayutilities.experiment.HXRD method), 28, S sampleAxis (xrayutilities.experiment.QConversion at-Q2Ang() (xrayutilities.experiment.NonCOP method), 30, 119 tribute), 33, 123 Q2Ang() (xrayutilities.experiment.Powder method), Save2HDF5() (xrayutilities.io.edf.EDFDirectory 30, 119 method), 51, 88, 140 QConversion (class in xrayutilities.experiment), 30, Save2HDF5() (xrayutilities.io.edf.EDFFile method), 119 51, 89, 140 QuartzLattice() xrayutili-Save2HDF5() (xrayutilities.io.spec.SPECCmdLine (in module ties.materials.lattice), 64, 101, 152 method), 55, 93, 144 Save2HDF5() (xrayutilities.io.spec.SPECFile method), R 55, 93, 144 Save2HDF5() (xrayutilities.io.spec.SPECScan RA_Alignment (class xrayutilimethod), 56, 94, 145 ties.io.rotanode_alignment), 53, 91, 142 Save2HDF5() (xrayutilities.io.spectra.SPECTRAFile rad2hdf5() (in module xrayutilities.io.radicon), 53, 90, method), 58, 95, 146 save_h5_attribs() (xrayutilities.io.seifert.SeifertHeader Read() (xrayutilities.io.spectra.SPECTRAFile method), method), 54, 91, 142 58, 95, 146 SeifertHeader (class in xrayutilities.io.seifert), 54, 91, read_data() (in module xrayutilities.io.spectra), 60, 97, SeifertMultiScan (class in xrayutilities.io.seifert), 54, read mca() (in module xrayutilities.io.spectra), 60, 97, 91, 142 SeifertScan (class in xrayutilities.io.seifert), 54, 92, 143 read_mca_dir() (in module xrayutilities.io.spectra), 60, selecthst() (in module xrayutilities.io.radicon), 53, 90, 98, 149 142 read_mcas() (in module xrayutilities.io.spectra), 60, 98, (xrayutilities.io.spectra.Spectra set_abs_factors() method), 59, 96, 147 ReadData() (xrayutilities.io.edf.EDFFile method), 51, (xrayutilities.materials.database.DataBase 88, 140 SetF0() method), 61, 99, 150 ReadData() (xrayutilities.io.spec.SPECMCAFile SetF1() (xrayutilities.materials.database.DataBase method), 56, 93, 144 method), 62, 99, 150 ReadData() (xrayutilities.io.spec.SPECMCAInline SetF2() (xrayutilities.materials.database.DataBase method), 56, 93, 145 method), 62, 99, 150 ReadData() (xrayutilities.io.spec.SPECScan method), SetMaterial() (xrayutili-56, 94, 145 ties.materials.database.DataBase method), readImage() (xrayutilities.io.imagereader.ImageReader 62, 99, 150 method), 51, 89, 140 SetMCAParams() (xrayutilities.io.spec.SPECScan ReadMCA() (xrayutilities.io.spectra.SPECTRAFile method), 56, 94, 145 method), 58, 95, 146 SetResolution() (xrayutilities.gridder2d.Gridder2D recarray2hdf5() (xrayutilities.io.spectra.Spectra method), 35, 124 method), 59, 96, 147

Index 173

(xrayutili-

ReciprocalLattice()

ties.materials.lattice.Lattice method),

SetResolution()

method), 35, 124

(xrayutilities.gridder3d.Gridder3D

SetWeight() (xrayutilities.materials.database.DataBase method), 62, 99, 150	TrigonalR3mh() (in module xrayutilities.materials.lattice), 64, 102, 153
SiGe (class in xrayutilities.materials.predefined_materials), 69,	TwoGauss2d() (in module xrayutilities.math.functions), 72, 110, 161
106, 157	11
smooth() (in module xrayutilities.math.functions), 73, 110, 161	U UB (xrayutilities.experiment.QConversion attribute),
SPECCmdLine (class in xrayutilities.io.spec), 55, 93,	30, 120
SPECFile (class in xrayutilities.io.spec), 55, 93, 144	UnitCellVolume() (xrayutilities.materials.lattice.Lattice method), 64, 101, 152
SPECLog (class in xrayutilities.io.spec), 56, 93, 144	Update() (xrayutilities.io.spec.SPECFile method), 56,
SPECMCA (class in xrayutilities.io.spec), 56, 93, 144	93, 144
SPECMCAFile (class in xrayutilities.io.spec), 56, 93, 144	Update() (xrayutilities.io.spec.SPECLog method), 56, 93, 144
SPECMCAInline (class in xrayutilities.io.spec), 56, 93, 144	V
SPECScan (class in xrayutilities.io.spec), 56, 93, 145 Spectra (class in xrayutilities.io.spectra), 58, 96, 147	VecAngle() (in module xrayutilities.math.vector), 74, 112, 163
spectra2hdf5() (xrayutilities.io.spectra.Spectra method), 59, 96, 147	VecDot() (in module xrayutilities.math.vector), 74, 112,
SPECTRAFile (class in xrayutilities.io.spectra), 57, 95,	VecNorm() (in module xrayutilities.math.vector), 75, 112, 163
SPECTRAFileComments (class in xrayutilities.io.spectra), 58, 96, 147	VecUnit() (in module xrayutilities.math.vector), 75, 112, 163
SPECTRAFileData (class in xrayutilities.io.spectra),	
58, 96, 147	W
SPECTRAFileDataColumn (class in xrayutilities.io.spectra), 58, 96, 147	wavelength (xrayutilities.experiment.Experiment at-
SPECTRAFileParameters (class in xrayutilities.io.spectra), 58, 96, 147	tribute), 25, 114 wavelength (xrayutilities.experiment.QConversion attribute), 34, 123
StructureFactor() (xrayutilities.materials.material.Material method),	wavelength() (in module xrayutilities_utilities_noconf), 37, 127
66, 104, 155	WurtziteLattice() (in module xrayutili-
StructureFactorForEnergy() (xrayutilities.materials.material.Material method),	ties.materials.lattice), 64, 102, 153
67, 104, 155	X
StructureFactorForQ() (xrayutili-	x (xrayutilities.materials.material.Alloy attribute), 65,
ties.materials.material.Material method), 67, 104, 155	x (xrayutilities.materials.materials.Alloy attribute), 65, 102, 153 x (xrayutilities.materials.predefined_materials.SiGe at-
SymStruct() (xrayutilities.materials.cif.CIFFile	tribute), 69, 106, 157
method), 61, 98, 149	xaxis (xrayutilities.gridder.Gridder1D attribute), 34, 123
T	xaxis (xrayutilities.gridder2d.Gridder2D attribute), 35,
tensorprod() (in module xrayutilities.math.transforms),	124
74, 112, 163 TetragonalIndiumLattice() (in module xrayutili-	xaxis (xrayutilities.gridder3d.Gridder3D attribute), 35, 124
ties.materials.lattice), 64, 102, 153 TetragonalTinLattice() (in module xrayutili-	xmatrix (xrayutilities.gridder2d.Gridder2D attribute), 35, 124
ties.materials.lattice), 64, 102, 153 TiltAngle() (xrayutilities.experiment.Experiment	xmatrix (xrayutilities.gridder3d.Gridder3D attribute), 35, 124
method), 25, 114 time (xrayutilities.normalize.IntensityNormalizer at-	xrayutilities (module), 9
tribute), 36, 125	xrayutilitiesinit (module), 24, 113
Transform (class in xrayutilities.math.transforms), 73,	xrayutilities.analysis (module), 38, 75, 127 xrayutilities.analysis.line_cuts (module), 38, 75, 127
111, 162	xrayutilities.analysis.line_cuts3d (module), 45, 82, 134
Transform() (xrayutilities.experiment.Experiment	xrayutilities.analysis.misc (module), 46, 84, 135
method), 25, 114	xrayutilities.analysis.sample_align (module), 46, 84, 135

174 Index

```
xrayutilities.config (module), 24, 113
                                                          ZincBlendeLattice()
                                                                                            module
                                                                                    (in
                                                                                                        xrayutili-
                                                                    ties.materials.lattice), 64, 102, 153
xrayutilities.exception (module), 24, 113
xrayutilities.experiment (module), 24, 114
                                                                   (xrayutilities.gridder3d.Gridder3D attribute),
xrayutilities.gridder (module), 34, 123
                                                                    35, 124
xrayutilities.gridder2d (module), 34, 124
                                                          ZRotation() (in module xrayutilities.math.transforms),
xrayutilities.gridder3d (module), 35, 124
                                                                    74, 111, 162
xrayutilities.io (module), 51, 88, 139
xrayutilities.io.edf (module), 51, 88, 140
xrayutilities.io.imagereader (module), 51, 89, 140
xrayutilities.io.panalytical_xml (module), 52, 89, 141
xrayutilities.io.radicon (module), 52, 90, 141
xrayutilities.io.rotanode_alignment (module), 53, 91,
xrayutilities.io.seifert (module), 54, 91, 142
xrayutilities.io.spec (module), 55, 93, 144
xrayutilities.io.spectra (module), 57, 95, 146
xrayutilities.materials (module), 60, 98, 149
xrayutilities.materials._create_database (module), 60,
          98, 149
xrayutilities.materials._create_database_alt (module),
          60, 98, 149
xrayutilities.materials.cif (module), 60, 98, 149
xrayutilities.materials.database (module), 61, 98, 149
xrayutilities.materials.elements (module), 62, 100, 151
xrayutilities.materials.lattice (module), 62, 100, 151
xrayutilities.materials.material (module), 64, 102, 153
xrayutilities.materials.predefined materials (module),
          69, 106, 157
xrayutilities.math (module), 69, 107, 157
xrayutilities.math.fit (module), 69, 107, 158
xrayutilities.math.functions (module), 71, 108, 159
xrayutilities.math.transforms (module), 73, 111, 161
xrayutilities.math.vector (module), 74, 112, 163
xrayutilities.normalize (module), 35, 124
xrayutilities.utilities (module), 37, 126
xrayutilities_utilities_noconf (module), 37, 126
XRDMLFile (class in xrayutilities.io.panalytical_xml),
          52, 89, 141
XRDMLMeasurement
                                       in
                                              xrayutili-
                            (class
          ties.io.panalytical_xml), 52, 90, 141
XRotation() (in module xrayutilities.math.transforms),
          73, 111, 162
Y
yaxis (xrayutilities.gridder2d.Gridder2D attribute), 35,
yaxis (xrayutilities.gridder3d.Gridder3D attribute), 35,
ymatrix (xrayutilities.gridder2d.Gridder2D attribute),
ymatrix (xrayutilities.gridder3d.Gridder3D attribute),
          35, 124
YRotation() (in module xrayutilities.math.transforms),
          74, 111, 162
Ζ
```

Index 175

zaxis (xrayutilities.gridder3d.Gridder3D attribute), 35,

124