جامعة خليفة
Khalifa University

Inspection Date	06-02-2023	**Report Ref. No.**	MACINS -06/2/2023
Site Name	Main Campus	**Location**	Clinical Skills and Simulation
Inspected By	Roberto Macahig	**Witnessed by**	Ahmed Kamal Abdalgadir Mohamed

Inspection Type	☑General ☑Housekeeping & Sanitation ☑Fire ☑Electrical ☐Ladders ☐Lab ☐Food ☐Structure ☐Motor Vehicles ☐Landscaping ☐PPE ☐Stores ☑Emergency Evacuation

Findings					
	☑ Safety ☐ Environment ☐ Occupational health				
S/N	**Description**	**Significant Risk Yes/No**	**Risk Evaluation**		
			Low	**Med**	**High**
1.	Clinical Skills and Simulation Spaces like offices (A04096) were allegedly hand-overs to end-users for occupancy but Fire Detection is not active, smoke detectors were covered and the space has ventilation concerns. The location of Space, A04097 and A04098 is not confirmed.	Yes			√
2.					
3.					

Attachment	☑Photos	☐ Video Footage	☐Other

جامعة خليفة
Khalifa University

Corrective actions				
S/N	**Description**			
	Short Term Action	**Long Term Action**	**By Whom**	**By When**
1.	Review the status of handover and follow up all the snag works.		FM Hard Service	Feb 2023
2.				
3.				
4.				
5.				

Prepared by:	**ESH Section**	**Received by:**				**Followed up by:**	
		Contractor:		**Consultant:**		☐ **Corrective Action is taken**	☐ **Corrective action not taken**
Name	Roberto Macahig	Name		Name		Name	
Designation	Lab Safety Specialist	Designation		Designation		Designation	
Signature		Signature		Signature		Signature	
Date		Date		Date		Date	

Attached Photos

Copies of this document available in ADM HSE Intranet are only the latest, valid and controlled documents. All other copies are uncontrolled and valid only on the date printed. Last printed: 23/5/2023 11:53:00 AM