ETUDES ET ESSAIS S2G Test Industriel	*Epreuve d'étanchéité*

Rapport N°: A.ASS 446 /24

Type of test	:	Epreuve d'étanchéité
Date of test	:	23/10/2025
Inspector	:	A.ASSILA
Code	:	51533
constrictor	:	SGTM

Test site	RABAT	**Builder**	SGTM
Test applicant	SGTM	**Year of manufacture**	2025

NOMENCLATURE	*Manometer*	*Nature of fluid*	*COMMENTS*
	-	CARBURANT	*The reservoir was tested by FUEL, without deformation or apparent leak*

Circumstances test		
At the request of the manufacturer	A Construction	after repair
☐	☑	☐

N° de plan	**Pression de service (en bar)**	**Pression d'épreuve (en bar)**
/	-	-

Visa Inspecteur	*Visa Direction*
S2G TEST INDUSTRIEL sarl Central Park Imm. A 3ème Etage Bureau N°21 Mohammedia (1)	S2G TEST INDUSTRIEL sarl Central Park Imm. A 3ème Etage Bureau N°21 Mohammedia (1)