Trench and Excavation Inspection

Form 18-B

COMPETENT PERSON CHECKLIST

LOCATION:	**DATE:**
TIME OF INSPECTION(S)	
WEATHER CONDITIONS:	**APPROX. TEMP.:**
CREW LEADER:	**SUPERVISOR:**

DIMENTIONS:			
(Depth x 2) x Ratio +Width= Top Opening	**DEPTH =**		
	TOP =	W	L
	BOTTOM =	W	L

SOIL TYPE:	**TESTED:**
☐ Solid rock (most stable)	☐ Yes
☐ Average soil – Class A	☐ No
☐ Fill material – Class B (Ratio 1:1)	
☐ Loose sand – Class C (Ratio 1:1.5) (No Benching)	

Yes	No	**HAZARDOUS CONDITIONS**
☐	☐	Saturated soil / standing or seeping water
☐	☐	Cracked or fissured wall(s)
☐	☐	Bulging wall(s)
☐	☐	Floor heaving
☐	☐	Utilities Located and tolerance zone followed
☐	☐	Super-imposed loads
☐	☐	Vibration
☐	☐	Depth greater than 10’

PROTECTION METHODS:

(Walls MUST be vertical—NO voids)

SHORING

- ☐ Timber
- ☐ Pneumatic
- ☐ Hydraulic
- ☐ Screw Jacks
- ☐ Trench Shield

UNEVEN, IRREGULAR WALLS

- ☐ Trench Box
- **Sloping:** ☐ **1:1 (45°)** ☐ **1 ½:1 (34°)**

Yes	No	**PLACEMENT OF SPOILS & EQUIPMENT**
☐	☐	Spoils at least 2 feet from edge of trench
☐	☐	Equipment at least 2 feet from edge
☐	☐	Backhoe at end of trench
☐	☐	Compressor, etc. at remote location

LADDER LOCATION

☐	☐	Located in protected area
☐	☐	Within 25 feet of safe travel
☐	☐	Secured
☐	☐	Extends 36 inches above the landing
☐	☐	Leads to safe landing

Yes	No	**ENVIRONMENTAL CONDITIONS:**
☐	☐	Gas detector used? Must be used at depths 4ft. or greater
☐	☐	Confined space permit issued? if Hazardous Atmosphere exists

		OTHER:
☐	☐	Shoring equip. & materials inspected prior to use? Tabulated Data on-site?
☐	☐	Is trench SAFE to enter?

COMMENTS:

Note Visual and Manual tests preformed :

OSHA PERMIT NOTIFICATION #:_____

USA Dig Ticket #

NOTE

All unsafe conditions must be corrected prior to trench entry. If any hazardous conditions are observed, the trench must be immediately evacuated and no one allowed to re-enter until corrective action has been taken.

TO BE FILLED OUT BY COMPETENT PERSON

_____

(Competent Person Print Name)

_____

(Competent Person Sign Name)