



TEST REPORT

TC-9888

Sample No.: 0708822532036091

Test Report No: DWTL-PEO-2023

Name and address of Customer: Govt. Ser. Sec. School Sangla

Division: ☒ Reckong Poo ☐ Kalpa ☐ Povant ☐ Sangla ☐ Kuvsham ☐ Nigulser ☐ Lapti ☐ Kalgom ☐ Sub-Division:

Section: ☒ Reckong Poo ☐ Kalpa ☐ Povant ☐ Sangla ☐ Kuvsham ☐ Nigulser ☐ Lapti ☐ Kalgom ☐ Sub-Division:

Name of Scheme Source: ☒ Niche ☐ Poo ☐ Name of Panchayat: Sangla

Name of Block: Sangla

Name of Village: Sangla

Date of Collection: 27/09/2023

Date of Receipt at Laboratory: 27/09/2023

Type of Source: ☐ Spring ☐ Public Tap Water ☐ Individual Tap Water ☒ Hand Pump ☐ Others

Quantity of sample: 1000 ml

Test Start Date: 27/09/2023

Test End Date: 27/09/2023

Sr. No.	Test Parameter	Units	Result	Requirement as per IS 10500:2012		Test Method
				Acceptable Limit	Permissible Limit in absence of Alternate Source	
Physical Parameters						
1	Colour	HU	2.5	5	15	APHA 23rd Edition - 2120-Colour Method B (Platinum Cobalt Visual Comparison): 2017
2	Odour			Agreeable	Agreeable	IS 3025 (Part 5): 2018
3	Taste			Agreeable	Agreeable	IS 3025 (Part 5): 2017
4	pH	pH	7.73	6.5	8.5	APHA 23rd Edition - 4500-H+ Method B: 2017
5	Turbidity	NTU	1.16	1	5	APHA 23rd Edition - 2130-Turbidity Method B: 2017
6	TDS	mg/l	108.0	Max 500	Max 2000	APHA 23rd Edition - 2540-TDS Method C (Dried at 180 degree Celsius): 2017
Chemical Parameters						
7	Total Hardness (as CaCO ₃)	mg/l	50	Max 200	Max 600	APHA 23rd Edition - 2340-Hardness Method C (EDTA method): 2017
8	Calcium (as Ca)	mg/l	11.22	Max 75	Max 200	APHA 23rd Edition - 3500-Ca Method B (EDTA method): 2017
9	Magnesium (as Mg)	mg/l	5.34	Max 30	Max 100	APHA 23rd Edition - 3500-Mg Method B (By Calculation): 2017
10	Chloride (as Cl)	mg/l	10.99	Max 250	Max 1000	APHA 23rd Edition - 4500-Cl Method B (Argentometric method): 2017
11	Total Alkalinity (as CaCO ₃)	mg/l	20	Max 200	Max 600	APHA 23rd Edition - 2320-Alkalinity Method B (Titration method): 2017

Remarks (if any): BDL: Below Detection Limit, DL: Detection Limit

Note:

- This report should not be produced partly or full without approval of signatory authority for legal purpose.
- This result refers only to tested samples and parameters tested.
- Sample will be stored for the period of 7 days from the date of issue of report.

Tested By:
Water Testing Laboratory,
Heckong Poo

Water Testing Laboratory
Jal Shakti Vibhag Ripeo

Authorized Signatory
Water Testing Laboratory,
Reckong Poo

Assistant Engineer
Jal Shakti Sub-Division Sangla

Attended By:
Jal Shakti Vibhag Ripeo

PALEOPAL
Govt. Ser. Sec. School
Sangla, District Baramulla