controlling equipment can interrupt operations, causing production delays or temporary shutdowns.

To prevent this, FOTA platforms schedule updates during periods when devices are inactive. Each device typically has an idle window, or administrators can define a maintenance window for firmware installation. The update waits until the scheduled period before it is downloaded and installed onto the device.

Updating millions of devices needs a completely different approach. Updating the devices at the same time could lead to overloading of the network and an increased probability of mass failure since the devices may be situated in different parts of the world with various time zones and usage schedules.

Thus, FOTA deployment is performed through a staged approach. First, the update is deployed to a small number of devices and then, after checking its validity, is rolled out to the next larger group of devices. Such an approach helps to decrease risks during deployment to deliver firmware updates efficiently and without disrupting the work process.

Telemetry and debug logs for effective OTA update monitoring

Telemetry data collected during and after an OTA update may vary depending on the application and customer requirements. However, one piece of data is critical for any OTA update: after completing the update, the device should report the firmware version or software revision it is running. This allows operators to confirm that the update was successful and verify the software version running on each device. Any additional telemetry is typically application-specific.

For troubleshooting OTA failures, diagnostic logs play an important role. Since different failures require different information, there is no single log that can identify every issue. At the same time, continuously collecting detailed debug logs from every device is not practical because it increases storage, processing, and communication overhead.

Instead, most systems keep logging minimal during normal operation and enable detailed debug logging only when needed. Before an OTA update, especially when investigating a known issue, a command can activate debug mode, allowing the device to capture detailed logs throughout the update process. This logging helps identify the root cause of failures, while routine OTA updates can be monitored using telemetry data alone.

Looking ahead: FOTA across a 10-to-20-year lifecycle

As connected products can have lifespans of 10 to 20 years, reliable firmware update mechanisms will become increasingly important. AI is already being used to identify non-responsive devices and detect problems during monitoring and diagnostics, and its role is likely to grow. Intelligent software agents may eventually operate on edge devices and adjust parameters such as thresholds, calibration values, or sampling rates according to application needs without requiring a firmware update.

No matter how advanced OTA technology becomes, the fundamentals of a reliable FOTA update will remain the same. An effective system should have a strong foundation of security and reliability, including CRC checks, firmware validation, and a rollback mechanism, because a failed firmware update can completely disable a device in the field. EFY

Co-author Nidhi Agarwal is Senior Technology Journalist at EFY with a deep interest in embedded systems, development boards, and IoT cloud solutions.

India's No.1 Electronics Magazine
RANKING AS PER ELCINA-IMRB REPORT

EFYGROUP
YOURS SINCE 1969

Facing problems in getting EFY Magazine in your area?

If so, let us know!



Electronics For You magazine is available at all top news-stands/outlets in India. But if you are facing problem in getting EFY magazine in your area, please call Akhilesh Yadav on **+91-8800295612** or drop an email at ***efycirc@efy.in***. We will help you locate the nearest news-stand or arrange a copy at your doorstep.

electronics FOR YOU

South Asia's Most Popular Electronics Magazine

Those who wish to distribute EFY Group publications may also call Akhilesh Yadav on +91-8800295612 or write at *efycirc@efy.in*