

Fig. 18: An example of scripting




Fig. 19: KEPServer application main screen




Fig. 20: Setting tag names and addresses in KEPServer

specify access name in InTouch as KEPServerEX_SL. Access names are selected in the tag name dictionary for each tag used in the application.

Scripting. In all control systems, it is essential to provide software interlocks to prevent human errors. So the best method would be using Window Scripts in InTouch. Window scripts execute periodically when an InTouch window is opened, or one time when an InTouch window is opened or closed.

Programming here is done using scripts, which is similar to any programming language. A typical scripting example is shown in Fig. 18.

KEPServer

KEPware's OPC server KEPServerEX provides an easy and reliable way to connect the Allen Bradley PLC to HMI, SCADA, Historian, MES, ERP and countless custom applications. Here, you can use KEPServer for communicating RSLOGIX to Wonderware InTouch using the Ethernet/IP protocol.

Be careful while specifying tag-names in KEPServer. Tag names and their corresponding addresses should match those mentioned in Wonderware InTouch development.

Running the final application

Once your PLC code is downloaded into the PLC and run from RSLogix, run KEPServer. Open the runtime application of Wonderware InTouch software and open your GUI file. Always make sure that KEPServer is running in the background while you run Wonderware InTouch application.

Applications

Such a control system can be very useful for industrial automation, in research laboratories and big industries. The graphical interface makes it easy for the operator to operate switching and controlling operations. The PLC provides a very rugged solution to control relays and RS232 devices. ●

addresses of devices and PLC variables used in Ladder logic.

Access name. Each PLC uses a specific protocol to communicate with the I/O server or DA server. InTouch then uses an access name concept to continue this communication for dynamic data exchange (DDE). Typically, because here KEPServer is acting as a communicator between PLC RSLogix and Wonderware InTouch, we