



Govt. of Karnataka
(Rural Drinking Water & Sanitation Department)

Office of the Executive Engineer
Rural Drinking Water & Sanitation,
Division, Bidar-585 401.

E-mail:- eedwsd.bdr1@gmail.com

No. EE RDW&SD BDR/LAB/2026-27/566

Date : 28.07.2026

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by MANIKANTH KERURU EE/RDW&SD Bid
(Name of Officers with designation) from **Rural Drinking Water and Sanitation Department,**
Govt. of Karnataka (Name of Department/Office) inspected **National English Medium Public**
School, BVB Campus, Manhalli Road, Bidar – 585403 on 18/7/26 (Date of Inspection)
and on the basis of **Water Test Report** dated 8/4/26 (Attached) of **Rural Drinking**
Water and Sanitation Department, Govt. of Karnataka certified that the **National English**
Medium Public School, BVB Campus, Manhalli Road, Bidar. – 585403 has safe drinking
water facilities for the students and members of staff of the institution. School also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central / State / U.T. Govt.

This certificate is valid till: **6 Months only.**

Note: At the time of inspection, the filter units
are connected to the Borewell source.

Signature with Seal:

Name:

Designation:

(Name & Address of the Office Department)


Executive Engineer
R.D W. & S Division
BIDAR

To,
Principal,
National English Medium Public School,
Bidar-585403.

RURAL DRINKING WATER & SANITATION DIVISION BIDAR
BIDAR DISTRICT WATER QUALITY TESTING LABORATORY, RDWSD
 OLD VETERINARY HOSPITAL, BIDAR, KARNATAKA, INDIA
 EmailId: rdwslabwqmisp.bidarlab@gmail.com. Phone Number: 08182-299944

THE PRINCIPAL

SHRILATHA G SWAMY

NATIONAL ENGLISH MEDIUM PUBLIC SCHOOL B V B COLLEGE CAMPUS
BIDAR.

TALUKA & DISTRICT BIDAR.

ADDRESS OF THE SAMPLE LOCATION: NATIONAL ENGLISH MEDIUM
PUBLIC SCHOOL B V B COLLEGE CAMPUS BIDAR.

Report date 09/04/2026

Report Number 26MS0214

Reference: Departmental Sample

Sample receipt date 08/04/2026

Sample code BID26APP0244

Date of Sample collection 08/04/2026

Analysis start date 08/04/2026

Analysis completion date 09/04/2026

Sample collection protocol APHA 24th Edition

Sample quantity 1 Liter

Sample Particulars: BORE WELL

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Clear.					
1	pH Value @25°C	8.03	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, µS/cm @ 25°C	407	—	—	IS 3025 (Part-14) : 2013 RA.2019
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6) : 2018
4	Colour, Hazen Units	2	5	15	IS 3025 (Part-8) : 2023
5	Turbidity, NTU	0.3	1	5	IS 3025 (Part-4) : 2021
6	Total Dissolved Solids @ 180°C, mg/l	204	500	2000	IS 3025 (Part-10) : 1984 RA.2023
7	Alkalinity as CaCO ₃ , mg/l	152.7	200	600	IS 3025 (Part-16) : 1984 RA.2023
8	Total Hardness as CaCO ₃ , mg/l	156.1	200	600	IS 3025 (Part-23) : 1986 RA.2023
9	Calcium as Ca, mg/l	27.2	75	200	IS 3025 (Part-21) : 2009 RA.2014
10	Magnesium as Mg, mg/l	21.4	30	100	IS 3025 (Part-40) : 1991 RA.2019
11	Chloride as Cl, mg/l	73.9	250	1000	IS 3025 (Part-46) : 1994 RA.2023
12	Sulphate as SO ₄ , mg/l	8.62	200	400	IS 3025 (Part-32) : 1988 RA.2019
13	Fluoride as F, mg/l	0.38	1	1.5	IS 3025 (Part-24) : 1986 RA.2022
14	Nitrate as NO ₃ , mg/l	12.51	45	No relaxation	APHA 23 rd Edition 4500-F D RA: APHA 24 th Edition
15	Iron as Fe, mg/l	BDL	1	No relaxation	APHA 23 rd Edition 4500-NO3-B RA: APHA 24 th Edition

Remarks: The given sample Conforms to the Acceptable limit of IS 10500:2012 RA 2018 Drinking water Specification for the above tested Physical & Chemical Parameters only.

Reviewed & Authorized By

Quality Manager

QUALITY MANAGER

Date: 09/04/2026

Bidar District Water Quality Testing Laboratory

RDWSD/WQMSP/Tr/01

RDWSD Division, BIDAR.

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.
- 6) Whereas BDL: Below Detection limit. UDL: Upper Detection limit NTU: Nephelometric meter
- 7) The Sample collected and Submitted by Client (PRINCIPAL SHRILATHA – 9482429210)