



MATERIAL INSPECTION REQUEST

OMNIYAT

BSBG

CONTRACT : Plot 18 by Dorchester Collection	CONTRACT No: 201A22002
Requested By : TSSC Kitchen & Laundry ET LLC MIR Ref. No.:  Signature : TSSC KITCHEN & LAUNDRY TRADING LLC	TSS-AX-MR-GF-00004 Revision No: 0 Subcontractors No. 12 Date : 12/9/2022
Discipline : <input checked="" type="checkbox"/> STRU <input type="checkbox"/> Bok:89. DUBAI <input type="checkbox"/> ARCH- <input checked="" type="checkbox"/> MEP	<input type="checkbox"/> OTHERS
The following items are ready to inspect on 12/12/2022 by 10:00 am/pm	
Subcon No. F015/15.1.13/31649/PMTDG/0321/ Variation Order No.1 dated 17/May/2022	
Material Description: Service distribution unit.	
Material Submittal Ref:	
Specification No : BQ.08A	
Quantity : 1 No.	
Attached :	<input checked="" type="checkbox"/> Checklist <input type="checkbox"/> Sketches <input type="checkbox"/> Others <input checked="" type="checkbox"/> Delivery Note
Manufacturer's Details :	
Manufacturer : M/s Professional Kitchens Industrial - UAE	
Batch No. :	
Date of Manufacture : 07/12/2022	
Delivery Note No : TSSC: PR-22231107	
Country of Origin : United Arab Emirates	
Date of arrival on site : 07/12/2022	
Storage Location : KCE Store	
Compliance Statement: The contractor hereby confirms that the Material offered for inspections are ready and compliance with the Contract Documents. Adequate HSE measures are in place for storage.	
Inspection Report :	
Physical Damage ?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Details Given Above Correct ?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Conform with Approved submission ?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Details :	
Remarks :	
Engineer's Comments :	
The above material has been inspected on site and found at time of inspection to be :	
Satisfactory <input type="checkbox"/>	Unsatisfactory <input type="checkbox"/>
Inspected by : Date :	
<input type="checkbox"/> Approved <input type="checkbox"/> Approved with Comments <input type="checkbox"/> Revise & Resubmit <input type="checkbox"/> Rejected	
Fondu will review all equipment once installation is complete	
Refer Fondu comments GD-14.12.2022	
Name: George K	Signature : 
Project Manager's Approval	
Name:	Signature :
Date : 07-12-2022	
Date :	

Project : The Residences Dorchester Collection by Omniyat, Business Bay, Dubai
Package : Supply & Installation of Kitchen Equipment
Client : Sky Palaces Real Estate Development LLC


Sub Contractor : TSSC Kitchen & Laundry Equipment Trading
Document Ref. : TDC/KE/09L22/MTR004/S001
Date : 9th December 2022

Schedule of Kitchen Equipment for MIR # 004

Received Goods in Good Condition

Receivers Name, Sign and Stamp

This Certifies that the equipment as listed above have been received satisfactorily and are acceptable to the client except for items noted otherwise above



تي اس اس سي لتجارة معدات المطابخ وتنظيف الملابس - ش ذ ٢٥
TSSC Kitchen & Laundry Equipment Trading LLC


DELIVERY NOTE


					Page #	1 of 1	
Customer:		Ship to:			PR	22231107	
Sky Palaces Real Estate Development LLC		The Residences Dorchester Collection by Omniyat, Business Bay, Dubai			Date	07/Dec/22	
P.O. Box 12501 Dubai, United Arab Emirates					LPO #	Salesman	JFA
					Currency	AED	
SL No.	BOQ ITEM No.	Manufacturer	MODEL	Description of the Item	U/M	Qty	
1	BQ.08A	PKI	Custom - SDU	service distribution unit. 3460 x 200	No	1	
Received Goods in Good Condition					for TSSC Kitchen & Laundry Equipment Trading LLC.		
							
Receivers Name, Sign and Stamp							
Contact No.: Mr. Vivek 050 6521454 (PM) Mr. Vinu 056 1169938 (Site In Charge)							
Date Received:							



P.O. Box 69, Dubai, United Arab Emirates Tel.: +971 4 343 1100
Fax: +971 4 343 8226 Email: tssc@eim.ae www.tsscdubai.com

Page 3 of 1



KHANSAHEB	MATERIAL INSPECTION REQUEST		OMNIYAT	BSBG
CONTRACT : Plot 18 by Dorchester Collection		CONTRACT No: 201A22002		
Requested By : TSSC Kitchen & Laundry ET LLC		MIR Ref. No.: TSS-AX-MR-GF-00006		
Signature : 		Revision No: 0		
		Subcontractors No: TSSC/MIR006		
		Date : 05/01/2023		
Discipline : <input type="checkbox"/> STRUCTURE <input checked="" type="checkbox"/> ARCH <input checked="" type="checkbox"/> MEP <input checked="" type="checkbox"/> OTHERS				
The following items are ready to inspect on 05/01/2023 by 10:00 am/pm				
Subcon No. F015/15.1.13/31649/PMTDG/0321/ Variation Order No.1 dated 17/May/2022				
Material Description: Material Inspection request for Cold Room, DO-PR-22191201				
Material Submittal Ref: OCI-WTRAN-015260 (Aconex Reference No)				
Specification No : BQ.14A				
Quantity : 1 No.				
Attached : <input checked="" type="checkbox"/> Checklist <input type="checkbox"/> Sketches <input type="checkbox"/> Others <input checked="" type="checkbox"/> Delivery Note				
Manufacturer's Details :				
Manufacturer : M/s Technical Supplies and Services Co LLC				
Batch No. :				
Date of Manufacture : 18 Dec 2022				
Delivery Note No : TSSC: PR-22191201				
Country of Origin : United Arab Emirates				
Date of arrival on site : 19 Dec 2022				
Storage Location : KCE Store				
Compliance Statement: The contractor hereby confirms that the Material offered for inspections are ready and compliance with the Contract Documents. Adequate HSE measures are in place for storage.				
Inspection Report :				
Physical Damage ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO	
Details Given Above Correct ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO	
Conform with Approved submission ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO	
Details :				
Remarks :				
Engineer's Comments :				
The above material has been inspected on site and found at time of inspection to be :				
Satisfactory <input type="checkbox"/>		Unsatisfactory <input type="checkbox"/>		
Inspected by :		Date :		
<input type="checkbox"/> Approved <input type="checkbox"/> Approved with Comments		<input type="checkbox"/> Revise & Resubmit	<input type="checkbox"/> Rejected	
BSBG Comment Refer Fondué comment on the Aconex Document Review History Status "D"				
Name:		Signature : FAA/GD	Date : 06.01.2023	
Project Manager's Approval				
Name:		Signature :	Date :	

Project : The Residences Dorchester Collection by Omniyat, Business Bay, Dubai
Package : Supply & Installation of Kitchen Equipment
Client : Sky Palaces Real Estate Development LLC

Sub Contractor : TSSC Kitchen & Laundry Equipment Trading
Document Ref. : TDC/KE/24L22/MIR006/S001
Date : 24th December 2022


Schedule of Kitchen Equipment for MIR # 006

Item No	Qty	Unit	Area / Item Description	Manufacturer	Model	Origin	Comments
GROUND FLOOR							
BQ.00 BANQUET KITCHEN AND SUPPORT							
BQ.14A	1	No.	Panel System with 2 Single Door	TSSC.	Custom	U. A. E.	

Received Goods in Good Condition

Receivers Name, Sign and Stamp

This Certifies that the equipment as listed above have been received satisfactorily and are acceptable to the client except for items noted otherwise above



تي اس اس سي لتجارة معدات المطابخ وتنظيف الملابس - ش ذ ٥٥
TSSC Kitchen & Laundry Equipment Trading LLC

DELIVERY NOTE

					Page #	1 of 1
Customer:		Ship to:			PR	22191201
Sky Palaces Real Estate Development LLC		The Residences Dorchester Collection by Omniyat, Business Bay, Dubai			19/Dec/22	
P.O. Box 12501 Dubai, United Arab Emirates					Date	
					LPO #	
					Salesman	JFA
					Currency	AED
SL No.	BOQ ITEM No:	Manufacturer	MODEL	Description of the Item	U/M	Qty
1	BQ.14A	TSSC.	Custom	Panel System with 2 Single Door	No	1
Received Goods in Good Condition				for TSSC Kitchen & Laundry Equipment Trading LLC.		
						
Receivers Name, Sign and Stamp						
Contact No.: Mr. Vivek 050 6521454 (PM) Mr. Vinu 056 1169938 (Site In Charge)						
Date Received:						



P.O. Box 69, Dubai, United Arab Emirates Tel: +971 4 343 1100
Fax: +971 4 343 8226 Email: tssc@eim.ae www.tsscdubai.com



MATERIAL INSPECTION
REQUEST

OMNIYAT



CONTRACT : Plot 18 by Dorchester Collection	CONTRACT No: 201A22002	
Requested By : TSSC Kitchen & Laundry ET LLC	MIR Ref. No.: TSS-AX-MR-B1-00001	
	Revision No: 0	
	Subcontractors No. TDC/KEP2/2207V/SWD/MIRO01	
Signature :	Date : 20/7/2022	
Discipline : <input type="checkbox"/> STRU <input checked="" type="checkbox"/> ARCH <input checked="" type="checkbox"/> MEP <input checked="" type="checkbox"/> OTHERS		
The following items are ready to inspect on 20/7/2022	by 10:00 am / pm	
Subcon No.		
Material Description: Floor Drain - Stainless Steel Grating		
Material Submittal Ref: TSS-AX-SA-ML-0013 Rev. 0.		
Specification No : FND-1614-02-FB-SPC-001-00 for Item Nos. LD07, RD08, SDP07, SD09, WW08, UD06 & GV07		
Quantity : 12 Nos.		
Attached : <input type="checkbox"/> Checklist <input type="checkbox"/> Sketches <input checked="" type="checkbox"/> Others <input checked="" type="checkbox"/> Delivery Note		
Manufacturer's Details :		
Manufacturer : Professional Kitchens Industrial - UAE		
Batch No. :		
Date of Manufacture : 16/7/2022		
Delivery Note No : PKI: 3436, TSSC: PR-222100178		
Country of Origin : United Arab Emirates		
Date of arrival on site : 16/7/2022		
Storage Location : KCE Store		
Compliance Statement: The contractor hereby confirms that the Material offered for inspections are ready and compliance with the Contract Documents. Adequate HSE measures are in place for storage.		
Inspection Report :		
Physical Damage ?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
Details Given Above Correct ?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
Conform with Approved submission ?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
Details :		
Remarks :		
Engineer's Comments :		
The above material has been inspected on site and found at time of inspection to be :		
Satisfactory <input type="checkbox"/>	Unsatisfactory <input type="checkbox"/> BSBG: Refer comments of FND	
Inspected by : George K Date : 29.07.2022		
<input type="checkbox"/> Approved	<input checked="" type="checkbox"/> Approved with Comments	
<input type="checkbox"/> Revise & Resubmit	<input type="checkbox"/> Rejected	
Fondue:-		
Approved as noted subject to final inspection after installation. Comply with all comments on Material submittal Coordinate and confirm the floor gullies are connected to an odor trap. Coordinate floor finishes details.		
Name: George K	Signature :	Date : 29.07.2022
Project Manager's Approval		KRIS Date : 31/07/22
Name:	Signature :	Date :

Comparative Bill Of Quantities for Kitchen Equipment

Current BOQ					
Item No	Quantity	Unit	Area / Item Description	Manufacturer	Model
BASEMENT 1					
LD.00 LOADING DOCK					
LD.07	3	No.	Floor drain with stainless steel gratings. 200 x 200	PKI / Techsteel	Custom
LD.08	1	No.	Floor drain with stainless steel gratings. 10300 x 500	PKI / Techsteel	Custom
RD.00 RECEIVING & DECANT					
RD.08	1	No.	Floor drain with stainless steel gratings. 200 x 200	PKI / Techsteel	Custom
RW.00 RAW WASH					
RW.03	1	No.	Floor drain with stainless steel gratings. 1200 x 300	PKI / Techsteel	Custom
SDP.00 STAFF DINING SUPPORT PANTRY					
SDP.07	1	No.	Floor drain with stainless steel gratings. 200 x 200	PKI / Techsteel	Custom
SD.09	1	No.	Floor drain with stainless steel gratings. 200 x 200	PKI / Techsteel	Custom
WW.00 STAFF DINING ROOM WAREWASH					
WW.08	2	No.	Floor drain with stainless steel gratings. 200 x 200	PKI / Techsteel	Custom
WW.10	1	No.	Floor drain with stainless steel gratings. 1200 x 300	PKI / Techsteel	Custom
Laundry Room					
LAUNDRY BASEMENT 1					
UD.00 UNIFORM DISTRIBUTION AREA					
UD.06	1	No.	Floor drain with stainless steel gratings. 200 x 200	PKI / Techsteel	Custom
UD.00 UNIFORM DISTRIBUTION AREA					
GV.07	3	No.	Floor drain with stainless steel gratings. 200 x 200	PKI / Techsteel	Custom

DORCHESTER HOTEL DUBAI	29.07.2022
STATUS	APPROVED TO PROCEED WITH NO COMMENT
A	APPROVED SUBJECT TO ALL COMMENTS BEING INCORPORATED
B	REJECTED, RESUBMIT INCORPORATING ALL COMMENTS
C	NO COMMENT REQUIRED FROM FONDUE TEAM
D	



MATERIAL INSPECTION REQUEST

OMNIYAT



CONTRACT : Plot 18 by Dorchester Collection		CONTRACT No: 201A22002	
Requested By :	TSSC Kitchen & Laundry ET LLC	MIR Ref. No.:	TSS-AX-MR-GF-00005
Signature :		Revision No:	00
		Subcontractors No.	TSSC/MIR005
		Date :	05/01/2023
Discipline :	<input type="checkbox"/> STRU <input checked="" type="checkbox"/> ARCH <input checked="" type="checkbox"/> MEP <input checked="" type="checkbox"/> OTHERS		
The following items are ready to inspect on 05/01/2023 by 10:00 am/pm			
Subcon No. F015/15.1.13/31649/PMTDG/0321/ Variation Order No.1 dated 17/May/2022			
Material Description: Material Inspection Request for Kitchen Hoods, DO-PR-22201204			
Material Submittal Ref:			
Specification No : HK.30, WW.07, BQ.48, LL.22, ADK.55			
Quantity : 5 Nos.			
Attached :	<input checked="" type="checkbox"/> Checklist <input type="checkbox"/> Sketches <input type="checkbox"/> Others	<input checked="" type="checkbox"/> Delivery Note	
Manufacturer's Details :			
Manufacturer : M/s Ginox Swiss Kitchen			
Batch No. :			
Date of Manufacture : 19 Dec 2022			
Delivery Note No : TSSC: PR-22201204			
Country of Origin : United Arab Emirates			
Date of arrival on site : 20 Dec 2022			
Storage Location : KCE Store			
Compliance Statement: The contractor hereby confirms that the Material offered for inspections are ready and compliance with the Contract Documents. Adequate HSE measures are in place for storage.			
Inspection Report :			
Physical Damage ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO
Details Given Above Correct ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO
Conform with Approved submission ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO
Details :			
Remarks :			
Engineer's Comments :			
The above material has been inspected on site and found at time of inspection to be :			
Satisfactory	<input type="checkbox"/>	Unsatisfactory	<input type="checkbox"/>
Inspected by :		Date :	
<input type="checkbox"/> Approved	<input type="checkbox"/> Approved with Comments	<input type="checkbox"/> Revise & Resubmit	<input type="checkbox"/> Rejctd
BSBG Comment		Refer Fondue comment on the Aconex Document Review History Status "D"	
Name:	Signature :	FAA/GD	Date : 06.01.2023
Project Manager's Approval			
Name:	Signature :	Date :	

Project : The Residences Dorchester Collection by Omniyat, Business Bay, Dubai
 Package : Supply & Installation of Kitchen Equipment
 Client : Sky Places Real Estate Development LLC

Sub Contractor : TSSC Kitchen & Laundry Equipment Trading
 Document Ref. : TDC/KE/23L22/MIR005/S001
 Date : 23rd December 2022

Schedule of Kitchen Equipment for MIR # 005

Item No	Qty	Unit	Area / Item Description	Manufacturer	Model	Origin	Comments
BASEMENT 1							
HK.00 HOT KITCHEN							
HK.30	1	No.	Hood type: Steam - Wall mount - Wall type - Single skin section(s) Hood dimension: 1500 (L) x 1250 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 2,425 m ³ /h Make-up air by Ginox: 0 m ³ /h - none Lights: No, 0 unit(s) Drain type: Not applicable	GINOX Hoods	CUSTOM HOOD	U. A. E.	
WW.00 STAFF DINING ROOM WAREWASH							
WW.07	1	No.	Hood type: Steam - Wall mount - Wall type - Single skin section(s) Hood dimension: 1140 (L) x 1050 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 825 m ³ /h Make-up air by Ginox: 0 m ³ /h - none Lights: No, 0 unit(s) Drain type: Not applicable	GINOX Hoods	CUSTOM HOOD	U. A. E.	
GROUND FLOOR							
BQ.00 BANQUET KITCHEN AND SUPPORT							
BQ.48	1	No.	Hood type: Steam - Wall mount - Wall type - Single skin section(s) Hood dimension: 2000 (L) x 1200 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air - m ³ /h Make-up air by Ginox: 0 m ³ /h - none Lights: No, 0 unit(s) Drain type: Not applicable	GINOX Hoods	CUSTOM HOOD	U. A. E.	
LEVEL 2							
LL.00 LOBBY LOUNGE SUPPORT PANTRY							
LL.22	1	No.	Hood type: Steam - Wall mount - Wall type - Single skin section(s) Hood dimension: 1000 (L) x 1000 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 1350 m ³ /h Make-up air by Ginox: 0 m ³ /h - none Lights: No, 0 unit(s) Drain type: Not applicable	GINOX Hoods	CUSTOM HOOD	U. A. E.	

Schedule of Kitchen Equipment for MIR # 005

Document Ref. : TDC/KE/23L22/MR005/S001



MATERIAL INSPECTION REQUEST

OMNIYAT



CONTRACT : Plot 18 by Dorchester Collection	CONTRACT No: 201A22002
Requested By : TSSC Kitchen & Laundry ET LLC MIR Ref. No.: TSS-AX-MR-GF-00003	Revision No: 0
Signature :	Subcontractors No. 12 Date : 12/9/2022
Discipline : TSSC EQUIPMENT TRADING - LLC STRU ARCH MEP	<input checked="" type="checkbox"/> OTHERS
The following items are ready to inspect on 12/12/2022 by 10:00 am/pm	
Subcon No. F015/15.1.13/31649/PMTDG/0321 / Variation Order No.1 dated 17/May/2022	
Material Description: Kitchen Hood & Modulating Damper	
Material Submittal Ref: TSS-AX-MT-ML-00002 & Aconex REFERENCE NUMBER : TSSC-TRANSMIT-000012	
Specification No : BQ.08, BQ.08.1, BQ.13, BQ.13.1	
Quantity : 4 Nos.	
Attached :	<input checked="" type="checkbox"/> Checklist <input type="checkbox"/> Sketches <input checked="" type="checkbox"/> Others <input type="checkbox"/> Delivery Note
Manufacturer's Details :	
Manufacturer : M/s Ginox Swiss Kitchen	
Batch No. :	
Date of Manufacture : 23/11/2022	
Delivery Note No : TSSC: PR-222311069	
Country of Origin : United Arab Emirates	
Date of arrival on site : 23/11/2022	
Storage Location : KCE Store	
Compliance Statement: The contractor hereby confirms that the Material offered for inspections are ready and compliance with the Contract Documents. Adequate HSE measures are in place for storage.	
Inspection Report :	
Physical Damage ?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Details Given Above Correct ?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Conform with Approved submission ?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Details :	
Remarks :	
Engineer's Comments :	
The above material has been inspected on site and found at time of inspection to be :	
Satisfactory <input type="checkbox"/>	Unsatisfactory <input type="checkbox"/>
Inspected by : Date :	
<input type="checkbox"/> Approved <input type="checkbox"/> Approved with Comments <input type="checkbox"/> Revise & Resubmit <input type="checkbox"/> Rejected	
Fondu will review all equipment once installation is complete	
Refer Fondu comments GD-14.12.2022	
Name: George K	Signature :
Date : 07-12-2022	
Project Manager's Approval	
Name:	Signature :
Date :	

Project : The Residences Dorchester Collection by Omiyat, Business Bay, Dubai
 Package : Supply & Installation of Kitchen Equipment
 Client : Sky Palaces Real Estate Development LLC

Sub Contractor : TSSC Kitchen & Laundry Equipment Trading
 Document Ref. : TDC/KE/09122/MIR003/S001
 Date : 9th December 2022


Schedule of Kitchen Equipment for MIR # 003

Item No	Qty	Unit	Area / Item Description	Manufacturer	Model	Origin	Comments
GROUND FLOOR							
BQ.00 BANQUET KITCHEN AND SUPPORT							
BQ.08	1	No.	Hood type: UV - Wall mount - Wall type - Double Skin Hood dimension: 3850 (L) x 1550 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 3269 m ³ /h Make-up air by Ginox: 0 m ³ /h - Hood front Lights: Fluorescent panel, 2 unit(s) Drain type: Not applicable Incl. 3 x Automated Dampers, 1 x Touchpad (On/Off Control)	GINOX Hoods	CUSTOM HOOD	U.A.E.	
BQ.08.1	1	No.	Incl. 3 x Automated Dampers, 1 x Touchpad (On/Off Control)	GINOX Hoods	CUSTOM	U.A.E.	
BQ.13	1	No.	Hood type: UV - Wall mount - Wall type - Double skin Hood dimension: 2050 (L) x 1300 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 1339 m ³ /h Make-up air by Ginox: 0 m ³ /h - Hood front Lights: Fluorescent panel, 1 unit(s) Drain type: Not applicable	GINOX Hoods	CUSTOM HOOD	U.A.E.	
BQ.13.1	1	No.	Incl. 2 x Automated Dampers, 1 x Touchpad (On/Off Control)	GINOX Hoods	CUSTOM	U.A.E.	

Received Goods in Good Condition

Receivers Name, Sign and Stamp

This Certifies that the equipment as listed above have been received satisfactorily and are acceptable to the client except for items noted otherwise above



تي اس اس سي لتجارة معدات المطابخ وتنظيف الملابس - شذ ٥٥
TSSC Kitchen & Laundry Equipment Trading LLC

DELIVERY NOTE

Customer: Sky Palaces Real Estate Development LLC P.O. Box 12501 Dubai, United Arab Emirates							Ship to: The Residences Dorchester Collection by Omniyat, Business Bay, Dubai	Date 23/Nov/22	Page # 1 of 1	PR 22231106
							LPO # Salesman Currency	JFA AED		
SL No.	BOQ ITEM No:	Manufacturer	MODEL	Description of the Item			U/M	Qty		
1	BQ.08	GINOX Hoods	CUSTOM HOOD	Hood type: UV - Wall mount - Wall type - Double skin Hood dimension: 3850 (L) x 1550 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 3269 m ³ /h Make-up air by Ginox: 0 m ³ /h - Hood front Lights: Fluorescent panel, 2 unit(s) Drain type: Not applicable			No	1		
2	BQ.08.1	GINOX Hoods	CUSTOM	Incl. 3 x Automated Dampers, 1 x Touchpad (On/Off Control)			No	1		
3	BQ.13	GINOX Hoods	CUSTOM HOOD	Hood type: UV - Wall mount - Wall type - Double skin Hood dimension: 2050 (L) x 1300 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 1339 m ³ /h Make-up air by Ginox: 0 m ³ /h - Hood front Lights: Fluorescent panel, 1 unit(s) Drain type: Not applicable			No	1		
4	BQ.13.1	GINOX Hoods	CUSTOM	Incl. 2 x Automated Dampers, 1 x Touchpad (On/Off Control)			No	1		
Received Goods in Good Condition for TSSC Kitchen & Laundry Equipment Trading LLC.										
J V										
Receivers Name, Sign and Stamp										
Contact No.: Mr. Vivek 050 6521454 (PM) Mr. Vinu 056 1169938 (Site In Charge)										
Date Received:										



P.O. Box 69, Dubai, United Arab Emirates Tel.: +971 4 343 1100

Fax: +971 4 343 8226 @ Email: tssc@eim.ae www.tsscdubai.com