



DGBR COMPLIANCE	COMMENT
304.05 Hardscape	Over 50% of the hardscape is shaded or has a SRI value of 29.
301.02 Enabled Access	The design is full accessible with ramps and level access for disabled users as per DM Regs.