



MATERIAL INSPECTION REQUEST

OMNIYAT

BSBG

CONTRACT : Plot 18 by Dorchester Collection		CONTRACT No: 201A22002	
Requested By : TSSC Kitchen & Laundry ET LLC		MIR Ref. No.: TSS-AX-MR-ET-00007	
Signature : 		Revision No: 0	
Discipline : <input type="checkbox"/> STRU <input checked="" type="checkbox"/> ARCH <input checked="" type="checkbox"/> MEP <input type="checkbox"/> OTHERS		Subcontractors No. TSSC/MIR007	
Date : 24 Feb 2022			
The following items are ready to inspect on 27 Feb 2023 by 10:00 am/pm			
Subcon No. F015/15.1.13/31649/PMTDG/0321/ Variation Order No.1 dated 17/May/2022			
Material Description: Kitchen Hood & Modulating Damper			
Material Submittal Ref: TSS-AX-MT-ML-00002 & Aconex REFERENCE NUMBER : TSSC-TRANSMIT-000012			
Specification No : HK.12, HK.12.1, LL.49, LL.49.1, RS.27, RS.27.1, ADK.49, ADK.49.1			
Quantity : 8 Nos.			
Attached : <input checked="" type="checkbox"/> Checklist <input type="checkbox"/> Sketches <input type="checkbox"/> Others <input checked="" type="checkbox"/> Delivery Note			
Manufacturer's Details :			
Manufacturer : M/s Ginox Swiss Kitchen			
Batch No. :			
Date of Manufacture : 6 Feb 2023			
Delivery Note No : TSSC: PR-23020051			
Country of Origin : United Arab Emirates			
Date of arrival on site : 08/02/20223			
Storage Location : KCE Store			
Compliance Statement: The contractor hereby confirms that the Material offered for inspections are ready and compliance with the Contract Documents. Adequate HSE measures are in place for storage.			
Inspection Report :			
Physical Damage ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO
Details Given Above Correct ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO
Conform with Approved submission ?		<input type="checkbox"/> YES	<input type="checkbox"/> NO
Details :			
Remarks :			
Engineer's Comments :			
The above material has been inspected on site and found at time of inspection to be :			
Satisfactory <input type="checkbox"/>		Unsatisfactory <input type="checkbox"/>	
Inspected by : Date :			
<input type="checkbox"/> Approved <input type="checkbox"/> Approved with Comments <input type="checkbox"/> Revise & Resubmit <input type="checkbox"/> Rejected			
Fondue will inspect all equipment once installation is complete			
Name: George K		Signature : 	Date : 03.03.2023
Project Manager's Approval			
Name:		Signature :	Date :

Project : The Residences Dorchester Collection by Omniyat, Business Bay, Dubai				Sub Contractor : TSSC Kitchen & Laundry Equipment Trading			
Package : Supply & Installation of Kitchen Equipment				Document Ref. : TDC/KE/24B23/MIR007/S001			
Client : Sky Palaces Real Estate Development LLC				Date : 24 th February 2022			
Schedule of Kitchen Equipment for MIR # 007							
Item No	Qty	Unit	Area / Item Description	Manufacturer	Model	Origin	Comments
BASEMENT 1							
HK.00 HOT KITCHEN							
HK.12	1	No.	Hood type: UV - Island mount - Island type - Double skin Hood dimension: 6055 (L) x 2975 (W) x 600 (H) , in 2 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 16,085 m3/h Make up air by Ginox: 12,672 m3/h - Hood front	GINOX Hoods	CUSTOM HOOD	U. A. E.	
HK.12.1	1	No.	Incl. 6 x Automated Dampers, 1 x Touchpad (On/Off Control)	GINOX Hoods	CUSTOM	U. A. E.	
LEVEL 2							
LL.00 LOBBY LOUNGE SUPPORT PANTRY							
LL.49	1	No.	Hood type: UV - Wall mount - Wall type - Double skin Hood dimension: 3800 (L) x 1265 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 3700 m3/h Make up air by Ginox: 2145 m3/h - Hood front	GINOX Hoods	CUSTOM HOOD	U. A. E.	
LL.49.1	1	No.	Incl. 3 x Automated Dampers, 1 x Touchpad (On/Off Control)	GINOX Hoods	CUSTOM	U. A. E.	
LEVEL 4							
RS.00 ROOM SERVICE BOH							
RS.27	1	No.	Hood type: UV - Wall mount - Wall type - Double skin Hood dimension: 4500 (L) x 1050 (W) x 600 (H) , in 2 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 4310 m3/h Make up air by Ginox: 2664 m3/h - Hood front	GINOX Hoods	CUSTOM HOOD	U. A. E.	
RS.27.1	1	No.	Incl. 4 x Automated Dampers, 1 x Touchpad (On/Off Control)	GINOX Hoods	CUSTOM	U. A. E.	
ADK.00 ALL DAY DNING KITCHEN							


Schedule of Kitchen Equipment for MIR # 007

Item No	Qty	Unit	Area / Item Description	Manufacturer	Model	Origin	Comments
ADK.49	1	No.	Hood type: Water Mist Wash - Island mount - Island type - Double skin Hood dimension: 3950 (L) x 2350 (W) x 600 (H) , in 2 section(s) Material: AISI 304, 1.2 mm - Brush Finish Exhaust air: 10670 m ³ /h	GINOX Hoods	CUSTOM HOOD	U. A. E.	
ADK.49.1	1	No.	Incl. 4 x Automated Dampers, 1 x Touchpad (On/Off Control)	GINOX Hoods	CUSTOM	U. A. E.	

Received Goods in Good Condition

Receivers Name, Sign and Stamp

This Certifies that the equipment as listed above have been received satisfactorily and are acceptable to the client except for items noted otherwise above

**TSSC**

شركة التوريد والخدمات الفنية (ذ.م.م.)
Technical Supplies & Services Co. LLC

DELIVERY NOTE

Customer:		Ship to:		Page #	1 of 1
Sky Palaces Real Estate Development LLC		The Residences Dorchester Collection by Omniyat, Business Bay, Dubai		PR	PR-23020051
P.O. Box 12501 Dubai, United Arab Emirates				Date	08/Feb/23
				LPO #	
				Salesman	JFA
				Currency	AED

SL No.	BOQ ITEM No:	Manufacturer	MODEL	Description of the Item	U/M	Qty
1	HK.12	GINOX Hoods	CUSTOM HOOD	Hood type: UV - Island mount - Island type - Double skin Hood dimension: 6055 (L) x 2975 (W) x 600 (H) , in 2 section(s) Material: AISI 304, 1.2 mm - Brush Finish	No	1
2	HK.12.1	GINOX Hoods	CUSTOM	Incl. 6 x Automated Dampers, 1 x Touchpad (On/Off Control)	No	1
3	LL.49	GINOX Hoods	CUSTOM HOOD	Hood type: UV - Wall mount - Wall type - Double skin Hood dimension: 3800 (L) x 1265 (W) x 600 (H) , in 1 section(s) Material: AISI 304, 1.2 mm - Brush Finish	No	1
4	LL.49.1	GINOX Hoods	CUSTOM	Incl. 3 x Automated Dampers, 1 x Touchpad (On/Off Control)	No	1
5	RS.27	GINOX Hoods	CUSTOM HOOD	Hood type: UV - Wall mount - Wall type - Double skin Hood dimension: 4500 (L) x 1050 (W) x 600 (H) , in 2 section(s) Material: AISI 304, 1.2 mm - Brush Finish	No	1
6	RS.27.1	GINOX Hoods	CUSTOM	Incl. 4 x Automated Dampers, 1 x Touchpad (On/Off Control)	No	1
7	ADK.49	GINOX Hoods	CUSTOM HOOD	Hood type: Water Mist Wash - Island mount - Island type - Double skin Hood dimension: 3950 (L) x 2350 (W) x 600 (H) , in 2 section(s) Material: AISI 304, 1.2 mm - Brush Finish	No	1
8	ADK.49.1	GINOX Hoods	CUSTOM	Incl. 4 x Automated Dampers, 1 x Touchpad (On/Off Control)	No	1

Received Goods in Good Condition

for TSSC Kitchen & Laundry Equipment Trading LLC.

Receivers Name, Sign and Stamp

Contact No.: Mr. Vinu 056 1169938 (Site In Charge)

Date Received:



ص.ب. ٦٩، دبي، ا.ع.م.
فاكس: +٩٧١ ٤ ٣٤٣٨٢٢٦ | هاتف: +٩٧١ ٤ ٣٤٣١١٠٠ | البريد الإلكتروني: tssc@eim.ae | الموقع الإلكتروني: www.tsscdubai.com

P.O. Box 69, Dubai, United Arab Emirates
Tel.: +971 4 3431100 | Fax: +971 4 3438226 | Email: tssc@eim.ae | www.tsscdubai.com



Page 1 of 1

DOCUMENT COVER SHEET



Project: Plot 18, Plot BB.B03.018, Business Bay, Dubai	Contractor / Package Roberts-Pizzarotti JV/ Main Contract	Document No. TSS-AX-SA-ML-00002	Revision 00
To:	Consultants/ Employer's Representative	Submittal Issue Date:	13-Sept-2021


Discipline:
☐ Architectural
☐ Structural
☐ Structural Steel
☐ Electrical
☐ Plumbing
☐ Interior Design
☐ Infrastructure
☐ Landscape
☐ Mechanical
☐ Survey
☐ Waterproofing
☐ Ceiling
☐ Others (.....)

Description: - Material Submittal for Extract Canopies	Submission Type <input checked="" type="checkbox"/> Material Submission <input type="checkbox"/> Manual <input type="checkbox"/> Calculation <input type="checkbox"/> Report <input type="checkbox"/> Pre-Qualification <input type="checkbox"/> Method Statement
Location of Use: - Level 4; Level2, Basement 1, Ground floor	Contract Specification Clause Ref: - NA

SPECIFIED	PROPOSED [NB: For alternative materials a Compliance Report must be provided]
MFR AGENT MAKE/ MODEL	As per attached compliance statement schedule ref.: DCD-P1-HCF/KLE/29H21A/VC/MTS002
MFR AGENT MAKE/ MODEL	As per attached compliance statement schedule ref.: DCD-P1-HCF/KLE/29H21A/VC/MTS002


Roberts Review Comments: Name..... Signature..... Date.....	Digital Stamping
---	-------------------------

Consultant Review Comments: Proposed Brand and general details approved subject to review and approval of itemized shop drawings and SEFR calculations. Hanging details to be submitted along with shop dwgs which need to be coordinated at site. Name <u>George K</u> Signature  Date <u>15-11-2021</u>	Digital Stamping 
---	--


Lead Consultant Review Comments: - Refer FND comments & address accordingly - Renewed commercial trade license copy to be provided Name <u>GD</u> Signature..... Date <u>16.11.2021</u>	Digital Stamping 
---	--

Employer's Representative (Omnivat) Review Comments: Name..... Signature..... Date.....	Digital Stamping
---	-------------------------

Technical drawings




Wall mounted type



Island mounted type

Technical specifications

Material	SS AISI 304 brush finish 1.2mm thickness as standard
Lighting	Fluorescent light LED panel or LED spot 600 lux at working surface
UV lamps capacity	500 to 3'000 CMH
Power supply	220-240V 50-60Hz
Maximum pressure drop	250 Pa



Pressure drop curve - Baffle filter 500 x 500 mm

Advantages

Welded construction, made entirely of AISI 304 stainless steel, brush finish, meeting the highest standards of hygiene and durability

Customization

Fully modular construction that can be adapted to any site condition

Lighting

Low profile, high light output, energy efficient fluorescent or LED lights, NSF, UL listed and NFPA96 rated

Filtration

Stainless steel UL listed baffle filter in compliance with NFPA96, easily removable with superior grease capture UV-C filtration with high energy UV-C lamps, breaking down smaller particles and odor molecules

Certifications



An active associative presence



Maintenance

Easily accessible grease collection channels, easy cleaning, simplifying maintenance

Installation

Easily attached to slabs by thread rods. Simple and fast connection of hood sections by fasteners

Delivery

Hood delivered in one piece or to be assembled on site, simplifying access to installation areas

UV safety

Safety interlocks checking the correct filter position and fan operation. An extra mesh is added at the back of each UV certified baffle filter to increase safety standards.

Options

- ecoAzur®: demand control for kitchen ventilation for financial, energy and environmental savings
- PulseAir : air induction for increased hood efficiency and lower extraction air flows

GINOX reserves the right to change specifications without notice.

GINOXGROUP.COM



EXPERTISE

ECOLOGY

DESIGN



HOOD

UVAIR
WITH MAKE-UP AIR

Product brochure