



SPACE DESIGN LOAD SUMMARY

Studio 1_0

Level: Level 0 · Internal condition: TM59_Bathroom

Test Project
Project no. P-001
Prepared by SAM Tests
2026-09-25

DESIGN CRITERIA

	Heating	Cooling
Room set point	16.0 °C	26.0 °C
Outdoor dry bulb	-4.9 °C	28.4 °C
Outdoor RH (coincident)	90 %	40 %

ROOM HUMIDITY

Humidification set point	—
lower RH limit	
Dehumidification set point	—
upper RH limit	

SIZING (TAS DESIGN LOADS)

	Heating	Cooling
Design load	1,368 W	0 W
Design load per area	263.1 W/m ²	0.0 W/m ²
Sizing multiplier	not set	not set

Design loads: from Tas sizing — date/currency not recorded

HEATING

Peaks not recorded: the heating results pre-date the design-day and full-year peak record. Re-run the simulation to report the heating peaks.

COOLING

Peaks not recorded: the cooling results pre-date the design-day and full-year peak record. Re-run the simulation to report the cooling peaks.

RESULTS

	Heating	Cooling
Status	Peaks not recorded	Peaks not recorded
Result source	—	—
Read into model	—	—
Matches current model	—	—

Peak hour: a design-day peak has an hour of the day only, no date; a full-year peak shows day and hour, no year.
Design loads (sizing) and simulated peaks are shown side by side for information; no acceptance rule is applied.