

DESIGN CRITERIA

	Heating	Cooling
Room set point	16.0 °C	26.0 °C
Outdoor dry bulb	-4.9 °C	28.4 °C
Outdoor RH (coincident)	90 %	40 %

ROOM HUMIDITY

Humidification set point	—
lower RH limit	
Dehumidification set point	—
upper RH limit	

SIZING (TAS DESIGN LOADS)

	Heating	Cooling
Design load	1,368 W	0 W
Design load per area	263.1 W/m ²	0.0 W/m ²
Sizing multiplier	not set	not set

Design loads: from Tas sizing — date/currency not recorded

HEATING

Ambiguous: more than one heating result records peaks, and none is chosen. Select the result source to report.

COOLING

Design day	Leeds_TRY ANN CLG 0% CONDS DB=>GRad	
	Design day	Full year
Peak load	0 W	0 W
0 W: no cooling demand on the design day or over the full year, so no peak hour, room or outdoor state or component breakdown.		

RESULTS

	Heating	Cooling
Status	Ambiguous: none chosen	Available
Result source	—	Tas
Read into model	—	27 Aug 2026 18:38
Matches current model	—	not recorded

Peak hour: a design-day peak has an hour of the day only, no date; a full-year peak shows day and hour, no year.
Design loads (sizing) and simulated peaks are shown side by side for information; no acceptance rule is applied.