NTNU
Norwegian University of
Science and Technology



Identification of turbine dynamics using PMUs

Sigurd Hofsmo Jakobsen[1], Xavier Bombois[2], Kjetil Uhlen[1]

[1]Norwegian university of technology and science Department of electrical engineering

[2]Ecole Centrale de Lyon Laboratoire Ampère

June 25, 2018

Outline



Background

Previous work

Validation of the approach

Results

Conclusions and further work

Frequency quality in the Nordics

- From 2008 the time the frequency has been outside its allowed band has increased
- The performance of hydro turbine governors play an important role



New requirements on FCR due to frequency quality

- Nordic TSOs are developing new requirements on FCR
- This includes offline testing and verification of performance



Idea on monitoring the FCR online

- Less intrusive



Idea on monitoring the FCR online

- Less intrusive
- The system is dynamic



Challenges in operation

- Towards 100% renewable electricity generation
  - Larger variability
  - More uncertainty
  - Increasing complexity



Figure: Present and future energy mix[Statnett]

Challenges in operation

- Towards 100% renewable electricity generation
  - Larger variability
  - More uncertainty
  - Increasing complexity
- More dynamics



Figure: Present and future energy mix[Statnett]

Challenges in operation

- Towards 100% renewable electricity generation
  - Larger variability
  - More uncertainty
  - Increasing complexity
- More dynamics
- Less time for actions



Figure: Present and future energy mix[Statnett]

Challenges in operation

- Towards 100% renewable electricity generation
  - Larger variability
  - More uncertainty
  - Increasing complexity
- More dynamics
- Less time for actions
- **Hydropower** is the main resource for balancing



Figure: Present and future energy mix[Statnett]

Research question

1. Do the transmission system operator (TSO) know whether or not the hydropower plants deliver the FCR they are supposed to?

Research question

1. Do the transmission system operator (TSO) know whether or not the hydropower plants deliver the FCR they are supposed to?
2. Can the TSO measure it online?

Outline



Background

Previous work

Validation of the approach

Results

Conclusions and further work

Previous articles

- Governor dynamics were identified using the ARX model structure



Previous articles

- Governor dynamics were identified using the ARX model structure
- Governor dynamics were identified using time domain vector fitting



Previous articles

- Governor dynamics were identified using the ARX model structure
- Governor dynamics were identified using time domain vector fitting
- There are also other papers in the literature using other methods for online identification, however, mostly relying on data from disturbance recordings.



Question leading to this work

- Why do we get different results?



Question leading to this work

- Why do we get different results?
- The signals we use are corrupted by noise.



Question leading to this work

- Why do we get different results?
- The signals we use are corrupted by noise.
- From system identification we have that the error will be asymptotic normally distributed

$$\sqrt{N}(\hat{\theta}_n - \theta^*) \in AsN(0, P_\theta)$$

Question leading to this work

- Why do we get different results?
- The signals we use are corrupted by noise.
- From system identification we have that the error will be asymptotic normally distributed
- However, first we need to prove the identifiability of the system

True system: $\mathcal{S}$

x: unbiased

x: biased



Outline

Background

Previous work

Validation of the approach

Results

Conclusions and further work

System identification basic

- Assume that a data set $Z^N = \{u[n], y[n] | n = 1 \dots N\}$ has been collected.
- The dataset Z^N is assumed generated by

$$\mathcal{S} : y[n] = G_0(z, \theta_0)u[n] + H_0(z, \theta_0)e[n] \tag{1}$$



- Using the data set Z^N we want to find the parameter vector θ^N minimizing

$$\hat{\theta}_N = \arg\min_{\theta} \frac{1}{N} \sum_{n=1}^{N} \epsilon^2(n, \theta) \tag{2}$$

Modeling used for the validation

- The system we are identifying



Modeling used for the validation

- The system we are identifying
- We use a small power system



Modeling used for the validation

- The system we are identifying
- We use a small power system
- We use a dc power flow



Modeling used for the validation

- The system we are identifying
- We use a small power system
- We use a dc power flow
- This results in the following block diagram



Outline

Background

Previous work

Validation of the approach

Results

Conclusions and further work

Results from the theoretical validation

- A consistent estimate of the closed loop transfer function of the turbine and electromechanical dynamics can be obtained by using:

Results from the theoretical validation



- A consistent estimate of the closed loop transfer function of the turbine and electromechanical dynamics can be obtained by using:
  - Measured PMU frequency as the output $u[n]$

Results from the theoretical validation

- A consistent estimate of the closed loop transfer function of the turbine and electromechanical dynamics can be obtained by using:
  - Measured PMU frequency as the output $u[n]$
  - Measured PMU power as the input $y[n]$

Results from the theoretical validation

- A consistent estimate of the closed loop transfer function of the turbine and electromechanical dynamics can be obtained by using:
  - Measured PMU frequency as the output $u[n]$
  - Measured PMU power as the input $y[n]$
- The proof was done with the following assumptions.
  - The system is excited by a load acting as a filtered white noise process
  - The measurement error of the electrical power is negligible.
  - The measured frequency is a good estimate of the generator speed.

Comparison of bode plots from simulation



Model obtained using PMU data



Whiteness test on model identified using PMU data



Outline

Background

Previous work

Validation of the approach

Results

Conclusions and further work

Conclusions and further work

- It is indeed possible to identify the turbine dynamics(closed loop with electromechanical dynamics) using PMU measurements.
- The results from real life measurements seem reasonable and have low variance, however, they should be further validated.
- The assumptions should be further investigated

Thanks for your attention.