

OEM Manual Excerpt - Package Boiler B-12

OEM Manual Excerpt - Package Boiler Model FB-2200

Applicable Asset: B-12

Section 3: Relief Valve Maintenance

The pressure relief valve (site tag V-045) must be bench tested at the frequency required by local regulation (see REG-052) and the certificate retained on file for the life of the boiler's operating permit. Operating the boiler without current relief valve test evidence is not permitted under REG-014.

Section 6: Emergency Shutdown (ESD) Testing

Functional ESD tests should be performed per REG-045 and logged alongside the relief valve certificate for audit purposes.