

Distinctive Electrical Services Corp.

Licensed • Bonded • Insured Electrical Contractors | Chicago, Illinois

Subject: Clarification on Breaker Count – 7919 S. Dorchester

To Whom It May Concern,

This letter clarifies the existing electrical panel conditions at the above property. While the previous panel contained numerous breakers, most were not actively serving loads. Many breaker positions had no conductors terminated, indicating they were unused.

Based on field conditions, it is our professional assessment that the home was previously configured for electric appliances and later converted to gas. During that transition, original circuits were abandoned, leaving unused breakers in place.

At the start of our work, the active system consisted of:

- Four (4) general circuits
- One (1) garage circuit
- One (1) 240V air conditioning circuit

As part of the current electrification scope, we installed new dedicated 240V circuits for:

- Heat strips • Air handler • Heat pump • Dryer • Range/Oven • Water heater

All circuits were installed per applicable code with proper breaker sizing and conductor installation.


Conclusion: The reduction in breaker count reflects removal of unused, non-terminated breakers—not active circuits. The current panel accurately represents the installed, code-compliant loads.

We are available for further clarification or walkthrough if needed.

Respectfully,

David Johnson

Distinctive Electrical Services Corp.



4/15/2026