

26-0024: UTSW CUH 4.219 Microbiology Lab
6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Source Building Group
651 East Debbie Lane, BLDG 200, Mansfield, TX 76063, United States of America
Sunny Fung | Estimator / Quantity Surveyor | +1 469-835-7725 | sfung@sourcebuild.net

Line Items

Description	Quantity	Unit Cost	Total Cost
BID FORM (8/28):			
* Plumbing Demo			\$
* Plumbing			\$
Base Bid			\$0

Alternates

OWNER BID ALTERNATES:	
* Alternate 4: AquaTap RO Water System	\$
:	
SCOPE ALTERNATES:	
* None at this time.	\$

Inclusions

Mark "yes" to all yes/no questions »

* MATERIAL	☐ Yes ☐ No
* INSTALLATION	☐ Yes ☐ No

SPECIFICATION(S) ACKNOWLEDGEMENT:	
* 22 00 13 - PLUMBING DESIGN REQUIREMENTS	☐ Yes ☐ No
* 22 05 23 - VALVES FOR PLUMBING PIPING	☐ Yes ☐ No
* 22 05 29 - HANGERS FOR PLUMBING PIPING	☐ Yes ☐ No
* 22 07 00 - PLUMBING INSULATION	☐ Yes ☐ No
* 22 11 16 - DOMESTIC WATER PIPING	☐ Yes ☐ No
* 22 11 19 - DOMESTIC WATER PIPING SPECIALTIES	☐ Yes ☐ No
* 22 13 16 - STORM AND SANITARY WASTE AND VENT PIPING	☐ Yes ☐ No
* 22 13 19 - SANITARY WASTE PIPING SPECIALTIES	☐ Yes ☐ No
* 22 43 00 - HEALTH CARE PLUMBING FIXTURES	☐ Yes ☐ No
* 22 60 00 - MEDICAL GAS PIPING SYSTEMS	☐ Yes ☐ No
* 22 60 13 - MEDICAL GAS SYSTEMS STARTUP AND CERTIFICATION	☐ Yes ☐ No
* 22 62 19 - MEDICAL GAS AND VACUUM SYSTEMS	☐ Yes ☐ No
* 22 67 13 - PURIFIED WATER SYSTEM AND PIPING	☐ Yes ☐ No

SCOPE OF WORK:	
Plumbing Demo:	

26-0024: UTSW CUH 4.219 Microbiology Lab
6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* PER PLAN PD-110 PLUMBING DEMO PLAN LEVEL 03, KEYNOTE 1-2 ☐ Yes ☐ No

* PER PLAN PD-111 PLUMBING DEMO PLAN LEVEL 04, KEYNOTE 1-9 ☐ Yes ☐ No

Lab Sink Schedule (Owner Furnished Vendor Installed):

* SK1, 2,3 and 5 Stainless Steel Lab Sink ☐ Yes ☐ No

* SK 4 and 4A Handwashing Sink ☐ Yes ☐ No

Lab Fixture & Fittings Schedule (Owner Furnished Vendor Installed):

* CO2 CARBON DIOXIDE ☐ Yes ☐ No

* DI (2, DI2, DI3) DEIONIZED WATER ☐ Yes ☐ No

* EW2 EYE WASH ☐ Yes ☐ No

* HCW PORTABLE HOT AND COLD WATER ☐ Yes ☐ No

* O2 OXYGEN ☐ Yes ☐ No

* SG1 MIXED GAS ☐ Yes ☐ No

Plumbing Schedule:

* MGM-1 MEDICAL GAS MANIFOLD ☐ Yes ☐ No

* ZVB-3 MEDICAL GAS EQUIPMENT ☐ Yes ☐ No

* SHOCK ARRESTOR ☐ Yes ☐ No

* P-14C FLOOR SINK ☐ Yes ☐ No

* P-20 EMERGENCY SHOWER EYE FACE WASH SAFETY STATION ☐ Yes ☐ No

* P-24/P-24A LAB SINK S.S. ☐ Yes ☐ No

* P-25/P-25A WALL HUNG SS SINK ☐ Yes ☐ No

* P-51 FLOOR DRAIN EQUIPMENT ROOMS ☐ Yes ☐ No

Plumbing Works:

* Piping & Fittings ☐ Yes ☐ No

* Sanitary Sewer & Vent Piping & Fittings ☐ Yes ☐ No

* Domestic Water Piping & Fittings ☐ Yes ☐ No

* Gas Piping & Fittings ☐ Yes ☐ No

* Plumbing Fixtures per schedule and plans. ☐ Yes ☐ No

* Pipe Insulation ☐ Yes ☐ No

* Hangers and Supports ☐ Yes ☐ No

* Identification ☐ Yes ☐ No

General:

* Trenching & Backfill ☐ Yes ☐ No

* Trade Permit (*Building Permit by GC) ☐ Yes ☐ No

* Penetration Firestopping ☐ Yes ☐ No

* Div 08: Access Doors & Panels Furnish Material (Coordinate with Drywall Subcontractor for installation and other trades) ☐ Yes ☐ No

PROJECT SPECIFIC SCOPE | NOTES:

* None at this time. ☐ Yes ☐ No

:

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Q&A Project Specific Items as of 8/27/26:**Q25. Level 3 RCP:**

* Q: Please provide a reflected ceiling plan for Level 3 where above-ceiling plumbing work is required.

Asked 8/18/2026 at 1:57 PM CDT

☐ Yes ☐ No

A: The overall Level 3 reflected ceiling plan is provided for reference only. The contractor is responsible for field verification and confirmation of existing conditions.

Answered 8/26/2026 at 9:42 AM CDT by Amanda Usrey

Q30. Laboratory Casework:

* Q: Please confirm definitively whether laboratory casework, laboratory sinks, laboratory accessories, and laboratory service fixtures are by Owner, or if they should be part of Contractor's proposal.

Asked 8/18/2026 at 1:47 PM CDT

☐ Yes ☐ No

A: Casework will be provided by the Owner. The contractor is responsible for all utility connections.

Answered 8/26/2026 at 9:44 AM CDT by Amanda Usrey

Q107. Deck Mounted Item Clarification:

* Q: Elevations C4 and D4 on sheet Q-210 show an item deck mounted near the sink fixture that is not called out. The sinks at these locations are not states to receive an eyewash. Please clarify what the item in the elevations is intended to represent.

Asked 4/15/2026 at 3:15 PM CDT

☐ Yes ☐ No

A: Fixture is to be DI / RO water fixture. I.E. tied to the AquaTAP alternative. Refer to Laboratory sink schedule for clarification.

Answered 5/5/2026 at 3:51 PM CDT by Marcus Howard

Q112. Eyewash EW2 Clarification:

* Q: Laboratory Fixture & Fittings Schedule on sheet Q-001 lists eyewash EW2 that is not shown on the plans. The only deck mounted eyewash is at single SK-4A locations. Please confirm this meets with intent.

Asked 4/15/2026 at 3:13 PM CDT

☐ Yes ☐ No

A: This is in alignment with the design intent.

Answered 5/5/2026 at 3:41 PM CDT by Marcus Howard

Q113. Lab Sinks w/ Eyewash:

* Q: Plumbing Fixture Connection Schedule on sheet P-000 notes both P-25 and P-25A sinks to have eyewash mounted on backsplash; however, only fixture P-25A provides an emergency fixture model. Additionally, corresponding fixture SK-4 on sheet Q-001 does not indicate an eyewash. Please confirm only fixture P-25A is to include eyewash, and the "eyewash" indicated for fixture P-25 is an error.

Asked 4/15/2026 at 3:13 PM CDT

☐ Yes ☐ No

A: SSR: HDR to confirm which sinks are clean sinks that require the eye wash. SSR will update the fixture schedule/plans accordingly.

Answered 8/6/2026 at 9:02 PM CDT by Marcus Howard

Q114. SK-4 and SK-4A:

* Q: Please confirm SK-4 and SK-4A are to be furnished and installed by Div 22 contractor, and not Owner/Vendor as indicated in the Laboratory Sink Schedule on sheet Q-001. See fixtures P25 and P25A at Connection Schedule on sheet P-000, and sheet P-111 for corresponding locations.

Asked 4/15/2026 at 3:12 PM CDT

☐ Yes ☐ No

A: Correct, annotation to be updated.

Answered 5/5/2026 at 3:39 PM CDT by Marcus Howard

Q115. Combination Shower/Eyewash:

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Q: Please confirm whether the combination safety shower/eyewash is to be provided by Owner, and Contractor is only responsible for final connections. Laboratory drawings appear to show this item to be included as Owner-provided laboratory service fixtures, however, sheet P-000 lists the combination shower/eyewash under the Plumbing Fixture Schedule.

☐ Yes ☐ No

Asked 4/15/2026 at 3:12 PM CDT

A: SSR: HDR to confirm who is specifying the Safety Shower. SSR can update our fixture schedule to connection only if equipment is calling for the shower.

Answered 8/6/2026 at 9:03 PM CDT by Marcus Howard

Q126. Operating Room Wall Penetrations:

* Q: Please provide wall penetration requirements at operating rooms for above ceiling plumbing work required on Level 3.

☐ Yes ☐ No

Asked 4/15/2026 at 3:07 PM CDT

A: Utilize standard penetration details and procedures, scheduling needs to be done through UTSW on a case by case basis and after hours. For areas that are shielded additional procedures will need to utilize to maintain the integrity of the existing shield system.

Answered 8/6/2026 at 9:18 PM CDT by Marcus Howard

Q128. Crawl Space Confirmation:

* Q: Please confirm whether there is a crawl space for below-slab sanitary waste pipe work on Level 1. If so, please provide UTSW Confined Space permitting requirements.

☐ Yes ☐ No

Asked 4/15/2026 at 3:06 PM CDT

A: There is a crawl space below the level 01, As of the date of this response there are not specialized permit requirements for this space.

Answered 8/6/2026 at 9:23 PM CDT by Marcus Howard

Q147. Alternates:

* Q: In the drawings it shows Alt#5 is for Aquatap water system but there is nothing in the specs about it. Is this something we need to include in our pricing?

☐ Yes ☐ No

Asked 4/7/2026 at 1:34 PM CDT

A: Aquatap product to be priced as an alternate to the full DI/RO loop shown in design. Aquatap is a product that prevents the need to bring full loop for DI/RO down the wall near the sinks.

Answered 4/24/2026 at 3:15 PM CDT by Marcus Howard

Scope-Specific Clarifications**Specific Exclusions:**

None at this time.

General Acknowledgments

Mark "yes" to all yes/no questions »

GENERAL INFECTION CONTROL NOTES:

* Maintain/meet a Class IV infection control classification.

☐ Yes ☐ No

* A. OBTAIN FROM THE OWNER A COPY OF THE INFECTION CONTROL RISK ASSESSMENT (ICRA) PREPARED FOR THIS PROJECT. REVIEW THE REQUIREMENTS IN THE REPORT AND PERFORM ALL WORK IN ACCORDANCE WITH THOSE PROTOCOLS. STRICTLY ADHERE TO THE LIMITS OF THE CONSTRUCTION AREA, AND WHERE PHASING APPLIES, ADHERE TO PHASING PLAN. COORDINATE ANY WORK OUTSIDE THE CONSTRUCTION AREA WITH THE OWNER AND PERFORM IT IN ACCORDANCE WITH THE ICRA REPORT, UNDER THE SUPERVISION OF THE OWNER'S REPRESENTATIVE OR OTHER DESIGNATED ICRA COMMITTEE OFFICER.

☐ Yes ☐ No

* B. TO THE EXTENT THAT IS REQUIRED BY THE ICRA, ENDEAVOR TO MAINTAIN EXISTING LEVELS OF INDOOR AIR QUALITY IN AREAS SURROUNDING AND ADJACENT TO THE CONSTRUCTION WORK ZONE, AND ELSEWHERE IN THE FACILITY. IT SHOULD BE ANTICIPATED THAT THE ICRA REPORT WILL REQUIRE MEASURES TO THIS EFFECT, INCLUDING THE ASSEMBLY OF THE CONSTRUCTION ZONE BARRIERS.

☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* C. PERFORM CONSTRUCTION ACTIVITIES IN AREAS THAT ARE OCCUPIED BY THE HOSPITAL STAFF, THE GENERAL PUBLIC, OR HOSPITAL PATIENTS PER THE REQUIREMENTS OF THE OWNER'S ICRA. WHERE CONSTRUCTION ACTIVITIES HAVE BEEN COMPLETED, RETURN THE AREA TO "CLEAN" CONDITIONS, AS DEFINED BY THE OWNER'S PROTOCOLS, BEFORE IT IS OCCUPIED BY THE HOSPITAL STAFF, THE GENERAL PUBLIC, OR HOSPITAL PATIENTS.

☐ Yes ☐ No**Work Hours & Restrictions:****On-Site Work Hours:**

* Owner's Special Conditions set normal hours at 7:00 AM–5:00 PM; after hours 6:00 PM–6:00 AM; weekends permitted. Work generating excessive noise, odor, or vibration, and any work above the active Level 3 operating rooms, must be performed after hours or on weekends (Owner has confirmed all work above active ORs is overtime/night work). Flooring scope is on Level 4 inside the contained renovation area, so we anticipate straight time – but carry the flexibility, and note the GC is responsible for OT/weekend work needed to hold schedule.

☐ Yes ☐ No**Work Restrictions:**

* THE BUILDING WILL BE OCCUPIED DURING CONSTRUCTION. COORDINATE WITH OWNER ON SCHEDULING CONSTRUCTION OPERATIONS THAT GENERATE VIBRATION, NOISE, SECURITY CONCERNS, POWER INTERRUPTIONS, SMELLS OR OTHER CONSTRUCTION ACTIVITIES THAT MAY DISRUPT OPERATION IN ADJACENT SPACES.

☐ Yes ☐ No

* Comply with limitations on use of public streets and other requirements of authorities having jurisdiction.

☐ Yes ☐ No**Jobsite Access:**

* This is a renovation inside Clements University Hospital with active clinical space adjacent and below. ICRA/infection control applies: negative air machines with HEPA at all times, hard-panel containment barriers, tacky and walk-off mats, covered trash buggies with wheels cleaned entering/leaving, daily debris removal. All personnel need UTSW badges and current UTSW safety training. No free parking – UTSW parking policy applies.

☐ Yes ☐ No**Parking:**

* No free parking. Parking is as per UTSW parking policy.

☐ Yes ☐ No**Employee Identification:****Addendum Acknowledgment:**

* Addendum 1

☐ Yes ☐ No

* Addendum 2

☐ Yes ☐ No

* Addendum 3

☐ Yes ☐ No

* Addendum 4

☐ Yes ☐ No

* Addendum 5

☐ Yes ☐ No

* Addendum 6

☐ Yes ☐ No

* Addendum 7

☐ Yes ☐ No

* Addendum 8

☐ Yes ☐ No

* Addendum 9

☐ Yes ☐ No**Q&A Acknowledgement:**

* Q&A Dated 08-26-2026

☐ Yes ☐ No**Taxes:**

* Sales Tax on Materials Included?

☐ Yes ☐ No

* Cost Breakout of Sales Tax on Materials ==> ENTER DOLLAR VALUE \$

\$

Lead Times:

* Shop Drawing / Submittal Lead Time

input response here

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Product Lead Time Description(s) & # of Weeks

input response here

Labor Rates:

* Wage Rates per project requirements (i.e., Prevailing Wage, Davis Bacon, etc. As Applicable)

☐ Yes ☐ No

The undersigned acknowledges that material substitutions are not permitted unless expressly approved in writing by Arch/Eng through Requests for substitutions must include detailed specifications and documentation for review and approval prior to bid submission:

Please acknowledge that you have read and agree with the information, procedures, and requirements listed in the following Specifications & Documents:

00 - RFP:

* RFP_Sealed_Proposal_-_CUH_3T_MRI_WITH_HIFU_AND_TULSA

☐ Yes ☐ No**01 - Plans:**

* Campus Map

☐ Yes ☐ No

* UTSW-CUH-MRI 4 IFC DRAWING SET

☐ Yes ☐ No**02 - Specifications:**

* UTSW-CUH-MRI 4 IFC PROJECT MANUAL

☐ Yes ☐ No**03 - Addenda:****04 - Owner's Special Conditions:**

* Owner's Special Conditions

☐ Yes ☐ No**05 - Safety & Security:**

* Construction Site Safety Manual FY22

☐ Yes ☐ No

* Environmental of Care Fire & Life Safety Policy

☐ Yes ☐ No

* Project Safety Requirements

☐ Yes ☐ No**06 - Planning & Scheduling:**

* Project Planning and Scheduling

☐ Yes ☐ No**07 - UTSW Uniform Specs & Acknowledgements:**

* Project Quality Control

☐ Yes ☐ No

* UGCs

☐ Yes ☐ No**08 - Wage Rates:**

* Wage Determination

☐ Yes ☐ No**09 - Q&A Clarifications:****10 - Additional Information:**

* Change Order Form CSP

☐ Yes ☐ No

* CUH Asbestos Free Letter

☐ Yes ☐ No

* General Commissioning Requirements

☐ Yes ☐ No

* Project Administration Templates

☐ Yes ☐ No

* Project Closeout Procedures

☐ Yes ☐ No

* utsw design guidelines vol 1 ada

☐ Yes ☐ No

* utsw design guidelines vol 2 ada

☐ Yes ☐ No

* utsw design guidelines vol 3 ada

☐ Yes ☐ No

* UTSW_VETHUB_SP_v2

☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab
6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Bond Information

* Payment & Performance Bond Add (If Required) % Percentage OR

%

* Payment & Performance Bond Add (If Required) Dollar Amount

\$

Certifications

* Certified VetHUB? (Project goal of 1%)

☐ Yes ☐ No

* Participation Included in Base Bid (% of VetHUB subcontractor total base bid)

input response here

* Certification Agency

input response here

* Certification Number

input response here

Attachments

⊕ upload files