

26-0024: UTSW CUH 4.219 Microbiology Lab
6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Source Building Group

651 East Debbie Lane, BLDG 200, Mansfield, TX 76063, United States of America

Sunny Fung | Estimator / Quantity Surveyor | +1 469-835-7725 | sfung@sourcebuild.net



Line Items

Description	Quantity	Unit Cost	Total Cost
BID FORM (8/28):			
* Mechanical Demo			\$
* HVAC Systems			\$
* Test & Balance			\$
* Direct Digital Control (DDC) System			\$
Base Bid			\$0

Alternates

OWNER BID ALTERNATES:

* None at this time.

\$

:

SCOPE ALTERNATES:

* None at this time.

\$

Inclusions

Mark "yes" to all yes/no questions »

* MATERIAL	☐ Yes	☐ No
* INSTALLATION	☐ Yes	☐ No
SPECIFICATION(S) ACKNOWLEDGEMENT:		
* 23 05 00 - COMMON WORK RESULTS FOR HVAC	☐ Yes	☐ No
* 23 05 13 - MOTORS	☐ Yes	☐ No
* 23 05 15 - MECHANICAL, PIPING, VALVES AND FITTINGS	☐ Yes	☐ No
* 23 05 16 - PIPING EXPANSION COMPENSATION	☐ Yes	☐ No
* 23 05 19 - METERS AND GAUGES	☐ Yes	☐ No
* 23 05 29 - SUPPORTS AND ANCHORS	☐ Yes	☐ No
* 23 05 48 - VIBRATION ISOLATION	☐ Yes	☐ No
* 23 05 53 - MECHANICAL IDENTIFICATION	☐ Yes	☐ No
* 23 05 93 - TESTING, ADJUSTING AND BALANCING	☐ Yes	☐ No
* 23 05 94 - SYSTEM TESTING, ADJUSTING AND BALANCING	☐ Yes	☐ No
* 23 07 01 - PIPING INSULATION	☐ Yes	☐ No
* 23 07 03 - DUCTWORK INSULATION	☐ Yes	☐ No
* 23 09 13 - INSTRUMENTATION AND CONTROL DEVICES	☐ Yes	☐ No
* 23 09 23 - BUILDING AUTOMATION AND DIRECT DIGITAL CONTROLS	☐ Yes	☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* 23 21 13 - HVAC PIPING	☐ Yes	☐ No
* 23 21 16 - HYDRONIC PIPING SPECIALTIES	☐ Yes	☐ No
* 23 21 23 - HVAC PUMPS	☐ Yes	☐ No
* 23 22 23 - STEAM AND STEAM CONDENSATE SPECIALTIES	☐ Yes	☐ No
* 23 31 13 - DUCTWORK	☐ Yes	☐ No
* 23 31 14 - SHEETMETAL - SPECIAL DUCTWORK	☐ Yes	☐ No
* 23 33 00 - DUCTWORK ACCESSORIES	☐ Yes	☐ No
* 23 34 17 - BELTED VENT SETS	☐ Yes	☐ No
* 23 36 00 - AIR TERMINAL UNITS	☐ Yes	☐ No
* 23 36 10 - AIR VALVES	☐ Yes	☐ No
* 23 37 00 - AIR OUTLETS AND INLETS	☐ Yes	☐ No
* 23 41 00 - PARTICULATE AIR FILTRATION	☐ Yes	☐ No
* 23 44 13 - ULTRAVIOLET FIXTURES	☐ Yes	☐ No
* 23 73 23 - CUSTOM INDOOR CENTRAL - STATION AIR HANDLING UNITS	☐ Yes	☐ No
* 23 84 13 - HUMIDIFIERS	☐ Yes	☐ No

:

SCOPE OF WORK:

Mechanical Demo:

* PER PLAN MHD-104 MECHANICAL DUCTWORK DEMO PLAN - LEVEL 04 KEYNOTE 1-11	☐ Yes	☐ No
* PER PLAN MPD-204 MECHANICAL PIPING DEMO PLAN - LEVEL 04 KEYNOTE 1-3	☐ Yes	☐ No
* PER PLAN MD-105.1 MECHANICAL OVERALL DUCTWORK PLAN MECHANICAL FLOOR KEYNOTE 1-3	☐ Yes	☐ No

Equipment (PER MECH SCHEDULE M-002, 003):

* CUH-AJUM41 AND M42 AIR HANDLING UNIT	☐ Yes	☐ No
* CUH-EFM44A, 44B, 45, 46, 47 AND 48 FAN	☐ Yes	☐ No
* SAV-4-4 AND EAV-4-4 AIR VALVE	☐ Yes	☐ No
* VAV-4-4 30A, B, C, D, N AIR TERMINAL UNIT	☐ Yes	☐ No
* AHUM41, 42 AND EFM44A, B, C, D AIR FILTER	☐ Yes	☐ No
* PHCP-M41 AND M42 PUMP	☐ Yes	☐ No
* CUH-PRV41 STEAM PRESSURE REDUCING STATION	☐ Yes	☐ No
* CUH-H10 AND H11 ELECTRIC HUMIDIFIER	☐ Yes	☐ No

Other:

* Refrigerant Piping	☐ Yes	☐ No
* Condensate Piping	☐ Yes	☐ No
* Air Outlets and Inlets	☐ Yes	☐ No
* Ductwork	☐ Yes	☐ No
* Duct Insulation	☐ Yes	☐ No
* Vibration and Seismic Controls for HVAC	☐ Yes	☐ No
* Instrumentation and Control Devices for HVAC	☐ Yes	☐ No
* Hangers and Supports for HVAC Piping and Equipment	☐ Yes	☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Test & Balance:

* NEBB Air Balance Report

☐ Yes ☐ No**Controls:**

* Energy Management System - System 600 APOGEEa and Siemens Building Technologies is the acceptable manufacturer/installer.

☐ Yes ☐ No

* Alternate bidders are acceptable with ownership approval. Any alternate bidder must be able to demonstrate to UTSWMC the ability to integrate with the existing Siemens Building Technologies Energy Management System prior to bidding

☐ Yes ☐ No**General:**

* Trade Permit (*Building Permit by GC)

☐ Yes ☐ No

* Lifting Equipment as required for installation

☐ Yes ☐ No

* Penetration Firestopping

☐ Yes ☐ No

* Div 08: Access Doors & Panels (Coordinate with Drywall Subcontractor and other trades)

☐ Yes ☐ No**Q&A Project Specific Items as of 8/27/26:****Q21. Mechanical Unit Site Delivery:**

* Q: Can we get confirmation that it is means and methods to set the new mechanical unit, and that a helicopter is not required?

☐ Yes ☐ No

Asked 8/18/2026 at 2:06 PM CDT

A: We recommend locating the crane at the Emergency Department entrance. Please refer to the attached sketch. A helicopter is not required. [Attachment: Crane-Q-31-Q-50.pdf]

Answered 8/26/2026 at 9:41 AM CDT by Amanda Usrey

Q37. HVAC Spec:

* Q: As per the prebid meeting it was mentioned that the HVAC Units are open specs and any manufacturer can be used as long as it meets the criteria. Please confirm

☐ Yes ☐ No

Asked 8/18/2026 at 8:09 AM CDT

A: Confirmed. Has to be approved equal

Answered 8/26/2026 at 9:46 AM CDT by Amanda Usrey

Q106. Roof Equipment Signed & Sealed Shops:

* Q: Sheet S-001, Part I, Note M1 states that all roof top equipment curbs, roof top mechanical equipment, equipment tie downs, and connections of all equipment to building structure are to be designed and engineered by a registered Specialty Engineer retained by the mechanical equipment supplier. Are Signed and Sealed shop drawings and calculations to be submitted? Please confirm this is required.

☐ Yes ☐ No

Asked 4/15/2026 at 3:16 PM CDT

A: Per S001, Part XII Section B.2.a - Roof Top Equipment and Anchorages (S&S) should be submitted. As stated in this section (S&S) indicates that shop drawings and deldgated design submittals shall be sealed per the project specifications by an engineer registered in the state where the project is located.

Answered 8/6/2026 at 9:01 PM CDT by Marcus Howard

Q109. Metal Closure Plate at BSL-3:

* Q: Detail A3/Q-550 references a metal closure plate at BSL-3 mechanical penetrations. Please specify what type of metal plate (e.g. stainless steel) is required at these locations.

☐ Yes ☐ No

Asked 4/15/2026 at 3:14 PM CDT

A: Exposed metal is to be non-porous.

Answered 5/5/2026 at 3:44 PM CDT by Marcus Howard

Q121. O2 Sensor Location:

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Q: Keyed note 13/EP-111 calls out an O2 sensor outside of Bio Hazard Waste 4.430K, and states to refer to mechanical drawings for rough-in location. Keyed note 7/MH-104 indicates the O2 sensor located outside of Cylinder Storage 4.430U. Please confirm the correct location for the O2 sensor is reflected on sheet MH-104.
Asked 4/15/2026 at 3:09 PM CDT

☐ Yes ☐ No

A: SSR: Location shall be per mechanical drawings power can be coordinated to the correct location. O2 sensor shall read levels at the breathing zone of the bottle room.
Answered 8/6/2026 at 9:05 PM CDT by Marcus Howard

Q123. TAB & Pre-Readings:

* Q: Mechanical Demolition Note A on sheet M-001 states Contractor shall take air flow and static pressure readings on existing equipment before demolition. Does this requirement fall under the TAB scope? The Owner's Special Conditions indicates TAB should be excluded from Contractor's proposal. Please confirm TAB will be provided by Owner and, if so, please confirm Contractor is not responsible for the pre-demolition readings indicated in this note.
Asked 4/15/2026 at 3:08 PM CDT

☐ Yes ☐ No

A: SSR: Needs to be addressed by UTSW PM. Pre-construction TAB verifications are typically on the contractor to coordinated. If owner is carrying project TAB then it is their ultimate decision on how to provide the pre-construction requests.
Answered 8/6/2026 at 9:06 PM CDT by Marcus Howard

Q132. HVAC System Cleaning Clarification:

* Q: Specification Section 015719 references required cleaning for each HVAC unit and ductwork. Please clarify the extent of this requirement. Does this apply to only new work, or is this intended to apply to existing systems as well?
Asked 4/15/2026 at 3:04 PM CDT

☐ Yes ☐ No

A: Duct cleaning is required if ductwork is not maintained per specifications during construction.
Answered 8/6/2026 at 9:27 PM CDT by Marcus Howard

Q134. HEPA Filtered BSL-3 Exhaust:

* Q: The Mechanical drawings do not appear to indicate any HEPA filtered BSL-3 exhaust until the exhaust fans (as noted in the schedule on sheet M-002). This is a cross contamination issue. Please advise. Contractor recommends using HEPA diffusers, or installing a bubble tight damper in exhaust at autoclave capture hoods that shut if the room goes positive to prevent cross contamination.
Asked 4/15/2026 at 3:03 PM CDT

☐ Yes ☐ No

A: Recommend review of comment with ownership. Has operational implications that need to be studies. Note it is NOT recommended to put terminal HEPA at the bio-hazardous room, the moisture from the autoclaves is too close with no dilution.
Answered 8/6/2026 at 9:29 PM CDT by Marcus Howard

Q135. Bubble Tight Dampers Confirmation:

* Q: Keyed note 4/MH-104 indicates high speed, zero leakage, 120V motorized dampers to be utilized at BSL-3 supply and exhaust duct. Please confirm this note is referencing the bubble tight dampers indicated in Specification Section 233300, Part 2.7.
Asked 4/15/2026 at 3:03 PM CDT

☐ Yes ☐ No

A: Correct
Answered 8/6/2026 at 9:29 PM CDT by Marcus Howard

Q136. Supply Duct Contamination Issue:

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Q: Sheet MH-104: The two (2) supply ducts branching off of the main 20"x20" SA between column lines 8.2 & 8.4 and L.3 & M are running to rooms outside of the BSL-3 containment boundary, which is a potential cross contamination issue. Please advise. Contractor recommends installing bubble tight dampers that shut to isolate at these tap locations.

☐ Yes ☐ No

Asked 4/15/2026 at 3:02 PM CDT

A: Proceed with the design as-is. Recommendations will be evaluated with the Owner and Engineer Further

Answered 8/6/2026 at 9:29 PM CDT by Marcus Howard

Q137. Exhaust Contamination Issue at Autoclaves:

* Q: Sheet MH-104: The tap on exhaust that leads to Bio Hazard Waste 4.430K goes to the capture hoods at the autoclaves, which are outside the BSL-3 containment barrier. If the lab were to go positive, this could lead to a cross contamination issue. Please advise.

☐ Yes ☐ No

Asked 4/15/2026 at 3:02 PM CDT

A: Proceed with the design as-is. Recommendations will be evaluated with the Owner and Engineer Further.

Answered 8/6/2026 at 9:34 PM CDT by Marcus Howard

Q138. BSL-3 Research:

* Q: What research is intended to take place in the BSL-3?

☐ Yes ☐ No

Asked 4/15/2026 at 3:01 PM CDT

A: Not applicable for RFP response.

Answered 8/6/2026 at 9:34 PM CDT by Marcus Howard

Q139. Sequence of Operations, BSL-3 Decontamination:

* Q: Please advise if there is a sequence of operations for decontamination of the BSL-3 (AFB Lab).

☐ Yes ☐ No

Asked 4/15/2026 at 3:01 PM CDT

A: Provide allowance for BSL-3 sequence of operations for controls sub-contractor. Recommendations will be evaluated with the Owner and Engineer Further.

Answered 8/6/2026 at 9:35 PM CDT by Marcus Howard

Q140. BSL-3 Sequence of Operations In Exhaust Failure:

* Q: Please advise if there is a sequence of operations for the BSL-3 (AFB Lab) in response to full exhaust fan failure.

☐ Yes ☐ No

Asked 4/15/2026 at 3:00 PM CDT

A: Provide allowance for BSL-3 sequence of operations for controls sub-contractor. Recommendations will be evaluated with the Owner and Engineer Further

Answered 8/6/2026 at 9:35 PM CDT by Marcus Howard

Q141. BSL-3 Sequence of Operations In Power Failure:

* Q: Please advise if there is a sequence of operations for the BSL-3 (AFB Lab) in response to full building power failure.

☐ Yes ☐ No

Asked 4/15/2026 at 2:59 PM CDT

A: Provide allowance for BSL-3 sequence of operations for controls sub-contractor. Recommendations will be evaluated with the Owner and Engineer Further.

Answered 8/6/2026 at 9:36 PM CDT by Marcus Howard

Q142. Sequence of Operations, Hardwire Safeties:

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Q: In the sequence of operations defined on sheet M-704, please elaborate on the hardwired safeties referred to in the following statement: "Exhaust fan system shall be stopped by any of the following: hardwired safeties".
Asked 4/15/2026 at 2:58 PM CDT

☐ Yes ☐ No

A: Provide allowance for BSL-3 sequence of operations for controls sub-contractor. Recommendations will be evaluated with the Owner and Engineer Further.

Answered 8/6/2026 at 9:37 PM CDT by Marcus Howard

Q143. BSL-3 Shutdown Sequence of Operations:

* Q: On sheet M-704, please define the BSL-3 (AFB Lab) shutdown sequence of operations relative to both exhaust and supply.

Asked 4/15/2026 at 2:58 PM CDT

☐ Yes ☐ No

A: Provide allowance for BSL-3 sequence of operations for controls sub-contractor. Recommendations will be evaluated with the Owner and Engineer Further.

Answered 8/6/2026 at 9:37 PM CDT by Marcus Howard

Q144. BSL-3 Startup Sequence of Operations:

* Q: On sheet M-704, please define the BSL-3 (AFB Lab) startup sequence of operations relative to both exhaust and supply. Exhaust should prove out before startup of supply.

Asked 4/15/2026 at 2:57 PM CDT

☐ Yes ☐ No

A: Provide allowance for BSL-3 sequence of operations for controls sub-contractor. Recommendations will be evaluated with the Owner and Engineer Further.

Answered 8/6/2026 at 9:38 PM CDT by Marcus Howard

Q145. Sequence of Operations, Exhaust Interlock:

* Q: In the sequence of operations defined on sheet M-702, please elaborate on the following statement: "Interlocked exhaust fans shall start/stop via hardwire interlock with supply." Typically, supply is interlocked with exhaust for exhaust failure. If supply fails, exhaust should continue to run, maintaining directional airflow requirements until the lab can initiate appropriate SOP's for biosafety, and then shut down. Typically, exhaust is run for a timed period to allow for safe shutdown of the lab.

Asked 4/15/2026 at 2:56 PM CDT

☐ Yes ☐ No

A: Provide allowance for BSL-3 sequence of operations for controls sub-contractor. Recommendations will be evaluated with the Owner and Engineer Further.

Answered 8/6/2026 at 9:39 PM CDT by Marcus Howard

Scope-Specific Clarifications**Exclusions:**

None at this time.

General Acknowledgments

Mark "yes" to all yes/no questions »

GENERAL INFECTION CONTROL NOTES:

* Maintain/meet a Class IV infection control classification.

☐ Yes ☐ No

* A. OBTAIN FROM THE OWNER A COPY OF THE INFECTION CONTROL RISK ASSESSMENT (ICRA) PREPARED FOR THIS PROJECT. REVIEW THE REQUIREMENTS IN THE REPORT AND PERFORM ALL WORK IN ACCORDANCE WITH THOSE PROTOCOLS. STRICTLY ADHERE TO THE LIMITS OF THE CONSTRUCTION AREA, AND WHERE PHASING APPLIES, ADHERE TO PHASING PLAN. COORDINATE ANY WORK OUTSIDE THE CONSTRUCTION AREA WITH THE OWNER AND PERFORM IT IN ACCORDANCE WITH THE ICRA REPORT, UNDER THE SUPERVISION OF THE OWNER'S REPRESENTATIVE OR OTHER DESIGNATED ICRA COMMITTEE OFFICER.

☐ Yes ☐ No

* B. TO THE EXTENT THAT IS REQUIRED BY THE ICRA, ENDEAVOR TO MAINTAIN EXISTING LEVELS OF INDOOR AIR QUALITY IN AREAS SURROUNDING AND ADJACENT TO THE CONSTRUCTION WORK ZONE, AND ELSEWHERE IN THE FACILITY. IT SHOULD BE ANTICIPATED THAT THE ICRA REPORT WILL REQUIRE MEASURES TO THIS EFFECT, INCLUDING THE ASSEMBLY OF THE CONSTRUCTION ZONE BARRIERS.

☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* C. PERFORM CONSTRUCTION ACTIVITIES IN AREAS THAT ARE OCCUPIED BY THE HOSPITAL STAFF, THE GENERAL PUBLIC, OR HOSPITAL PATIENTS PER THE REQUIREMENTS OF THE OWNER'S ICRA. WHERE CONSTRUCTION ACTIVITIES HAVE BEEN COMPLETED, RETURN THE AREA TO "CLEAN" CONDITIONS, AS DEFINED BY THE OWNER'S PROTOCOLS, BEFORE IT IS OCCUPIED BY THE HOSPITAL STAFF, THE GENERAL PUBLIC, OR HOSPITAL PATIENTS.

☐ Yes ☐ No**Work Hours & Restrictions:****On-Site Work Hours:**

* Owner's Special Conditions set normal hours at 7:00 AM–5:00 PM; after hours 6:00 PM–6:00 AM; weekends permitted. Work generating excessive noise, odor, or vibration, and any work above the active Level 3 operating rooms, must be performed after hours or on weekends (Owner has confirmed all work above active ORs is overtime/night work). Flooring scope is on Level 4 inside the contained renovation area, so we anticipate straight time – but carry the flexibility, and note the GC is responsible for OT/weekend work needed to hold schedule.

☐ Yes ☐ No**Work Restrictions:**

* THE BUILDING WILL BE OCCUPIED DURING CONSTRUCTION. COORDINATE WITH OWNER ON SCHEDULING CONSTRUCTION OPERATIONS THAT GENERATE VIBRATION, NOISE, SECURITY CONCERNS, POWER INTERRUPTIONS, SMELLS OR OTHER CONSTRUCTION ACTIVITIES THAT MAY DISRUPT OPERATION IN ADJACENT SPACES.

☐ Yes ☐ No

* Comply with limitations on use of public streets and other requirements of authorities having jurisdiction.

☐ Yes ☐ No**Jobsite Access:**

* This is a renovation inside Clements University Hospital with active clinical space adjacent and below. ICRA/infection control applies: negative air machines with HEPA at all times, hard-panel containment barriers, tacky and walk-off mats, covered trash buggies with wheels cleaned entering/leaving, daily debris removal. All personnel need UTSW badges and current UTSW safety training. No free parking – UTSW parking policy applies.

☐ Yes ☐ No**Parking:**

* No free parking. Parking is as per UTSW parking policy.

☐ Yes ☐ No**Employee Identification:****Addendum Acknowledgment:**

* Addendum 1

☐ Yes ☐ No

* Addendum 2

☐ Yes ☐ No

* Addendum 3

☐ Yes ☐ No

* Addendum 4

☐ Yes ☐ No

* Addendum 5

☐ Yes ☐ No

* Addendum 6

☐ Yes ☐ No

* Addendum 7

☐ Yes ☐ No

* Addendum 8

☐ Yes ☐ No

* Addendum 9

☐ Yes ☐ No**Q&A Acknowledgement:**

* Q&A Dated 08-26-2026

☐ Yes ☐ No**Taxes:**

* Sales Tax on Materials Included?

☐ Yes ☐ No

* Cost Breakout of Sales Tax on Materials ==> ENTER DOLLAR VALUE \$

Lead Times:

* Shop Drawing / Submittal Lead Time

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Product Lead Time Description(s) & # of Weeks

input response here

Labor Rates:

* Wage Rates per project requirements (i.e., Prevailing Wage, Davis Bacon, etc. As Applicable)

☐ Yes ☐ No

The undersigned acknowledges that material substitutions are not permitted unless expressly approved in writing by Arch/Eng through Requests for substitutions must include detailed specifications and documentation for review and approval prior to bid submission:

Please acknowledge that you have read and agree with the information, procedures, and requirements listed in the following Specifications & Documents:

00 - RFP:

* RFP_Sealed_Proposal_-_CUH_3T_MRI_WITH_HIFU_AND_TULSA

☐ Yes ☐ No**01 - Plans:**

* Campus Map

☐ Yes ☐ No

* UTSW-CUH-MRI 4 IFC DRAWING SET

☐ Yes ☐ No**02 - Specifications:**

* UTSW-CUH-MRI 4 IFC PROJECT MANUAL

☐ Yes ☐ No**03 - Addenda:****04 - Owner's Special Conditions:**

* Owner's Special Conditions

☐ Yes ☐ No**05 - Safety & Security:**

* Construction Site Safety Manual FY22

☐ Yes ☐ No

* Environmental of Care Fire & Life Safety Policy

☐ Yes ☐ No

* Project Safety Requirements

☐ Yes ☐ No**06 - Planning & Scheduling:**

* Project Planning and Scheduling

☐ Yes ☐ No**07 - UTSW Uniform Specs & Acknowledgements:**

* Project Quality Control

☐ Yes ☐ No

* UGCs

☐ Yes ☐ No**08 - Wage Rates:**

* Wage Determination

☐ Yes ☐ No**09 - Q&A Clarifications:****10 - Additional Information:**

* Change Order Form CSP

☐ Yes ☐ No

* CUH Asbestos Free Letter

☐ Yes ☐ No

* General Commissioning Requirements

☐ Yes ☐ No

* Project Administration Templates

☐ Yes ☐ No

* Project Closeout Procedures

☐ Yes ☐ No

* utsw design guidelines vol 1 ada

☐ Yes ☐ No

* utsw design guidelines vol 2 ada

☐ Yes ☐ No

* utsw design guidelines vol 3 ada

☐ Yes ☐ No

* UTSW_VETHUB_SP_v2

☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab
6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Bond Information

* Payment & Performance Bond Add (If Required) % Percentage OR

%

* Payment & Performance Bond Add (If Required) Dollar Amount

\$

Certifications

* Certified VetHUB? (Project goal of 1%)

☐ Yes ☐ No

* Participation Included in Base Bid (% of VetHUB subcontractor total base bid)

input response here

* Certification Agency

input response here

* Certification Number

input response here

Attachments

⊕ upload files