

26-0024: UTSW CUH 4.219 Microbiology Lab
6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Source Building Group
651 East Debbie Lane, BLDG 200, Mansfield, TX 76063, United States of America
Sunny Fung | Estimator / Quantity Surveyor | +1 469-835-7725 | sfung@sourcebuild.net



Line Items

Description	Quantity	Unit Cost	Total Cost
BID FORM (8/28):			
* Electrical Demo			\$
* Electrical (Building)			\$
* Empty Conduit Pathways for Communications, Security, Fire Alarm Systems			\$
Base Bid			\$0

Alternates

OWNER BID ALTERNATES:	
* None at this time.	\$
:	
SCOPE ALTERNATES:	
* Lightning Protection System	\$

Inclusions

Mark "yes" to all yes/no questions »

* MATERIAL	☐ Yes	☐ No
* INSTALLATION	☐ Yes	☐ No

SPECIFICATION(S) ACKNOWLEDGEMENT:

* 26 00 00 - BASIC ELECTRICAL REQUIREMENTS	☐ Yes	☐ No
* 26 00 10 - ELECTRICAL DESIGN REQUIREMENTS	☐ Yes	☐ No
* 26 05 00 - BASIC ELECTRICAL MATERIALS AND METHODS	☐ Yes	☐ No
* 26 05 01 - ELECTRICAL DEMOLITION	☐ Yes	☐ No
* 26 05 19 - BUILDING WIRE, CABLE AND CONNECTORS 600 VOLTS AND BELOW	☐ Yes	☐ No
* 26 05 26 - GROUNDING	☐ Yes	☐ No
* 26 05 29 - SUPPORTING DEVICES	☐ Yes	☐ No
* 26 05 33 - CONDUITS AND BOXES	☐ Yes	☐ No
* 26 05 50 - SYSTEM COORDINATION AND ANALYSIS	☐ Yes	☐ No
* 26 05 53 - ELECTRICAL IDENTIFICATION	☐ Yes	☐ No
* 26 24 17 - BRANCH CIRCUIT PANEL PANELBOARDS	☐ Yes	☐ No
26 27 26 - WIRING DEVICES AND FLOOR BOXES	☐ Yes	☐ No
* 26 28 13 - FUSES, 600 VOLT	☐ Yes	☐ No
* 26 28 16 - DISCONNECT SWITCHES - HEAVY DUTY	☐ Yes	☐ No
* 26 29 20 - MOTORS, CONTROLLERS AND ELECTRIC POWERED EQUIPMENT	☐ Yes	☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* 26 29 23 - VARIABLE FREQUENCY MOTOR CONTROLLERS ☐ Yes ☐ No

* 26 41 13 - LIGHTNING PROTECTION SYSTEM ☐ Yes ☐ No

* 26 51 00 - LIGHTING FIXTURES ☐ Yes ☐ No

: _____

SCOPE OF WORK: _____

Electrical Demo: _____

* PER PLAN E-000 DEMOLITION NOTES ☐ Yes ☐ No

* PER PLAN ED-110, ED-111, ED-112 AND ED-113 ☐ Yes ☐ No

Electrical Scope: _____

* Grounding and Bonding for Electrical Systems ☐ Yes ☐ No

* Hangers and Supports for Electrical Systems ☐ Yes ☐ No

* Conduit & Boxes for Electrical Systems ☐ Yes ☐ No

* Wiring for Electrical Systems ☐ Yes ☐ No

* Vibration and Seismic Control ☐ Yes ☐ No

* Identification for Electrical Systems ☐ Yes ☐ No

* Switchgear & Panelboards ☐ Yes ☐ No

* Interior Lighting ☐ Yes ☐ No

* Lighting Controls ☐ Yes ☐ No

Equipment Connections: _____

- * - Make final electrical connections to equipment provided under: ☐ Yes ☐ No
- Division 21 (Fire Suppression): Fire pump controllers and flow switches.(If Applicable)
 - Division 22 (Plumbing): Water heaters, sump pumps, and other powered plumbing fixtures.
 - Division 23 (HVAC): Air handling units, exhaust fans, and other HVAC equipment.
 - Coordinate closely with the respective trades to ensure seamless integration.

Pathways for Communications Systems: _____

- * - Install all conduits, raceways, pull boxes, and junction boxes. ☐ Yes ☐ No
- Ensure proper sizing and routing to prevent interference with other trades.

Pathways for Fire Alarm Systems: _____

- * - Install all conduits, raceways, pull boxes, and junction boxes. ☐ Yes ☐ No
- Ensure proper sizing and routing to prevent interference with other trades.

Pathways for Security & Access Control & Camera Systems: _____

- * - Install all conduits, raceways, pull boxes, and junction boxes. ☐ Yes ☐ No
- Ensure proper sizing and routing to prevent interference with other trades.

GENERAL: _____

* Penetration Firestopping ☐ Yes ☐ No

* Div 08: Access Doors & Panels (Coordinate with Drywall Subcontractor and other trades) ☐ Yes ☐ No

Permit: _____

* Trade Permit (*Building Permit by GC) ☐ Yes ☐ No

: _____

PROJECT SPECIFIC SCOPE | NOTES: _____

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* PER PLAN Q-550 WIRING DEVICES, OUTLETS, AND WHITE COVER PLATES AT UC. ALL COMPONENTS TO BE U.L. LISTED. PROVIDE NEMA RECEPTACLES AS SHOWN ON THE UC DRAWINGS UNO. COORDINATE WITH DIVISION 12 TO PROVIDE CIRCUIT LABELING ON USC.

☐ Yes ☐ No

* PER PLAN Q-550 REFER TO USC DRAWINGS FOR DESIGN INTENT AND UTILITY REQUIREMENTS. PROVIDE ELECTRICAL JUNCTION BOX ABOVE UC. COORDINATE WITH DIVISION 26 TO PROVIDE CIRCUIT LABELING ON UC.

☐ Yes ☐ No**Q&A Project Specific Items as of 8/27/26:****Q24. Reuse of Existing Conduit:**

* Q: Please confirm whether use of existing conduit is acceptable for new circuits. Previous RFI response noted that SSR takes no exception, but needs to be confirmed with UTSW if acceptable.
Asked 8/18/2026 at 2:00 PM CDT

☐ Yes ☐ No

A: Existing conduit may be reused, provided it meets the specifications and applicable codes.
Answered 8/26/2026 at 9:42 AM CDT by Amanda Usrey

Q30. Laboratory Casework:

* Q: Please confirm definitively whether laboratory casework, laboratory sinks, laboratory accessories, and laboratory service fixtures are by Owner, or if they should be part of Contractor's proposal.
Asked 8/18/2026 at 1:47 PM CDT

☐ Yes ☐ No

A: Casework will be provided by the Owner. The contractor is responsible for all utility connections.
Answered 8/26/2026 at 9:44 AM CDT by Amanda Usrey

Q87. Raceway Clarification:

* Q: Elevation C1 on sheet A-553 shows a third raceway above the typical double that is shown on all other elevations and electrical drawings. Additionally, it is not shown on corresponding elevation D4/Q-210. Please advise what this third raceway is intended for and if it is required.
Asked 4/15/2026 at 3:24 PM CDT

☐ Yes ☐ No

A: Disregard, refer to MEP drawings for raceway count. Mounting height to be coordinated with mounting height requirements prior to installation.
Answered 5/6/2026 at 3:07 PM CDT by Marcus Howard

Q88. Device Clarification:

* Q: Elevations C1 & C2 on sheet A-553 show multiple devices on the wall that appear to be thermostats. Please advise what these devices are.
Asked 4/15/2026 at 3:24 PM CDT

☐ Yes ☐ No

A: Refer to MEP plans for associated wall fixtures.
Answered 5/6/2026 at 3:06 PM CDT by Marcus Howard

Q89. Alcove Light Fixture:

* Q: Ceiling Plan B1/A-104 shows a can light at Alcove 4.430X that is missing on Electrical Lighting Plan A5/EL-111. Please confirm whether this can light is required at this location.
Asked 4/15/2026 at 3:23 PM CDT

☐ Yes ☐ No

A: Light is required, fixture has been added in Addendum 01
Answered 5/6/2026 at 3:05 PM CDT by Marcus Howard

Q116. Existing Lab Casework Removal:

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Q: Keyed note AD-01 on sheet A-104 notes to salvage existing laboratory casework and equipment, if not removed already. Please confirm Contractor is to remove and salvage the existing laboratory casework and equipment. Additionally, sheet ED-112 does not indicate any electrical demolition at these locations. Please confirm Contractor will need to make-safe and demo electrical within this lab casework.

☐ Yes ☐ No

Asked 4/15/2026 at 3:11 PM CDT

A: Contractor will need to make-safe and demolish electrical within lab casework.

Answered 5/5/2026 at 3:38 PM CDT by Marcus Howard

Q122. New Electrical Circuits:

* Q: Sheets ED-111 and ED-112: Please confirm reuse of existing conduit is acceptable for new circuits.

☐ Yes ☐ No

Asked 4/15/2026 at 3:09 PM CDT

A: SSR: This needs to be confirm with UTSW if acceptable, SSR takes no exception as long as the conduits are not damaged and installation meets code.

Answered 8/6/2026 at 9:05 PM CDT by Marcus Howard

Q130. Systems Requiring Hot Tie-Ins Clarification:

* Q: Per the pre-bid conference, it was indicated that tie-ins would be performed without outages. Does this apply to mechanical, plumbing, med gas, and electrical systems?

☐ Yes ☐ No

Asked 4/15/2026 at 3:06 PM CDT

A: All electrical work will be hot-work. Mechanical and Plumbing shutdowns to be minimized with hot work when ever possible and be scheduled and approved by UTSW prior to performing work. UTSW have the right to request hot work for any system on a case-by-case basis.

Answered 8/6/2026 at 9:24 PM CDT by Marcus Howard

Q131. Panel Shutdowns:

* Q: Per the pre-bid conference, it was indicated that no panel shutdowns are allowed, and all work must be hot work. Please confirm whether this requirement applies only to critical and life safety systems or all electrical power work. Will UTSW perform the electrical scope in hot electrical panels?

☐ Yes ☐ No

Asked 4/15/2026 at 3:05 PM CDT

A: Contractor is required to preform all hot work. Contractor is to submit EEW for UTSW approval prior to performing work.

Answered 8/6/2026 at 9:26 PM CDT by Marcus Howard

Scope-Specific Clarifications**Exclusions:**

- Specialty systems explicitly assigned to other divisions, such as communications (Division 27) or security (Division 28).

General Acknowledgments

Mark "yes" to all yes/no questions »

GENERAL INFECTION CONTROL NOTES:

* Maintain/meet a Class IV infection control classification.

☐ Yes ☐ No

* A. OBTAIN FROM THE OWNER A COPY OF THE INFECTION CONTROL RISK ASSESSMENT (ICRA) PREPARED FOR THIS PROJECT. REVIEW THE REQUIREMENTS IN THE REPORT AND PERFORM ALL WORK IN ACCORDANCE WITH THOSE PROTOCOLS. STRICTLY ADHERE TO THE LIMITS OF THE CONSTRUCTION AREA, AND WHERE PHASING APPLIES, ADHERE TO PHASING PLAN. COORDINATE ANY WORK OUTSIDE THE CONSTRUCTION AREA WITH THE OWNER AND PERFORM IT IN ACCORDANCE WITH THE ICRA REPORT, UNDER THE SUPERVISION OF THE OWNER'S REPRESENTATIVE OR OTHER DESIGNATED ICRA COMMITTEE OFFICER.

☐ Yes ☐ No

* B. TO THE EXTENT THAT IS REQUIRED BY THE ICRA, ENDEAVOR TO MAINTAIN EXISTING LEVELS OF INDOOR AIR QUALITY IN AREAS SURROUNDING AND ADJACENT TO THE CONSTRUCTION WORK ZONE, AND ELSEWHERE IN THE FACILITY. IT SHOULD BE ANTICIPATED THAT THE ICRA REPORT WILL REQUIRE MEASURES TO THIS EFFECT, INCLUDING THE ASSEMBLY OF THE CONSTRUCTION ZONE BARRIERS.

☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* C. PERFORM CONSTRUCTION ACTIVITIES IN AREAS THAT ARE OCCUPIED BY THE HOSPITAL STAFF, THE GENERAL PUBLIC, OR HOSPITAL PATIENTS PER THE REQUIREMENTS OF THE OWNER'S ICRA. WHERE CONSTRUCTION ACTIVITIES HAVE BEEN COMPLETED, RETURN THE AREA TO "CLEAN" CONDITIONS, AS DEFINED BY THE OWNER'S PROTOCOLS, BEFORE IT IS OCCUPIED BY THE HOSPITAL STAFF, THE GENERAL PUBLIC, OR HOSPITAL PATIENTS.

☐ Yes ☐ No**Work Hours & Restrictions:****On-Site Work Hours:**

* Owner's Special Conditions set normal hours at 7:00 AM–5:00 PM; after hours 6:00 PM–6:00 AM; weekends permitted. Work generating excessive noise, odor, or vibration, and any work above the active Level 3 operating rooms, must be performed after hours or on weekends (Owner has confirmed all work above active ORs is overtime/night work). Flooring scope is on Level 4 inside the contained renovation area, so we anticipate straight time – but carry the flexibility, and note the GC is responsible for OT/weekend work needed to hold schedule.

☐ Yes ☐ No**Work Restrictions:**

* THE BUILDING WILL BE OCCUPIED DURING CONSTRUCTION. COORDINATE WITH OWNER ON SCHEDULING CONSTRUCTION OPERATIONS THAT GENERATE VIBRATION, NOISE, SECURITY CONCERNS, POWER INTERRUPTIONS, SMELLS OR OTHER CONSTRUCTION ACTIVITIES THAT MAY DISRUPT OPERATION IN ADJACENT SPACES.

☐ Yes ☐ No

* Comply with limitations on use of public streets and other requirements of authorities having jurisdiction.

☐ Yes ☐ No**Jobsite Access:**

* This is a renovation inside Clements University Hospital with active clinical space adjacent and below. ICRA/infection control applies: negative air machines with HEPA at all times, hard-panel containment barriers, tacky and walk-off mats, covered trash buggies with wheels cleaned entering/leaving, daily debris removal. All personnel need UTSW badges and current UTSW safety training. No free parking – UTSW parking policy applies.

☐ Yes ☐ No**Parking:**

* No free parking. Parking is as per UTSW parking policy.

☐ Yes ☐ No**Employee Identification:****Addendum Acknowledgment:**

* Addendum 1

☐ Yes ☐ No

* Addendum 2

☐ Yes ☐ No

* Addendum 3

☐ Yes ☐ No

* Addendum 4

☐ Yes ☐ No

* Addendum 5

☐ Yes ☐ No

* Addendum 6

☐ Yes ☐ No

* Addendum 7

☐ Yes ☐ No

* Addendum 8

☐ Yes ☐ No

* Addendum 9

☐ Yes ☐ No**Q&A Acknowledgement:**

* Q&A Dated 08-26-2026

☐ Yes ☐ No**Taxes:**

* Sales Tax on Materials Included?

☐ Yes ☐ No

* Cost Breakout of Sales Tax on Materials ==> ENTER DOLLAR VALUE \$

Lead Times:

* Shop Drawing / Submittal Lead Time

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Product Lead Time Description(s) & # of Weeks

input response here

Labor Rates:

* Wage Rates per project requirements (i.e., Prevailing Wage, Davis Bacon, etc. As Applicable)

☐ Yes ☐ No

The undersigned acknowledges that material substitutions are not permitted unless expressly approved in writing by Arch/Eng through Requests for substitutions must include detailed specifications and documentation for review and approval prior to bid submission:

Please acknowledge that you have read and agree with the information, procedures, and requirements listed in the following Specifications & Documents:

00 - RFP:

* RFP_Sealed_Proposal_-_CUH_3T_MRI_WITH_HIFU_AND_TULSA

☐ Yes ☐ No**01 - Plans:**

* Campus Map

☐ Yes ☐ No

* UTSW-CUH-MRI 4 IFC DRAWING SET

☐ Yes ☐ No**02 - Specifications:**

* UTSW-CUH-MRI 4 IFC PROJECT MANUAL

☐ Yes ☐ No**03 - Addenda:****04 - Owner's Special Conditions:**

* Owner's Special Conditions

☐ Yes ☐ No**05 - Safety & Security:**

* Construction Site Safety Manual FY22

☐ Yes ☐ No

* Environmental of Care Fire & Life Safety Policy

☐ Yes ☐ No

* Project Safety Requirements

☐ Yes ☐ No**06 - Planning & Scheduling:**

* Project Planning and Scheduling

☐ Yes ☐ No**07 - UTSW Uniform Specs & Acknowledgements:**

* Project Quality Control

☐ Yes ☐ No

* UGCs

☐ Yes ☐ No**08 - Wage Rates:**

* Wage Determination

☐ Yes ☐ No**09 - Q&A Clarifications:****10 - Additional Information:**

* Change Order Form CSP

☐ Yes ☐ No

* CUH Asbestos Free Letter

☐ Yes ☐ No

* General Commissioning Requirements

☐ Yes ☐ No

* Project Administration Templates

☐ Yes ☐ No

* Project Closeout Procedures

☐ Yes ☐ No

* utsw design guidelines vol 1 ada

☐ Yes ☐ No

* utsw design guidelines vol 2 ada

☐ Yes ☐ No

* utsw design guidelines vol 3 ada

☐ Yes ☐ No

* UTSW_VETHUB_SP_v2

☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab
6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Bond Information

* Payment & Performance Bond Add (If Required) % Percentage OR

%

* Payment & Performance Bond Add (If Required) Dollar Amount

\$

Certifications

* Certified VetHUB? (Project goal of 1%)

☐ Yes ☐ No

* Participation Included in Base Bid (% of VetHUB subcontractor total base bid)

input response here

* Certification Agency

input response here

* Certification Number

input response here

Attachments

⊕ upload files