

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Source Building Group

651 East Debbie Lane, BLDG 200, Mansfield, TX 76063, United States of America

Sunny Fung | Estimator / Quantity Surveyor | +1 469-835-7725 | sfung@sourcebuild.net



Line Items

Description	Quantity	Unit Cost	Total Cost
BID FORM (8/28):			
* Access Control			\$
Base Bid			\$0

Alternates

OWNER BID ALTERNATES:

* None at this time. \$

:

SCOPE ALTERNATES:

* None at this time. \$

Inclusions

Mark "yes" to all yes/no questions »

* MATERIAL ☐ Yes ☐ No

* INSTALLATION ☐ Yes ☐ No

SPECIFICATION(S) ACKNOWLEDGEMENT:

* 28 05 00 - COMMON WORK RESULTS FOR ELECTRONIC SAFETY & SECURITY ☐ Yes ☐ No

* 28 13 00 - ACCESS CONTROL SYSTEM ☐ Yes ☐ No

Scope of Works:

* PER T05-01 ELECTRIC LOCKSET - DOUBLE DOORS - CARD READER - REFER TO DOOR RESPONSIBILITY MATRIX, DATA CABLE, IF POE READER SUPPLIED AND INSTALLED BY COMMUNICATION CONTRACTOR ☐ Yes ☐ No

General:

* ACCESS CONTROL PANELS ☐ Yes ☐ No

* ACCESS CONTROL ENCLOSURES & POWER SUPPLIES ☐ Yes ☐ No

* CARD READERS ☐ Yes ☐ No

* POSITION SWITCHES ☐ Yes ☐ No

* DURESS BUTTONS ☐ Yes ☐ No

* WIRE & CABLE ☐ Yes ☐ No

Warranties:

* A. Installer - Provide one year installer warranty on parts and labor. ☐ Yes ☐ No

* B. Manufacturer - Provide standard manufacturer warranty for components provided. ☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Q&A Project Specific Items as of 8/27/26:**Q1. Outdated Part Numbers:**

* Q: Please confirm desired card reader and Lenel control board part numbers, specification part numbers are outdated.

☐ Yes ☐ No

Asked 8/18/2026 at 3:57 PM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.). The Owner will install the cabling, terminate the wires, and install the system.

Answered 8/26/2026 at 9:29 AM CDT by Amanda Usrey

Q2. Security Device Model Numbers:

* Q: Please provide desired model numbers for the "EP" emergency blue pull stations and the "DR" security door release buttons shown on plans.

☐ Yes ☐ No

Asked 8/18/2026 at 3:57 PM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.). The Owner will install the cabling, terminate the wires, and install the system.

Answered 8/26/2026 at 9:29 AM CDT by Amanda Usrey

Q3. "KP" Security Keypad:

* Q: For the "security keypad" KP symbol shown on the security plans, there is no specification for this symbol. Is this a card reader with integrated keypad? Please provide desired model number.

☐ Yes ☐ No

Asked 8/18/2026 at 3:57 PM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.). The Owner will install the cabling, terminate the wires, and install the system and devices

Answered 8/26/2026 at 9:30 AM CDT by Amanda Usrey

Q4. Access Control Panels/Power Supplies:

* Q: Is there an existing access control panel that can be used and expanded, as well as power supplies, or will new enclosures and power supplies be needed?

☐ Yes ☐ No

Asked 8/18/2026 at 3:56 PM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.). The Owner will install the cabling, terminate the wires, and install the system and devices

Answered 8/26/2026 at 9:30 AM CDT by Amanda Usrey

Q5. IDF Closet Location:

* Q: Where is the IDF closet located that will be used for access control doors on this project?

☐ Yes ☐ No

Asked 8/18/2026 at 3:56 PM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.) to the nearest accessible corridor ceiling. The Owner will install the cabling, terminate the wires, and install the system.

Answered 8/26/2026 at 9:31 AM CDT by Amanda Usrey

Q6. Licensing for VMS:

* Q: Specifications state to provide licensing for video surveillance integration with the card readers and reference the video surveillance specs, which are not provided. Is this licensing required, and if so, which VMS is in use?

☐ Yes ☐ No

Asked 8/18/2026 at 3:55 PM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.). The Owner will install the cabling, terminate the wires, and install the system.

Answered 8/26/2026 at 9:31 AM CDT by Amanda Usrey

Q7. Lenel Licensing Confirmation:

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Q: Specifications state to provide Lenel licensing for new reader additions (64 reader expansion) – will this be required on this project?

☐ Yes ☐ No

Asked 8/18/2026 at 3:55 PM CDT

A: Not applicable. The Owner will provide all security licenses and perform all terminations.

Answered 8/26/2026 at 9:31 AM CDT by Amanda Usrey

Q23. Security Cable Topology:

* Q: Please provide the existing cable topology that the new security cabling should match as indicated in general note B on sheet TS-201.

☐ Yes ☐ No

Asked 8/18/2026 at 2:02 PM CDT

A: Will be provided and installed by owner

Answered 8/26/2026 at 9:41 AM CDT by Amanda Usrey

Q35. Low voltage cabling and Access Controls:

* Q: Please confirm low voltage cabling and access controls including card readers are by Owner

☐ Yes ☐ No

Asked 8/18/2026 at 8:11 AM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.) to the nearest accessible corridor ceiling. The Owner will install the cabling, terminate the wires, and install the system.

Answered 8/26/2026 at 9:46 AM CDT by Amanda Usrey

Q42. Access control scope:

* Q: Please confirm desired card reader and Lenel control board part numbers, specification part numbers are outdated

☐ Yes ☐ No

Asked 8/12/2026 at 3:32 PM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.). The Owner will install the cabling, terminate the wires, and install the system.

Answered 8/26/2026 at 11:47 AM CDT by Amanda Usrey

Q45. Access control scope:

* Q: Is there an existing access control panel that can be used and expanded, as well as power supplies, or will new enclosures and power supplies be needed?

☐ Yes ☐ No

Asked 8/12/2026 at 3:31 PM CDT

A: The contractor is responsible for providing raceways (conduit, wall boxes, etc.). The Owner will install the cabling, terminate the wires, and install the system and devices

Answered 8/26/2026 at 11:46 AM CDT by Amanda Usrey

Q78. Security Door Hardware Clarification:

* Q: The Door and Frame Schedule on sheet A-551 references door 4.430G receiving hardware set C201GPW. Per the hardware schedule, this door receives a card reader and electric components that are not shown on TS-201. Please confirm hardware requirements for door 4.430G.

☐ Yes ☐ No

Asked 4/15/2026 at 3:27 PM CDT

A: SSR: The door's card reader was removed during a review for addendum 1 issue. Aprox 3-9-2026. Card reader is to remain removed, and hardware set is to be adjusting accordingly.

Answered 8/6/2026 at 8:52 PM CDT by Marcus Howard

Scope-Specific Information and Unit Costs

Mark "yes" to all yes/no questions »

Unit Cost:

Bid Quantities:

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

Scope-Specific Clarifications**Specific Exclusions:**

None at this time.

General Acknowledgments

Mark "yes" to all yes/no questions »

GENERAL INFECTION CONTROL NOTES:

- * Maintain/meet a Class IV infection control classification. ☐ Yes ☐ No
- * A. OBTAIN FROM THE OWNER A COPY OF THE INFECTION CONTROL RISK ASSESSMENT (ICRA) PREPARED FOR THIS PROJECT. REVIEW THE REQUIREMENTS IN THE REPORT AND PERFORM ALL WORK IN ACCORDANCE WITH THOSE PROTOCOLS. STRICTLY ADHERE TO THE LIMITS OF THE CONSTRUCTION AREA, AND WHERE PHASING APPLIES, ADHERE TO PHASING PLAN. COORDINATE ANY WORK OUTSIDE THE CONSTRUCTION AREA WITH THE OWNER AND PERFORM IT IN ACCORDANCE WITH THE ICRA REPORT, UNDER THE SUPERVISION OF THE OWNER'S REPRESENTATIVE OR OTHER DESIGNATED ICRA COMMITTEE OFFICER. ☐ Yes ☐ No
- * B. TO THE EXTENT THAT IS REQUIRED BY THE ICRA, ENDEAVOR TO MAINTAIN EXISTING LEVELS OF INDOOR AIR QUALITY IN AREAS SURROUNDING AND ADJACENT TO THE CONSTRUCTION WORK ZONE, AND ELSEWHERE IN THE FACILITY. IT SHOULD BE ANTICIPATED THAT THE ICRA REPORT WILL REQUIRE MEASURES TO THIS EFFECT, INCLUDING THE ASSEMBLY OF THE CONSTRUCTION ZONE BARRIERS. ☐ Yes ☐ No
- * C. PERFORM CONSTRUCTION ACTIVITIES IN AREAS THAT ARE OCCUPIED BY THE HOSPITAL STAFF, THE GENERAL PUBLIC, OR HOSPITAL PATIENTS PER THE REQUIREMENTS OF THE OWNER'S ICRA. WHERE CONSTRUCTION ACTIVITIES HAVE BEEN COMPLETED, RETURN THE AREA TO "CLEAN" CONDITIONS, AS DEFINED BY THE OWNER'S PROTOCOLS, BEFORE IT IS OCCUPIED BY THE HOSPITAL STAFF, THE GENERAL PUBLIC, OR HOSPITAL PATIENTS. ☐ Yes ☐ No

Work Hours & Restrictions:**On-Site Work Hours:**

- * Owner's Special Conditions set normal hours at 7:00 AM–5:00 PM; after hours 6:00 PM–6:00 AM; weekends permitted. Work generating excessive noise, odor, or vibration, and any work above the active Level 3 operating rooms, must be performed after hours or on weekends (Owner has confirmed all work above active ORs is overtime/night work). Flooring scope is on Level 4 inside the contained renovation area, so we anticipate straight time – but carry the flexibility, and note the GC is responsible for OT/weekend work needed to hold schedule. ☐ Yes ☐ No

Work Restrictions:

- * THE BUILDING WILL BE OCCUPIED DURING CONSTRUCTION. COORDINATE WITH OWNER ON SCHEDULING CONSTRUCTION OPERATIONS THAT GENERATE VIBRATION, NOISE, SECURITY CONCERNS, POWER INTERRUPTIONS, SMELLS OR OTHER CONSTRUCTION ACTIVITIES THAT MAY DISRUPT OPERATION IN ADJACENT SPACES. ☐ Yes ☐ No
- * Comply with limitations on use of public streets and other requirements of authorities having jurisdiction. ☐ Yes ☐ No

Jobsite Access:

- * This is a renovation inside Clements University Hospital with active clinical space adjacent and below. ICRA/infection control applies: negative air machines with HEPA at all times, hard-panel containment barriers, tacky and walk-off mats, covered trash buggies with wheels cleaned entering/leaving, daily debris removal. All personnel need UTSW badges and current UTSW safety training. No free parking – UTSW parking policy applies. ☐ Yes ☐ No

Parking:

- * No free parking. Parking is as per UTSW parking policy. ☐ Yes ☐ No

Employee Identification:**Addendum Acknowledgment:**

- * Addendum 1 ☐ Yes ☐ No
- * Addendum 2 ☐ Yes ☐ No
- * Addendum 3 ☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* Addendum 4 ☐ Yes ☐ No

* Addendum 5 ☐ Yes ☐ No

* Addendum 6 ☐ Yes ☐ No

* Addendum 7 ☐ Yes ☐ No

* Addendum 8 ☐ Yes ☐ No

* Addendum 9 ☐ Yes ☐ No

Q&A Acknowledgement:

* Q&A Dated 08-26-2026 ☐ Yes ☐ No

Taxes:

* Sales Tax on Materials Included? ☐ Yes ☐ No

* Cost Breakout of Sales Tax on Materials ==> ENTER DOLLAR VALUE \$

Lead Times:

* Shop Drawing / Submittal Lead Time

* Product Lead Time Description(s) & # of Weeks

Labor Rates:

* Wage Rates per project requirements (i.e., Prevailing Wage, Davis Bacon, etc. As Applicable) ☐ Yes ☐ No

The undersigned acknowledges that material substitutions are not permitted unless expressly approved in writing by Arch/Eng through Requests for substitutions must include detailed specifications and documentation for review and approval prior to bid submission:

Please acknowledge that you have read and agree with the information, procedures, and requirements listed in the following Specifications & Documents:

00 - RFP:

* RFP_Sealed_Proposal_-_CUH_3T_MRI_WITH_HIFU_AND_TULSA ☐ Yes ☐ No

01 - Plans:

* Campus Map ☐ Yes ☐ No

* UTSW-CUH-MRI 4 IFC DRAWING SET ☐ Yes ☐ No

02 - Specifications:

* UTSW-CUH-MRI 4 IFC PROJECT MANUAL ☐ Yes ☐ No

03 - Addenda:**04 - Owner's Special Conditions:**

* Owner's Special Conditions ☐ Yes ☐ No

05 - Safety & Security:

* Construction Site Safety Manual FY22 ☐ Yes ☐ No

* Environmental of Care Fire & Life Safety Policy ☐ Yes ☐ No

* Project Safety Requirements ☐ Yes ☐ No

06 - Planning & Scheduling:

* Project Planning and Scheduling ☐ Yes ☐ No

07 - UTSW Uniform Specs & Acknowledgements:

* Project Quality Control ☐ Yes ☐ No

26-0024: UTSW CUH 4.219 Microbiology Lab

6201 Harry Hines Boulevard, Dallas, TX 75235, United States of America

* UGCs

☐ Yes ☐ No**08 - Wage Rates:**

* Wage Determination

☐ Yes ☐ No**09 - Q&A Clarifications:****10 - Additional Information:**

* Change Order Form CSP

☐ Yes ☐ No

* CUH Asbestos Free Letter

☐ Yes ☐ No

* General Commissioning Requirements

☐ Yes ☐ No

* Project Administration Templates

☐ Yes ☐ No

* Project Closeout Procedures

☐ Yes ☐ No

* utsw design guidelines vol 1 ada

☐ Yes ☐ No

* utsw design guidelines vol 2 ada

☐ Yes ☐ No

* utsw design guidelines vol 3 ada

☐ Yes ☐ No

* UTSW_VETHUB_SP_v2

☐ Yes ☐ No**Bond Information**

* Payment & Performance Bond Add (If Required) % Percentage OR

%

* Payment & Performance Bond Add (If Required) Dollar Amount

\$

Certifications

* Certified VetHUB? (Project goal of 1%)

☐ Yes ☐ No

* Participation Included in Base Bid (% of VetHUB subcontractor total base bid)

input response here

* Certification Agency

input response here

* Certification Number

input response here

Attachments upload files