

Construction Project Specification (Sample)

1. Project Overview

This sample specification is created for learning Retrieval-Augmented Generation (RAG).

2. Concrete Specification

Concrete grade for columns: M40. Concrete grade for beams: M30. Concrete grade for slabs: M25. Concrete cover: Columns 40 mm, Beams 30 mm, Slabs 25 mm. Curing period: 14 days.

3. Reinforcement

Main reinforcement shall use Fe500 steel. Lap length shall follow design drawings.

4. Brickwork

Use first-class clay bricks. Standard brick size is 190 x 90 x 90 mm. Mortar ratio 1:6.

5. Foundation

Footing type: Isolated footing. Minimum excavation depth: 1.5 m.

6. Safety

Workers shall wear helmets, safety shoes, reflective jackets, gloves, and safety goggles. Fall protection is mandatory above 2 meters.

7. Quality Control

Concrete cube tests at 7 and 28 days. Slump test required before every concrete pour.

8. BOQ Extract

Item 1: M40 Concrete for Columns. Item 2: M30 Concrete for Beams. Item 3: Reinforcement Fe500.

9. Painting

Interior walls: Acrylic emulsion. Exterior walls: Weather-resistant paint.