





1. MINIMUM EQUIPMENT STANDARD FOR DUST HAZARDS TO MEET INGRESS PROTECTION (IP) RATING OF 5X (ZONE 22) AND 6X (ZONE 21) AND A MAXIMUM SURFACE TEMPERATURE OF 205°C BASED ON 280°C (LIT) - 75°C = 205°C.

3. A ZONE 21 WITHIN THE DISCHARGE CHUTES. REFER [1] TABLE 2.

- [1] 7619_REP01 ROYAL SEAFORTH GRAIN TERMINAL DSEAR HAZARDOUS AREA CLASSIFICATION REPORT.

A 



A



PROJECT
DSEAR AREA CLASSIFICATION

IEC PROJECT No. 7840

IEC DRAWING No. 7840-73-00019

TITLE	ROYAL SEAFORTH GRAIN TERMINAL SILO 2 BASEMENT BB4/5 TO BB6/7 AREA CLASSIFICATION DRAWING
-------	--

EV.

A