TO LORRIES

HAND VALVE LIMIT — 135 — D189 — TD189 — OPEN
136 — D190 — TD190 — CLOSE

RECEIVING BELT RB4

HS/107 — 137 — D192 — TD192 — HAND TEST
15/107 — 138 — D193 — TD193
TF — 139 — D194 — TD194 — GRAIN FLOW
PR5 — 140 — D195 — TD195 — STOP
141 — D196 — TD196 — START

SURGE BIN No1
VALVE No1 RSB1V1

SU1-33-3 — LCC1-28-2 — 1246 — D197 — TD197 — HIGH LEVEL WARNING
LCC1-30-11 — 1208 — D198 — TD198 — HIGH LEVEL ALARM
R2 — 163 — D169 — TD169 — HAND TEST
LINK TO 150 — 164 — D170 — TD170
R91 — 165 — D171 — TD171 — OPEN
166 — D172 — TD172 — CLOSE
1214 — VALVE POSITION INDICATOR — 1215
POTENTIOMETER (PLANT)

VALVE No 2
RSB1V2

R5 — 167 — D173 — TD173 — VALVERSB1V2 ROUTE TO L1
R6 — 168 — D174 — TD174 — VALVERSB1V2 ROUTE TO L2
R8 — 169 — D175 — TD175 — HAND TEST
LINK TO 255 — 170 — D176 — TD176

LORRY WEIGHBACK CHAIN CONVEYOR
LWCC2

PR2 — 151 — D177 — TD177 — START
152 — D178 — TD178 — STOP
R2 — 1223 — D179 — TD179 — CHOKE
HS/64 — 153 — D180 — TD180 — HAND TEST
15/64 — 154 — D181 — TD181

LORRY WEIGHBACK CHAIN CONVEYOR
LWCC1

PR1 — 155 — D182 — TD182 — START
PR1 — 156 — D183 — TD183 — STOP
R1 — 1227 — R30 & R30A — D184 — TD184 — CHOKE
HS/63 — 157 — D185 — TD185 — HAND TEST
15/63 — 158 — D186 — TD186

DUST BIN

R31 & R31A — D236 — TD236 — HIGH LEVEL WARNING
HLA — 1236 — R32 & R32A — D237 — TD237 — HIGH LEVEL ALARM
SBD — 1239 — D238 — TD238 — SIMON BIN (SBD) DISCHARGER RUNNING

GROUP 1
DUST PLANT

R88 — 62 — D190 — TD190 — START
63 — D191 — TD191 — STOP
LINK TO 1238 — 232

172	D200	TD200	HAND	DUST PLANT 1	
173	D201	TD201	TEST		
164	D192	TD192	RUNNING		
174	D202	TD202	HAND	DUST PLANT 2	
175	D203	TD203	TEST		
165	D193	TD193	RUNNING		
176	D204	TD204	HAND	DUST PLANT 3	
177	D205	TD205	TEST		
166	D194	TD194	RUNNING		
178	D206	TD206	HAND	DUST PLANT 4	
179	D207	TD207	TEST		
167	D195	TD195	RUNNING		
180	D208	TD208	HAND	DUST PLANT 6	
181	D209	TD209	TEST		
168	D196	TD196	RUNNING		
182	D210	TD210	HAND	DUST PLANT 7	
183	D211	TD211	TEST		
169	D197	TD197	RUNNING		
184	D212	TD212	HAND	DUST PLANT 7A	
185	D213	TD213	TEST		
170	D198	TD198	RUNNING		
186	D214	TD214	HAND	DUST PLANT 8	
187	D215	TD215	TEST		
171	D199	TD199	RUNNING		

LINK TO 206 — 186
LINK TO 207 — 187

GROUP 2
DUST PLANT

188	D216	TD216	START		
189	D217	TD217	STOP		
196	D224	TD224	HAND	DUST PLANT 1	
197	D225	TD225	TEST		
190	D218	TD218	RUNNING		
198	D226	TD226	HAND	DUST PLANT 2	
199	D227	TD227	TEST		
191	D219	TD219	RUNNING		
200	D228	TD228	HAND	DUST PLANT 3	
201	D229	TD229	TEST		
192	D220	TD220	RUNNING		
202	D230	TD230	HAND	DUST PLANT 4	
203	D231	TD231	TEST		
193	D221	TD221	RUNNING		
204	D232	TD232	HAND	DUST PLANT 5	
205	D233	TD233	TEST		
194	D222	TD222	RUNNING		
206	D234	TD234	HAND	DUST PLANT 8	
207	D235	TD235	TEST		
195	D223	TD223	RUNNING		

THE DESIGN AND MANUFACTURING INFORMATION CONTAINED IN THIS DRAWING IS THE EXCLUSIVE RIGHT OF DEWHURST & PARTNER LTD. AND MUST NOT BE COPIED OR USED FOR MANUFACTURING PURPOSES.

ISSUE 1 2

SCHEMATIC DIAGRAM FOR SUPERVISORY CONTROL PANEL SHEET 4 OF 12

53

DEWHURST & PARTNER LTD.
MELBOURNE WORKS HOUNSLOW

TITLE: SCHEMATIC DIAGRAM FOR SUPERVISORY CONTROL PANEL - SEAFORTH GRAIN TERMINAL

REVISION :	REVISION :	REVISION :	REVISION :	REVISION : 1	DRAWN BY	KEY DIAG. No.
ORIGIN : / / SGD.	ORIGIN : / / SGD.	ORIGIN : / / SGD.	ORIGIN : / / SGD.	LEVEL CONTROL CONTACTS WERE H/O. ORIGIN : rcb. 19/3/73 SGD. JS	DATE 4/1/73	EXT. DIAG. No.
					CHECKED BY	REL. DIAG. No.
					APPROVED BY	PANEL LAYOUT No.
					DATE	

DTX 361AR/4

G.A.P. 7331/78