10732

MAIN FUSE SWITCH MFS
INCOMING SUPPLY L1 IL1, L2 IL2, L3 IL3, N NN
VOLTMETER FUSES & NEUTRAL LINK VF & VNL
VOLTMETER SELECTOR SWITCH VSS
VOLTMETER
CONTROL SUPPLY SWITCHFUSE
C/O SWITCH
PT CT1 S1 S3 SF1
P2 CT2 S4 S2 3
P3 CT3 S4 S5 3
P1 S4 S6 SF2 3

MF NEUTRAL LINK NL — IS — A B C NN
MOTORISED HOIST FEEDER - (18.319. 520. 521)

MF NL — IS — A NN
M^R 114 STARTER FEEDER (TERMS:- 522. 523)

MF - MAIN FUSES
IS - ISOLATOR
OL - OVERLOAD
MC - MAIN CONTACTOR
DUST FILTER DRIVE DFD7A-(TERMS:-506, 507A 508)
ROTARY VALVE RV7A - (TERMS:- 509, 510A 511)

EARTH LEAKAGE RELAY ELR
ELRT ELCT EARTH LEAKAGE TRANSFORMER
AMMETER
DUST FAN DF7A (TERMS:- 500, 501A, 502)
DUST FILTER FAN DFF 7A (TERMS:- 503, 504A 505)
PONY MOTOR J12P (TERMS:- 524, 525A 526)

OVERLOAD CURRENT TRANSFORMER OLCT
AMMETER CURRENT TRANSFORMER ACT
RECEIVING CHAIN CONVEYOR RCC2 (TERMS:- 512, 513A, 514)

RECEIVING BELT RB2 (TERMS:- 515, 516A, 517)
JUNCTION TOWER ELEVATOR J L 2 (TERMS:- 527, 528A. 529)
POWER FACTOR CORRECTION CAPACITORS

CONTROL POWER RELAY 2
DCE RB2 4,5,7,9.
RUNNING
STOPPED
PULSE AIR UNIT
INTER LOCK RELAY. 76.
D.C.E/RB2.
DCE RC2 13,14,16,17.
RUNNING
STOPPED
PULSE AIR UNIT
INTERLOCK RELAY. 58.
D.C.E/RC2.

PILOT RELAY 58
TIMER 54
MAIN CONTACTOR 54, 56, 62, 63
SLAVE RELAY 67, 68, 72
PRESSURE SWITCH RELAY 93, 69
PRESSURE SWITCH
RUNNING
STOPPED
ISOLATOR RELAY 54, 57
HAND INDICATION
TEST INDICATION
RUNNING INDICATION
STOPPED INDICATION
BLOCKAGE INDICATION
TO DESK
PR2 TO DCE/RC2.
DC JTX 361V/10 90-110
RECEIVING CONVEYOR RC2 (M^R 105)

PILOT RELAY 76, 87, 88
TIMER 73
TIMER 77, 79
HORN RELAY 78
MAIN CONTACTOR 73, 76, 83, 84
SLAVE RELAY
ISOLATOR RELAY 73, 76
TIMER 89
RUNNING
STOPPED
HAND INDICATION
TEST INDICATION
RUNNING INDICATION
STOPPED INDICATION
GRAIN FLOW INDICATION
TO DESK
PR3 TO DCE/RB2.
D7-8 JTX 361V/11 120-142
RECEIVING BELT RB2 (M^R 107)

MAIN CONTACTOR 32, 94, 96
SLAVE RELAY 98, 99, 101, 102
ELEVATOR 54'-0" CASTELL KEY SWITCH
ELEVATOR BOOT CASTELL KEY SWITCH
START
RUNNING INDICATION — TO DESK
(NOT USED)
FG JTX 361V/4 147-158
PONY MOTOR J L 2P (M^R 103)

FROM MCC 2C
PILOT RELAY 113
TIMER 105
ELEVATOR HEAD CASTELL KEY SWITCH
ELEVATOR BOOT CASTELL KEY SWITCH
MAIN CONTACTOR 109, 111, 53
SLAVE RELAY 110, 119, 124, 125, 105
ISOLATOR RELAY 115, 105
CHUTE BLOCK RELAY 104, 126
HAND INDICATION
TEST INDICATION
RUNNING INDICATION
STOPPED INDICATION
BLOCKAGE INDICATION
GRAIN FLOW INDICATION
TO DESK
TIMER 127
CHOKE ELEVATOR HEAD 116. 122
CHOKE ELEVATOR BOOT 116
F7-8 JTX 361V/17 170-198
JUNCTION TOWER
ROUTE SELECTOR (DESK)
(RB2 BELT RUNNING)
RELAY 133
RELAY 132
R10 (FROM MCC 1A) (RB1 BELT RUNNING)
(RB1 RUNNING)
(RB2 RUNNING)
TO MCC 9 (MARINE TOWER 2)
TO MCC 1A
114-119 143-145
DCE RB No.4 43, 139, 141
PULSE-AIR UNIT No. 4
REVERSE JETTING SWITCH
JUNCTION HOUSE COMPRESSOR No.2 137, 149.

▲ DENOTES CONTACTS MADE IN 'ON' AND 'TEST' POSITIONS.
DENOTES CONTACTS MADE IN 'TEST' POSITION ONLY
DENOTES CONTACTS MADE IN 'ON' POSITION ONLY.

REVISION: 12	REVISION: 11	REVISION: 10	REVISION: 9
WIRING MODS FROM DUST PLANTS TO D·C·E UNITS ADDED: 27.9.89 GD	WIRING MODS. TO CHUTE BLOCK RELAY RELAYS R13 & R14 ADDED. 22.4.86 EP	NEW COMPRESSOR FITTED IN JUNCTION HOUSE FOR D.C.E No 2 EXTRA COMPRESSOR FITTED 28-1-88 EP	NEW DUST PLANT (DCE) & COMPRESSOR IN J/HOUSE FOR RB No 4 & DCE/RB No 3 & 4. 5-3-91 EP
REVISION: 3	REVISION: 2	REVISION: 1	
ON RB2 SUSTAINING CONTACT WAS ON M.C. ORIGIN: / / SGD.	BLOCKAGE INDICATION FEED MODIFIED. MINOR MODS. MCC 9B TERMINALS MODIFIED ORIGIN: E.J.S.R 11/3/71. SGD. J.T.	HORN REMOVED ORIGIN: E.J.S.R 29/2/72 SGD J.T.	

DRAWN BY	THOMAS
DATE	18/2/71
CHECKED BY	
APPROVED BY	
DATE	

KEY DIAG. Nº	
EXT. DIAG. Nº	STX 361 AB
REL. DIAG. Nº	JTX 361 AB
PANEL LAYOUT Nº	HTX 361 AB

THE DESIGN AND MANUFACTURING INFORMATION CONTAINED IN THIS DRAWING IS THE EXCLUSIVE RIGHT OF DEWHURST & PARTNER LTD. AND MUST NOT BE COPIED OR USED FOR MANUFACTURING PURPOSES

SCHEME FOR MCC 1B SEAFORTH GRAIN TERMINAL

ISSUE 1 2 3 4 5 6 7 8 9 10 11 12

DTX 361 AB

DTX 361 AB

DEWHURST & PARTNER LTD.
MELBOURNE WORKS HOUNSLOW

TITLE: SCHEME FOR MCC 1B — SEAFORTH GRAIN TERMINAL

REVISION: 8	REVISION: 7	REVISION: 6	REVISION: 5	REVISION: 4
CONTACT R110 ADDED ON LINE 43. 9-8-77.	RELAYS R11 & R12 REVERSED ORIGIN: SITE 14/12/72 J.S.	CONNECTIONS TO MCC 9B MODIFIED ORIGIN: CUST. 14/2/72 J.S.	DESK TERMINALS ADDED ORIGIN: I.C.D. 24/1/72 SGD. J.S	MODS TO RCC2, RB2 AND JL2. ORIGIN: E.J.S.R 1/6/71 SGD. B.J.C.

* DCE Mods Attached. SUPERCEDED *