

FRONT VIEW OF PANEL

DEWHURST & PARTNER LTD.

MELBOURNE WORKS

HOUNSLOW

REVISION 2
MOTOR MOD 1
WIRE SIZE
ADDED
ORIGIN: EIP
11/11/70 SGD. S

REVISION 1
MOD TO NOTES
MOTOR COLOUR
CODE REMOVED
ORIGIN: EIP
2/11/70 SGD. S

DRAWN BY :- J.S.
DATE :- 25/11/70
CHECKED BY
APPROVED BY
DATE

COMPOSITE WIRING DIAGRAM FOR RAIL LOADING PANELS
SEAFORTH GRAIN TERMINALS

THE DESIGN AND MANUFACTURING
INFORMATION CONTAINED IN
THIS DRAWING IS THE EXCLUSIVE
RIGHT OF DEWHURST & PARTNER
LTD. AND MUST NOT BE COPIED
OR USED FOR MANUFACTURING
PURPOSES.

KEY DIAG. No. BTY361BA
EXT. DIAG. No. ---
REL. DIAG. No. ---
PANEL LAYOUT No. BTY361BA

ISSUE 1 2 3 4 5 6 7

QTY 361 BA

QTY 361 BA

REVISION: 6
HEATER FUSE ADDED
WIRING MOD.
DESK TERMS
ADDED
ORIGIN: ICB
9/12/72 JS

REVISION: 5
FEED TO LAMP
ON SCP ADDED
ORIGIN: ICB
16/11/71 JT

REVISION: 4
WIRES 5 & 10
MODIFIED
ORIGIN: EIP
21/11/71 JT

REVISION: 3
WIRE MARKER
10-114 ADDED
ORIGIN: EIP
12/11/71 JT

NOTE: ALL CONTROL WIRING TO BE MARKED WITH HELLEMAN MARKER.
CONTROL WIRING TO BE BLACK. MAIN & CONTROL WIRE TO BE 32/0.2 mm

