10905

ISOLATOR 1S
EARTHING SWITCH EF SW
INCOMING SUPPLY 3300 V 3 PHASE 50 HZ
L1 L2 L3 R Y B
1F 2F 4F 5F
CONTROL VOLTAGE TRANSFORMER (1000 VA)
1 CVT 2 CVT (1000 VA)
3300V 110V
No 1 CONTROL SUPPLY ON
No 2 CONTROL SUPPLY ON
SL1 SL2
SELECTOR SWITCH 1SS
(1CVT) (2CVT)
LINE
STAGE 3 MOTOR HEATER 400 W
STAGE 4 MOTOR HEATER 400 W
9F 8F 7F 10F
VOLTMETER 0-4 kv
3 CVT (160 VA) 110 V 135 V
RECTIFIER 1W
EMERGENCY STOP (PANEL)
EXPLOSION SWITCH 1
EXPLOSION SWITCH 2
CR (SCP)
REMOTE TRIP RELAY 1
REMOTE TRIP RELAY 2
IN MEAT BERTH SUBSTATION
RELAY 14,42
A19 A24

ISOLATOR 1S
MAIN FUSES M1
CONTACTOR C
OVERLOAD OL
OVERLOAD CTs
2 AMMETER CTs IN SERIES
AMMETER PANEL
AMMETER SCP
STALLING RELAY CT
CORE BALANCE TRANSPORMER CBT
EARTH LEAKAGE RELAY ELR
MOTOR EARTHING CONTACTS
CAPACITOR
MOTOR

STAGE 3
ELEVATOR LEG No 1.

STAGE 4
ELEVATOR LEG No 2

STALLING RELAY SR1
STALLING RELAY SR2
ELEVATOR HEAD KEY SWITCH
ELEVATOR BOOT KEYSWITCH
SELECTOR SWITCH 5S2
AUTO HAND
TEST 1 TEST 2 NORMAL
MCC 2A MCC 3B
ELEVATOR STOP/LOCKS HEAD BOOT
STOP ISOLATOR (PANEL) PUSH OLT ELT CBR
CONTACTOR PILOT RELAY 20,24,34,34
TIMING RELAY 25
TIMING AUXILIARY RELAY 20,27 (0-15 SEC)
INTERLOCK RELAY 36,37,38,39,40
CHUTE BLOCK RELAY 20,41
OVERLOAD TRIP RELAY (LATCHED) 20
EARTH LEAKAGE TRIP RELAY (LATCHED) 20
HOURS RUN COUNTER
PRESSURE PAD SWITCHES PPSW1 PPSW2
RECTIFIER W
ECONOMY CP RESISTOR
CONTACTOR 1,27,29,38,39
INDICATION ON SCP
TEST RUNNING STOPPED CHUTE BLOCKAGE

CONTACTOR PILOT RELAY 48,52,62,62
TIMING RELAY 53
TIMING AUXILIARY RELAY 48,55 (0-15 SEC)
INTER LOCK RELAY 64,64,65,65,66
CHUTE BLOCK RELAY 48,69
OVERLOAD TRIP RELAY (LATCHED) 48
EARTH LEAKAGE TRIP RELAY (LATCHED) 48
HOURS RUN COUNTER
CONTACTOR 2,55,67,66,67

10905

NOTE:-
A TERMINAL REFERENCE SHOWN THUS MCC 4A3-21
REFERS TO TERMINAL 21 ON STAGE 3 OF MCC 4 A

SCHEMATIC DIAGRAM FOR MCC 4A

THE DESIGN & MANUFACTURING INFORMATION CONTAINED IN THIS DRAWING IS THE EXCLUSIVE RIGHT OF DEWHURST & PARTNER LTD. AND MUST NOT BE COPIED OR USED FOR MANUFACTURING PURPOSES.

ISSUE 1 2 3

DTX 361 AF/1

DEWHURST & PARTNER LTD
MELBOURNE WORKS HOUNSLOW

TITLE
SCHEMATIC DIAGRAM FOR MCC 4 A
(AS GEC SCHEME X3119326)

REVISION:	REVISION:	REVISION:	REVISION: 2	REVISION 1
ORIGIN:	ORIGIN	ORIGIN:	ECONOMY RESISTORS ADDED	STOP INTERLOCK CIRCUIT MODIFIED
/ / SGD	/ / SGD	/ / SGD.	ORIGIN 18/9/72 SGD	ORIGIN: ICD 14/4/72 SGD J.S

DRAWN BY	KEY DIAG No
DATE 13/3/72	EXT. DIAG. Nº RTX 361 AF
CHECKED BY	REL DIAG No
APPROVED BY	PANEL LAYOUT Nº X3119325 (GEC)
DATE	

DTX 361 AF/1