INCOMING SUPPLY 3300V 3 PHASE 50HZ

ISOLATOR 1S — EARTHING SWITCH EFSW — L1 L2 L3 — R Y B

CONTROL VOLTAGE TRANSFORMER (1000VA) 1CVT 3300/110V — 2CVT 3300/110V (1000VA)

No1 control supply on — SW1 — No2 control supply on — SW2

SELECTOR SWITCH 1SS

1F 2F 3F 4F 5F 6F 7F

STAGE 3 C — STAGE 3 MOTOR HEATER 4.0KW

STAGE 4 — STAGE 4 MOTOR HEATER 4.0KW

VOLTMETER V 0-440V

2CVT (1000VA) 110V/135V — 1R RECTIFIER

EMERGENCY STOP (PANEL)

EXPLOSION SWITCH 1 — EXPLOSION SWITCH 2

CR (SCP)

RTR1 60V — REMOTE TRIP RELAY 1

RTR2 60V — REMOTE TRIP RELAY 2

R — RELAY 1A, 4Z

IN MEAT BERTH SUBSTATION

LINK

STAGE 3
ELEVATOR LEG No1

ISOLATOR 1S — MAIN FUSES M1 — CONTACTOR C — OVERLOAD CT's

OVERLOAD OL — 2 AMMETER CT's IN SERIES — A1 AMMETER PANEL — A2 AMMETER SCP (1004, 1005)

STALLING RELAY CT. — CORE BALANCE TRANSFORMER CBT — EARTH LEAKAGE RELAY ELR

MOTOR EARTHING CONTACTS — CAPACITOR — MOTOR

STAGE 4
ELEVATOR LEG No 2

1S M1 C — OL — CT1 CT2 CT3 CT4 CT5 — A1 A2 SCP (1034, 1035)

CBT — ELR

MOTOR EARTHING CONTACTS — CAPACITOR — MOTOR

STALLING RELAY 5S1

SELECTOR SWITCH 5S2 — AUTO / HAND — TEST

ELEVATOR HEAD KEYSWITCH — ELEVATOR BOOT KEYSWITCH

MCC 2A — R7 R6 1SR5 1SR6 R5 R4 — SCP STOP — MCC3B R2 — ELEVATOR STOP LOCKS HEAD BOOT

STOP (PANEL) — ISOLATOR PANEL — OLT — ELT — CBR — 5S2

CP — TIMING RELAY TR — TRA (0-15SEC)

CONTACTOR PILOT RELAY 20, 26, 29, 24

TIMING RELAY 25

TIMING AUXILIARY RELAY 22, 27

PRESSURE PAD SWITCHES PPSW1 PPSW2

INTERLOCK RELAY IR 34, 37, 38, 39, 49

CHUTE BLOCK RELAY CBR 20, 41

OVERLOAD TRIP RELAY (LATCHED) OLT 20

EARTH LEAKAGE TRIP RELAY (LATCHED) ELT 20

HOURS RUN COUNTER HRC

RECTIFIER W — ECONOMY RESISTOR C — CONTACTOR 1, 17, 28, 38, 39

INDICATION ON SCP: TEST, HAND, RUNNING, STOPPED, CHUTE BLOCKING

MCC 2A

CONTACTOR PILOT RELAY 46, 47, 48, 42

TIMING RELAY 53

TIMING AUXILIARY RELAY 48, 68

INTER LOCK RELAY 64, 67, 69, 52, 66

CHUTE BLOCK RELAY 48, 43

OVERLOAD TRIP RELAY (LATCHED) 40

EARTH LEAKAGE TRIP RELAY (LATCHED) 40

HOURS RUN COUNTER

CONTACTOR 2, 55, 67, 66, 67

MCC 2A — MCC 2A — MCC 2B

NOTE:
A TERMINAL REFERENCE SHOWN THUS MCC 4A3-21 REFERS TO TERMINAL 21 OF STAGE 3 OF MCC 4A.

SCHEMATIC DIAGRAM FOR MCC4A

32

THE DESIGN AND MANUFACTURING INFORMATION CONTAINED IN THIS DRAWING IS THE EXCLUSIVE RIGHT OF DEWHURST & PARTNER LTD. AND MUST NOT BE COPIED OR USED FOR MANUFACTURING PURPOSES.	ISSUE 1 2 3
KEY DIAG. No. —	DTX361AF/1 3
EXT. DIAG. No. RTX 361AF	
REL. DIAG. No.	DTX361AF/1
PANEL LAYOUT No. X3119325 (sh2)	

DRAWN BY — DATE 13/5/72 — CHECKED BY — APPROVED BY — DATE

REVISION:	REVISION:	REVISION:	REVISION: 2 ECONOMY RESISTORS ADDED.	REVISION: 1 STOP INTERLOCK CIRCUITS MODIFIED.
ORIGIN: / / SGD.	ORIGIN: / / SGD.	ORIGIN: / / SGD.	ORIGIN: 11/9/72 SGD	ORIGIN: W.D. 14/4/72 SGD. JS.

DEWHURST & PARTNER LTD.
MELBOURNE WORKS HOUNSLOW

TITLE: SCHEMATIC DIAGRAM FOR MCC4A
(AS GEC SCHEME X3119326)

ADMEL 4913