10713

PILOT RELAY 207,216

MAIN CONTACTOR 205,209, 210, 272

HOURS COUNTER

RUNNING

STOPPED

HAND INDICATION

TEST INDICATION

RUNNING INDICATION

TO DESK

To MCC 2B

DUST FILTER FAN DFF1 (n° 240) G1 DTX 361W/2

PILOT RELAY 277

MAIN CONTACTOR 273, 282, 283

ISOLATOR RELAY 278, 288, 290, 292

HAND RELAY 280, 285, 289, 291, 293

SLAVE RELAY 284, 287, 290, 292, 294, 296

MOTOR HEATER

MCC 4A

MCC 4B

DUST FAN DF1 (n° 260) G5 DTX 361W/3 194-231

PILOT RELAY 254, 261

MAIN CONTACTOR 252, 256, 257, 319

DUST FILTER FAN DFS (n° 237) G3 DTX 361W/1 163-175

PILOT RELAY 3011

MAIN CONTACTOR 297, 306, 307

ISOLATOR RELAY 286, 288, 290, 292

HAND RELAY 284, 288, 290, 292

SLAVE RELAY 238, 284, 288, 290, 292, 308

DUST FAN DF4 (n° 282) G4 DTX 361W/3 180-193

PILOT RELAY 347

MFF n°1 MAIN CONTACTOR 345, 350, 353, 392,

SLAVE RELAY 343, 355, 392

ISOLATOR RELAY 392

RUNNING

HOURS COUNTER

STOPPED

PULSE AIR

MILL FEED FAN N°1 D6

MFC N°1 MAIN CONTACTOR 342, 371, 372

SLAVE RELAY 355

MILL FEED COMPRESSOR N°1 D7

OVERLOAD LIGHT

PILOT SURGE BIN RELAY 384 385 390

MAIN FAN 382 387 388

RUNNING LIGHT

STOPPED LIGHT

SURGE BIN

DCR DUST UNIT FOR SURGE BINS RB 3+4

10713

DEWHURST & PARTNER LTD. MELBOURNE WORKS HOUNSLOW	TITLE: SCHEME FOR PANEL MCC 2A - SEAFORTH GRAIN TERMINAL	REVISION: ORIGIN: 1 1 SGD.	REVISION: ORIGIN: 1 1 SGD.	REVISION: ORIGIN: 1 1 SGD.	REVISION: 9 DUST PLANT NO 9 REMOVED. DCR UNIT SYSTEM ADDED LINE NOS 361 TO 377 10161/93GD. ws	REVISION: 6 REDRAWN ORIGIN: 5/4+1775GD.	DRAWN BY JS DATE 8/12/00 CHECKED BY APPROVED BY DATE

THE DESIGN AND MANUFACTURING INFORMATION CONTAINED IN THIS DRAWING IS THE EXCLUSIVE RIGHT OF DEWHURST & PARTNER LTD. AND MUST NOT BE COPIED OR USED FOR MANUFACTURING PURPOSES.

ISSUE: 7

DTX 361W/2

KEY DIAG. No.
EXT. DIAG. No.
REL. DIAG. No.
PANEL LAYOUT No.

DTX 361W/2

OF 4

GAF 1656/24