

C

[1] [3]


D



Piping contractor is responsible for final routing and supporting.


$$L_4$$

Degree of prefabrication to be decided by contractor.



PIPE SPOOLS

[2]



Bore	Thickness	Length	Insulation spec name
150	60mm	448mm	/PSK3704-6a-Prot-alum
25	30mm	22566mm	/PSK3704-6a-Prot-alum

		Hazardous CLP content		Legal protection must be secured by customer.					
Directive	2014/68/EU	Pipe Class	/I19440-VE16C1C-R00	Rev/ Revision Note		Created by	Checked by	Approved by	Date
Design press. (min)	-1bar	PED Category	I	0		J. Lakka	T. Saarinen	M. Kankkunen	5/5/2026
Design temp. (min)	-	Media		Site Tervasaari, Valkeakoski		Equipment Type Höyry- ja lauhdejärjestelmä		Equipment ID	
Max. allow. press. (PS)	-	Standard		Project Key TERFMS_N52654		Project Name Ter PM 5 Safe Future		Project Number N52654	Work
Operating press.	5.9bar	P&ID	RAUF00303	Projection Method Welding Symbols ISO 2553		General Tolerances ISO 13 920-BF ISO 2768-mK-E ISO 2768-mK-E ISO 2768-mK-E		Scale A1	Weight -
Operating temp	181degC	Design press	6bar	 This document is the exclusive intellectual property of Valmet Corporation and/or its subsidiaries (collectively and individually "Valmet") and is furnished solely for executing and maintaining the specific project. Re-use of the document for any other project or purpose is prohibited. The document or the information shall not be reproduced, copied or disclosed to any third party without the prior written consent of Valmet. By accessing this document, you accept these terms of use.					
PED Module	-	Design temp.	220degC	Title 50238-VLA-25-16C1B					
PED Group	-	Test press.	-						
Wind loads	-	Pipe list doc. ID	RAUAF04300	Status CERTIFIED		Document ID			Sheet 2 / 2
External loads	-	Valve list doc. ID	RAUAF04301	Security Classification Internal					Revision 0

For installation tolerances dimensions to be checked by pipe contractor at site
Degree of prefabrication to be decided by contractor.