

No.	Example	Description
(a)		LAD language
(b)		FBD language
(c)		Action block

Note:

If S8 is inactive, the impact is fed to the logic connected;
e.g. Q17.0 = 0 and M10.0 keeps its previous state.

Note:

The block “Comparator with Enable input“ applied above is a user defined Block (so called Function block) and Is not part of the basic operation pool of a PLC