

IS : 10553 (Part 2) - 1983

Indian Standard

REQUIREMENTS FOR
CHLORINATION EQUIPMENT

PART 2 VACUUM FEED TYPE CHLORINATORS

(First Reprint JANUARY 1993)

UDC 628.162.84.06

© Copyright 1983

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

Indian Standard

REQUIREMENTS FOR CHLORINATION EQUIPMENT

PART 2 VACUUM FEED TYPE CHLORINATORS

Public Health Engineering Equipment Sectional Committee,
BDC 40

Chairman

DR B. B. SUNDARESAN

Representing

National Environmental Engineering Research
Institute (CSIR), Nagpur

Members

SHRI R. PARAMASIVAM (*Alternate to*
Dr B. B. Sundaresan)

ADVISED (PHE)

DR S. R. SUKLA (*Alternate*)

SHRI S. V. BOPARDIKAR

SHRI R. C. P. CHAUDHARY
CHIEF ENGINEER

Ministry of Works & Housing, New Delhi

Directorate General of Technical Development,
New Delhi

Engineers India Limited, New Delhi

Department of Health, Government of West
Bengal, Calcutta

SHRI T. N. CHATTERJEE (*Alternate*)
CHIEF ENGINEER (WATER)

Municipal Corporation of Delhi, Delhi

SHRI JAI NARAIN (*Alternate*)

SHRI D. K. CHOUDHURY

SHRI D. R. MALL (*Alternate*)

SHRI S. K. DASGUPTA

Geo-Miller & Co, Calcutta

Calcutta Metropolitan Development Authority,
Calcutta

SHRI S. J. DUTTA (*Alternate*)
DY MUNICIPAL COMMISSIONER

Municipal Corporation of Greater Bombay,
Bombay

HYDRAULIC ENGINEER (*Alternate I*)

CHIEF ENGINEER (SEWERAGE)

(*Alternate II*)

SHRI B. R. N. GUPTA

Engineer-in-Chief's Branch, Army Headquarters,
New Delhi

SHRI K. V. KRISHNAMURTHY
(*Alternate*)

Continued (on page 2)

© Copyright 1983

BUREAU OF INDIAN STANDARDS

This publication is protected under the *Indian Copyright Act* (XIV of 1957) and reproduction in whole or in part by any means except with written permission of the publisher shall be deemed to be an infringement of copyright under the said Act.

(Continued from page 1)

<i>Members</i>	<i>Representing</i>
SHRI S. P. JAMES	Local Administration & Social Welfare (F) Department, Trivandrum
SHRI R. KRISHNASWAMY	Tamil Nadu Water Supply & Drainage Board, Madras
SHRI S. A. JAGDESAN (<i>Alternate</i>)	
SHRI M. Y. MADAN	The Hindustan Construction Co Ltd, Bombay
SHRI C. E. S. RAO (<i>Alternate</i>)	
SHRI S. R. MAJUMDAR	Paterson Engineering Co (India) Ltd, Calcutta
SHRI A. R. MIR	Public Health Engineering Department, Govern- ment of Jammu & Kashmir, Srinagar
SHRI G. M. KANTH (<i>Alternate</i>)	
SHRI S. S. NAIK	Hydraulic & General Engineers Pvt Ltd, Bombay
SHRI D. R. KENKRE (<i>Alternate</i>)	
SHRI R. NATARAJAN	Hindustan Dorr-Oliver Ltd, Bombay
SHRI B. M. RAHUL (<i>Alternate</i>)	
SHRI M. M. PATEL	Indian Water Works Association, Bombay
PROF S. SUBHA RAO	All India Institute of Hygiene & Public Health, Calcutta
SHRI A. V. RAO (<i>Alternate</i>)	
REPRESENTATIVE	Public Health Engineering Department, Govern- ment of Punjab, Chandigarh
REPRESENTATIVE	Public Health Engineering Department, Govern- ment of Haryana, Chandigarh
SHRI K. K. GANDHI (<i>Alternate</i>)	
SHRI T. P. SHARMA	M. P. State Prevention and Control of Water Pollution Board, Bhopal
DR G. K. KHARE (<i>Alternate</i>)	
SHRI S. S. SRIVASTAVA	Uttar Pradesh Jal Nigam, Lucknow
SHRI S. A. SWAMY	The Institution of Engineers (India), Calcutta
SHRI P. S. TENDOLKAR	Candy Filters (India) Ltd, Bombay
SHRI C. L. SASTRI (<i>Alternate</i>)	
SHRI M. G. VAIDYA	Public Health Engineering Department, Govern- ment of Madhya Pradesh, Bhopal
SHRI V. VARDARAJAN	Madras Metropolitan Water Supply and Sewerage Board, Madras
SHRI S. DAIVAMANI (<i>Alternate</i>)	
SHRI G. RAMAN, Director (Civ Engg)	Director General, ISI (<i>Ex-officio Member</i>)
	<i>Secretary</i>
	SHRI A. K. AVASTHY Assistant Director (Civ Engg), ISI

Water Treatment Equipment Subcommittee, BDC 40 : 1

Convener

SHRI JAI NARAIN

Indian Water Works Association, Bombay

Members

SHRI K. R. SAHU (*Alternate to*
Shri Jai Narain)

(Continued on page 9)

Indian Standard

**REQUIREMENTS FOR
CHLORINATION EQUIPMENT**

PART 2 VACUUM FEED TYPE CHLORINATORS

0. FOREWORD

0.1 This Indian Standard (Part 2) was adopted by the Indian Standards Institution on 31 May 1983, after the draft finalized by the Public Health Engineering Equipment Sectional Committee had been approved by the Civil Engineering Division Council.

0.2 Vacuum feed type chlorination apparatus works according to indirect method where aqueous chlorine solution is prepared at site before delivering it to the water to be treated. The system is brought under vacuum by using high pressure water passing through the injector. The minimum pressure of the water depends upon the mixing equipment which may be 0.1 to 0.5 N/mm² according to the capacity of plant and depends also on the pressure that has to be overcome at the inlet. The quantity of the water should correspond to the solubility of chlorine gas in water.

NOTE — If the pressure of water exceeds 0.5 N/mm², pumping is necessary to regulate the required chlorine dose.

0.3 The chlorinators are made in different sizes with chlorine supply up to 50 kg/h.

0.4 Typical flow diagram of vacuum feed type chlorinator is shown in Fig. 1.

0.5 In formulating this standard assistance has been derived from the following:

TGL 11074-1961 Wasseraufbereitung Chlorgasgeräte : Betrieb, Aufstellung (Water treatment chlorine gas apparatus, operation installation) Deutsche Demokratische Republik,




FIG. 1 TYPICAL FLOW DIAGRAM OF VACUUM FEED TYPE CHLORINATOR

ONORM M 5879-1975 Anforderungen an chlorungsanlagen und—
geräte Zur Wasserbehand Lung. (Requirements for chlorine
plants and apparatus for treatment of water). Österreichisches
Normungsinstitut.

ONORM M 5879-1981 (Teil 1) Anforderungen an Chlorungsanlagen
Zur Wesser-behandlung. (Specification for chlorination plants for
water treatment, gas chlorination equipment). Österreichisches
Normungsinstitut.

0.6 In the formulation of this standard due weightage has been given to international co-ordination among the standards and practices prevailing in different countries in addition to relating it to the practices in the field in this country.

0.7 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS : 2-1960*. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

1. SCOPE

1.1 This standard (Part 2) lays down the requirements for materials of construction, types and performance requirements of vacuum feed type gaseous chlorinators.

*Rules for rounding off numerical values (*revised*).

2. TYPES

2.1 The chlorinators shall be of the following types:

- a) Wall mounted,
- b) Pedestal mounted, and
- c) Cylinder mounted.

3. APPARATUS

3.1 Vacuum feed type chlorination equipment is provided with the following:

- a) Chlorine gas stop valve in the tube connecting the chlorine gas container and chlorination apparatus;

In case of chlorination apparatus with several chlorine gas container connections, a stop valve shall be provided for each container;

- b) Pressure gauges, one for indicating the cylinder pressure and the other for delivery pressure;
- c) Filter for retaining solid impurities of chlorine gas before it enters the main units;
- d) A desiccator valve or non-return valve containing concentrated sulphuric acid or calcium chloride through which chlorine should pass to free it from moisture;
- e) Chlorine gas automatic closer (rapid closing valve) which closes when there is a reduction of vacuum due to stoppage of water supply;
- f) A compensating vacuum regulating valve to maintain a constant upstream pressure;
- g) A back pressure valve to maintain constant downstream pressure;
- h) Device for keeping constant the adjusted quantity of chlorine gas;
- j) Device for measuring the chlorine gas flow;

IS : 10553 (Part 2) - 1983

- k) Automatic switch device may be provided for shifting to a full chlorine gas container if a continuous chlorination has to be ensured;
- m) Stop valve and measuring device for the water passing through the injector;
- n) Injector for creating vacuum to control flow of gas from the main unit and for mixing chlorine gas with water prior to injection to main supply. The injector is either of fixed throat type, adjustable throat type or antisiphon fixed throat type;
- p) Safety device or non-return valve which prevents backflow of chlorine water in the main unit under adverse condition;
- q) Venting device which prevents the building up the pressure in the vacuum dozing apparatus. The vent line shall lead outside the building housing the chlorination equipment;
- r) Evaporators are provided in case liquid chlorine is to be withdrawn from tonne container;
- s) Chlorine gas pressure reducing valve, shut off valve and evaporator pressure relief system are provided where evaporators are used; and
- t) Diffusers for delivering the chlorine water solution into the main line (for dia exceeding 300 mm)/open channel.

4. MATERIALS

4.1 Main body of units should be fiber glass reinforced polyester in case of plants of large capacity (equipment with chlorine supply above 60 kg/h) and in smaller plants, the main body of units may be of rigid PVC.

4.2 The injector should be of chlorine resistant PVC, bronze, hard rubber in cast iron or ebonite body with renewable nozzle and throat.

4.3 All the metal parts inside the main body coming in contact with chlorine shall be made of corrosion resistant material, such as silver plated brass, monel, nickel or silver.

4.4 The pipeline for carrying dry chlorine or liquid chlorine under pressure should be either phosphorus dioxide non-arsenical copper conforming to IS : 191 (Part 8)-1980* phosphorous dioxide arsenical copper

*Specification for copper (*third revision*).

conforming to IS : 191 (Part 10)-1980* or carbon steel conforming to IS : 1030-1974†.

NOTE — Minimum wall thickness for tubes is recommended below :

	<i>Outside Diameter</i> (mm)	<i>Min Wall Thickness</i> (mm)	<i>Tolerances</i> (mm)
Copper tubes	Up to 5	0.8	± 0.08
	Above 5 to 12	1.0	± 0.10
	Above 12 to 20	1.2	± 0.10
Carbon steel	Up to 20	2.5	± 0.10
	Above 20 to 30	3.0	± 0.15
	Above 30 to 40	3.2	± 0.20

4.5 For carrying moist chlorine, the pipelines should be made of silver, platinum, corrosion resistance alloy steel conforming to grade 19 of IS : 3444-1978‡, HDEP conforming to IS : 4984-1978§ or UPVC conforming to IS : 4985-1981||.

4.6 Diaphragm of gauges should be of silver and body should be of cast iron alloy, finished in enamel, brass or aluminium alloy. The dial and the pointer should be of anodised aluminium.

4.7 Diaphragm of valves should be of teflon silver, or bronze or steel backed with silver or teflon foil.

4.8 Filter for retaining impurities of chlorine gas should be of silvered metal with renewable glass wool insert.

4.9 Flowmeter tube should be of borosilicate glass.

4.10 Nuts, bolts and brackets should be of chromium plated brass or cadmium plated mild steel.

4.11 Gaskets and packings should be of bonded asbestos fibre or anti-mony lead (with 2 to 3 percent antimony).

5. OPERATION

5.1 With the start of water supply the entire system shall come under vacuum.

*Specification for copper (*third revision*).

†Specification for carbon steel castings for general engineering purposes (*second revision*).

‡Specification for corrosion resistant alloy steel and nickel based castings for general applications (*first revision*).

§Specification for high density polyethylene pipes for potable water supplies, sewage and industrial effluents (*second revision*).

||Specification for unplasticized PVC pipes for potable water supplies (*first revision*).

IS : 10553 (Part 2) - 1983

5.2 The built up valve in the main unit shall be able to reduce pressure.

5.3 Only after the system comes under vacuum the valve of the chlorine cylinder shall be opened slowly and then the rate of flow control valve in the unit shall be adjusted.

5.4 At the point of injection the chlorine water concentrate line should dip to about 1.5 m in the receiving tank.

6. CHLORINE REQUIREMENT

6.1 Rate of withdrawal of chlorine from container depends upon the size of container and the surrounding temperature. For guidance, Table 1 may be followed.

TABLE 1 RATE OF WITHDRAWAL OF CHLORINE FROM CONTAINER

TEMPERATURE °C	kg OF CHLORINE DISCHARGE PER DAY		
	Cylinders		Tonne Container
	45 kg	67 kg	
4	2.72	4.08	45
10	6.35	9.5	110
15	10.75	16.10	130
20	14.50	21.54	254
Above 27°	18.70	28.12	315

NOTE — If the discharge rate of chlorine is exceeded beyond the recommended rate, the liquid chlorine may freeze.

6.2 When the gas discharge rate from a single container does not meet the requirements, two or more containers can be connected to a manifold and discharge simultaneously. It is advisable not to couple more than four containers to a manifold.

6.2.1 When discharging through a manifold, all the containers shall be at the same temperature, particularly when connecting a new cylinder to the manifold.

6.2.2 When more than 3 cylinders are used, the connections should be arranged in groups so that one complete group can be changed at a time.

7. INSTALLATION AND SAFETY

7.1 For installation of the chlorination plant including handling, storage and safety of chlorine cylinder and drums IS : 10553 (Part 1)-1983* may be followed.

*Requirements for chlorination equipment : Part 1 General guidelines for chlorination plants including handling, storage and safety of chlorine cylinders and drums.

(Continued from page 2)

Members

SHRI R.R. BAGRI
DR A. G. BHOLE

DR S. M. DHABADGAONKAR
(Alternate)

SHRI D. K. CHOUDHURY

SHRI A. K. MAZUMDAR (Alternate)

SHRI M. M. DATTA

DR I. RADHAKRISHNAN (Alternate)

SHRI K. GOVINDAN NAIR

DR R. P. MATHUR

SHRI N. W. MIRCHANDANI

SHRI K. MOHAN

SHRI S. S. NAIK

SHRI D. R. KENKRE (Alternate)

SHRI R. NATARAJAN

SHRI B. M. RAHUL (Alternate)

SHRI R. PARAMASIVAM

SHRI N. G. SWARANKAR (Alternate)

SHRI N. RAMACHANDRAN

SHRI A. M. JOSHI (Alternate)

SHRI C. E. S. RAO

SHRI C. L. SASTRI

SHRI V. SATYAMUATHI

SHRI T. SUBRAHMANYAM (Alternate)

SHRI S. S. SRIVASTAVA

PROF S. SUBBA RAO

SHRI K. J. NATH (Alternate)

Representing

Clear Water Ltd, New Delhi

Visvesvaraya Regional College of Engineering,
Nagpur

Geo-Miller & Co Pvt Ltd, Calcutta

Central Public Health and Environmental
Engineering Organization, New Delhi

Public Health Engineering Department, Trivan-
drum

University of Roorkee, Roorkee

Municipal Corporation of Greater Bombay

Engineers India Ltd, New Delhi

Hydraulic & General Engineers (P) Ltd,
Bombay

Hindustan Dorr-Oliver Ltd, Bombay

National Environmental Engineering Research
Institute, Nagpur

Ion Exchange (India) Ltd, Bombay

The Hindustan Construction Co Ltd, Bombay

Candy Filters (India) Ltd, Bombay

EIMCO-KCP Ltd, Madras

Uttar Pradesh Jal Nigam, Lucknow

All India Institute of Hygiene & Public Health,
Calcutta

BUREAU OF INDIAN STANDARDS

Headquarters :

Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002

Telephones : 331 01 31

331 13 75

Telegrams : Manaksanstha

(Common to all Offices)

Regional Offices :

	Telephone
Central : Manak Bhavan, 9, Bahadur Shah Zafar Marg. NEW DELHI 110002	{ 331 01 31 331 13 75
* Eastern : 1/14 C.I.T. Scheme VII M, V.I.P. Road, Maniktola, CALCUTTA 700054	37 86 62
Northern : SCO 445-446, Sector 35-C, CHANDIGARH 160036	2 18 43
Southern : C.I.T. Campus, IV Cross Road, MADRAS 600113	41 29 16
† Western : Manakalaya, E9 MIDC, Marol, Andheri (East), BOMBAY 400093	6 32 92 95

Branch Offices :

'Pushpak', Nurmohamed Shaikh Marg, Khanpur, AHMADABAD 380001	2 63 48
† Peenya Industrial Area, 1st Stage, Bangalore-Tumkur Road, BANGALORE 560058	39 49 55
Gangotri Complex, 5th Floor, Bhadbhada Road, T.T. Nagar, BHOPAL 462003	55 40 21
Plot No. 82/83, Lewis Road, BHUBANESHWAR 751002	5 36 27
Kalai Kathir Building, 6/48-A Avanasi Road, COIMBATORE 641037	2 67 05
Quality Marking Centre, N.H. IV, N.I.T., FARIDABAD 121001	—
Savitri Complex, 116 G. T. Road, GHAZIABAD 201001	8-71 19 96
53/5 Ward No. 29, R.G. Barua Road, 5th By-lane, GUWAHATI 781003	3 31 77
5-8-56C L. N. Gupta Marg, (Nampally Station Road) HYDERABAD 500001	23 10 83
R14 Yudhister Marg, C Scheme, JAIPUR 302005	6 34 71
117/418 B Sarvodaya Nagar, KANPUR 208005	21 68 76
Plot No. A-9, House No. 561/63, Sindhu Nagar, Kanpur Road LUCKNOW 226005	5 55 07
Patliputra Industrial Estate, PATNA 800013	6 23 05
District Industries Centre Complex, Bagh-e-Ali Maidan, SRINAGAR 190011	—
T. C. No. 14/1421, University P. O., Palayam, THIRUVANANTHAPURAM 695034	6 21 04

Inspection Offices (With Sale Point) :

Pushpanjali, First Floor, 205-A West High Court Road, Shankar Nagar Square, NAGPUR 440010	52 51 71
Institution of Engineers (India) Building, 1332 Shivaji Nagar, PUNE 411005	5 24 35

*Sales Office Calcutta is at 5 Chowringhee Approach.
P. O. Princep Street, CALCUTTA 27 68 00

† Sales Office is at Novelty Chambers, Grant Road, BOMBAY 89 65 28

‡ Sales Office is at Unity Building, Narasimharaja Square,
BANGALORE 22 39 71