IS: 5600 - 1970 (Reaffirmed 1983)

# Indian Standard

# SPECIFICATION FOR SEWAGE AND DRAINAGE PUMPS

(Third Reprint NOVEMBER 1994)

UDC 621.67:628.336.23

© Copyright 1970

BUREAU OF INDIAN STANDARDS MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG NEW DELHI 1 10002

Association.

## Indian Standard

### SPECIFICATION FOR SEWAGE AND DRAINAGE PUMPS

Pumps Sectional Committee, EDC 35

Chairman

Representing

SHRI P. N. MENON

Best & Co Pvt Ltd. Madras

Members

SHRI K. SRINIVASAN ( Alternate to

Shri P. N. Menon )

Jyoti Ltd, Baroda

Indian

Calcutta

SHRI NANU B. AMIN

SHRI P. L. JAIN ( Alternate ) \*SHRI K. AROKAN

Engineering Association of India, Calcutta; and

SHRI A. C. GUPTA ( Alternate )

Engineering Association of India, Calcutta SHRI B. P. MITTAL ( Alternate ) Indian Pump Manufacturers Association, Calcutta Water Supply & Sewage Disposal Undertaking,

Pump Manufacturers

SHRI-BALWANT SINGH

Municipal Corporation of Delhi

SHRI M. M. PATEL ( Alternate ) Shri J. R. Bammi

LT-COL BHAGAT SINGH

Johnston Pumps India Ltd. Calcutta Department of Industries, Labour & Housing,

SHRIR. BARATAN

Government of Tamil Nadu Ministry of Transport & Aviation

SHRI A. CAVINATHAN CHIEF ELECTRICAL ENGINEER Bharat Heavy Electricals Ltd, Tiruchirapalli Northern Railway (Ministry of Railways)

SENIOR ELECTRICAL ENGI-NEER (M) ( Alternate ) GENERAL SUPERINTENDENT

SHRI JAGAN MOHAN

COL P. N. KAPOOR

Public Works, Workshops and Stores, Government of Tamil Nadu

SHRI M. A. JALIHAL SHRI S. G. PHATAR ( Alternate ) Central Equipment and Stores Procurement Organization. Government of Uttar Pradesh Kirloskar Brothers Ltd, Kirloskarvadi

MAJ B. S. MALHI ( Alternate ) SHRI R. KRISHNAMURTHY

Ministry of Defence (R&D)

SHRI P. M. NAIK

Neyveli Lignite Corporation Ltd, Neyveli Directorate of Industries, Government of Maharashtra

SHRI S. Y. TIPNIS ( Alternate ) SHRIK. S. PRABHAKAR

Directorate General of Technical Development, Ministry of Industrial Development, Internal Trade & Company Affairs

\*Shri K. Asokan is also alternate to Shri J. R. Bammi.

(Continued on page 2)

BUREAU OF INDIAN STANDARDS MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG **NEW DELHI 110002** 

#### (Continued from page 1)

Members

Representing

REPRESENTATIVE PROF K. SEETHARAMIAH Ministry of Food & Agriculture Indian Institute of Science, Bangalore Tata Chemicals Ltd, Mithapur

SHRI C. M. SHAH Tata (
SHRI B. T. DEVANATHAN (Alternate)

SHRI C. V. J. VARMA SHRI S. N. VOHRA

Central Board of Irrigation and Power
Directorate General of Supplies and Disposals,
Ministry of Foreign Trade & Supply

SHRI R. M. GANPULE ( Alternate )
SHRI M. V. PATANKAR, D

Director General, ISI (Ex-officio Member)

Director (Mech Engg)

Secretary

SHRI S. CHANDRASEKHARAN Deputy Director (Mech Engg), ISI

Special Purpose Pumps Subcommittee, EDC 35:5

Convener

SHRI M. A. JALIHAL

Kirloskar Brothers Ltd, Kirloskarvadi

Members

SHRI S. G. PHATAK ( Alternate to

Shri M. A. Jalihal)

D.C.M. Chemical Works, Delhi

SHRI S. K. BATRA

DR R. K. GUPTA ( Alternate )

British Electrical & Pumps Pvt Ltd, Calcutta

SHRI B. N. BHATTACHERJEE SHRI P. K. MUKHERJI ( Alternate )

SHRI S. K. GUHA

Century Rayon, Bombay

SHRI DURGESHCHANDRA ( Alternate )

KSB Pumps Ltd, Bombay

Shri H. J. Hanke

Jyoti Ltd, Baroda

SHRI P. L. JAIN
SHRI K. S. PATEL (Alternate)
SHRI B. P. MITTAL

Flowmore Pvt Ltd, New Delhi

SHRI K. G. SHARMA ( Alternate ) SHRI MAJEED MOHIUDDIN

Orient Paper Mills Ltd, Calcutta

SHRI J. P. MUKHERJEE

Walchand Nagar Industries Ltd, Poona

SHRI V. B. K. MURTHY

National Coal Development Corporation Ltd,

Ranchi

SHRI M. B. TAWADEY ( Alternate )

Seri S. T. Naik

Mather & Platt Ltd, Bombay

SHRI K. IYENGER ( Alternate )

Fertilizers and Chemicals Travancore Ltd, Kerala

SHRI V. S. PILLAI SHRI S. PADMANABHAN ( Alternate )

SHRIK, RAMANATHAN

Mettur Chemical and Industrial Corporation Ltd,

Mettur Dam

SHRI P. S. ROY

SERI N. M. SARAIYA

Bird & Co Pvt Ltd, Calcutta

PROF K. SEETHARAMIAH

Dorr-Olivar (India) Ltd, Bombay Indian Institute of Science, Bangalore

SHRI K. SRINIVASAN

Best & Co Pvt Ltd, Madras

(Continued on page 8)

## Indian Standard

# SPECIFICATION FOR SEWAGE AND DRAINAGE PUMPS

#### O. FOREWORD

- 0.1 This Indian Standard was adopted by the Indian Standards Institution on 25 March 1970, after the draft finalized by the Pumps Sectional Committee had been approved by the Mechanical Engineering Division Council.
- **0.2** Sewage and drainage pumps are used where sewage and other drainage from buildings is below sewer level and is to be taken into a sump and pumped or ejected from there into the sewer. These pumps are also used in cases where drainage cannot be taken care of by gravity flow.
- 0.3 The technical requirements for centrifugal and rotodynamic pumps covering wide range including definitions, units, classes and types of pumps, effect of viscosity, specific gravity and other effects on the performance of pumps, material of construction, salient design features, testing procedures, tolerances and guarantees are already included in IS:5120-1968\*.
- 0.4 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test, shall be rounded off in accordance with IS:2-1960†. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

#### 1. SCOPE

1.1 This standard specifies the technical requirements for rotodynamic pumps (such as centrifugal, axial, flow, etc) for handling sewage and other drainage.

### 2. UNITS, TERMINOLOGY AND CLASSIFICATION

2.1 Units, terminology and classification relating to pumps for handling sewage and other drainage shall be as specified in IS:5120-1968\*.

<sup>\*</sup>Technical requirements for rotodynamic special purpose pumps. (Since revised). †Rules for rounding off numerical values (revised).

#### 3. CHARACTERISTICS OF SEWAGE

3.1 Some typical characteristics of sewage are given below:

a) Total solids	1000 to 2	2200 ppm
b) Suspended solids	150 to	500 ppm
c) Four hours oxygen consumption	50 to	120 ppm
d) BOD (5 days 20°C)	150 to	450 ppm
e) Alkalinity	350 to	700 ppm
f) Chloride	120 to	300 ppm
g) Free nitrogen	15 to	45 ppm
h) Albuminoid nitrogen	4 to	40 ppm
j) pH value	6.8 to	7•9

#### 4. NOMENCLATURE

4.1 Nomenclature of the parts commonly used in sewage and drainage pumps shall be as given in IS:5120-1968\*.

#### 5. MATERIAL OF CONSTRUCTION

5.1 The typical materials of construction for sewage and drainage pumps are given below:

Sl No.	Material of Construction	Relevant Specification
1)	All cast iron fitted	Grade 20 of IS:210-1962†
2)	All stainless steel	Schedule V of IS: 1570-1961‡

Note — The materials of construction indicated above are merely for guidance and are not necessary to be considered as exhaustive.

#### 6. DIRECTION OF ROTATION

- 6.1 For rotodynamic pumps, the direction of rotation is designated as clockwise or anti-clockwise as observed when looking at the pump shaft from the driving end.
- 6.2 The direction of rotation shall be clearly marked either by incorporating an arrow in the casting or by a separate metal plate arrow securely fitted to the pump.

<sup>\*</sup>Technical requirements for rotodynamic special purpose pumps. (Since revised).

<sup>†</sup>Specification for grey iron castings (revised). (Since revised).

<sup>1</sup>Schedules for wrought steels for general engineering purposes.

#### 7. ACCESSORIES

- 7.1 The following shall constitute common accessories:
  - a) Vacuum pump if there is no positive suction,
  - \*b) Flanged sluice valve on suction side if there is positive suction,
  - \*c) Flanged sluice valve on delivery side,
  - \*d) Flanged reflux valve,
    - e) Pressure relief valve,
    - f) Coupling,
    - g) Pressure and vacuum gauge with siphon and cock,
    - h) Base plate,
    - j) Foundation bolts and nuts, and
    - k) Ball type air relief valve.
- 7.2 An automatic level operated control switch may be provided as an optional accessory.

#### 8. SUCTION LIMITATIONS

8.1 Suction limitations affecting the performance of the sewage and drainage pumps are the same as specified in IS:5120-1968†.

Note — It is always desirable for sewage pumps to operate with positive head on suction or with flooded suction. If the pumps operate with a suction lift, there is a possibility of the gases contained in the sawage being given off resulting in vapour lock and ultimate failure of the pumps.

#### 9. FACTORS AFFECTING PUMP PERFORMANCE

9.1 Factors affecting the pump performance are the same as those specified in IS:5120-1968†.

#### 10. ESSENTIAL DESIGN FEATURES

- 10.1 The pumps shall have suitable features properly designed to ensure satisfactory performance. In particular design features, such as the following shall be incorporated:
  - a) The size of solids should at least be up to 80 percent of the outlet width of the impeller;
  - b) Casing and impeller should be so designed as to allow free passage of the specified maximum size of solids;

<sup>\*</sup>Optional.

<sup>†</sup>Technical requirements for rotodynamic special purpose pumps. (Since revised).

#### IS: 5600 - 1970

- c) Hand holes should be provided in the casing, one to allow early access to the impeller eye, and one as close as possible to the casing throat; and
- d) On account of the abrasive nature of sewage, provision should be made on the stuffing boxes to ensure clear water supply or grease lubrication to the glands shall be provided from external sources according to the discretions of the manufacturer.

# 11. INFORMATION TO BE SUPPLIED BY THE PURCHASER AND THE SUPPLIER

11.1 The information to be supplied by the purchaser and the supplier shall be as specified in IS:5120-1968\*.

#### 12. PUMP TESTS

12.1 Pump tests shall be the same as those specified in IS:5120-1968\*.

#### 13. DETERMINATION OF PUMP PERFORMANCE

13.1 The determination of the performance of the sewage and drainage pumps shall be in accordance with the method specified in 14 of 1S:5120-1968\*.

#### 14. GUARANTEES

- 14.1 Guarantee of Workmanship and Material—The pumps shall be guaranteed by the manufacturer against defects in material and workmanship, under normal use and service, for a period of at least one year.
- 14.2 Guarantee of Performance—The supplier shall indicate the working range of the pump and the efficiency of the pump shall be guaranteed to cover the performance of the pump under conditions varying therefrom or for a sustained performance for any period of time. If the purchaser so desires, the manufacturer shall guarantee the non-overload of the prime mover for variations in the head in the working range. In the case of pumps where acceptance cannot be conducted on the liquid for which the pump is designed, the manufacturer shall indicate the liquid performance of the pump based on the results of the tests conducted by him on the pump with water and interpolated as given in IS:5120-1968\*. However, in these cases, the manufacturer shall guarantee for the performance of the pumps with water for the specified range.

<sup>\*</sup>Technical requirements for rotodynamic special purpose pumps. (Since revised).

- 14.3 Unless specified otherwise, pump performance figures shall be deemed to be applicable for 4.5 m suction lift at mean sea level and at a water temperature of 30°C.
- 14.4 Suction lift is to be reduced for higher altitudes at the rate of 1.5 m for every 1000 m above mean sea level.

#### 15. TOLERANCES

- 15.1 In all commercial acceptance tests of pumps, a certain tolerance shall be allowed to the manufacturer on his guarantee to cover inaccuracies of the equations for discharge, errors of observation and unavoidable minor inaccuracies of the instruments employed.
- 15.2 A tolerance of  $\pm 2.5$  percent shall be permissible on the discharge. However, for small discharges up to 900 litres per minute, a tolerance of +2.5 percent or +24 litres per minute whichever is higher, is allowed while the negative tolerance of 2.5 percent is maintained.
- 15.3 The percentage pump efficiency shall be not less than the specified value by more than 2.5. This tolerance may be raised to 5 in case the prime mover does not get overloaded.

#### 16. GENERAL REQUIREMENTS

16.1 The general requirements covering the pumps for process water shall be as given in IS: 5120-1968\*.

<sup>\*</sup>Technical requirements for rotodynamic special purpose pumps. (Since revised).

(Continued from page 2)

#### Sewage and Drainage Pumps Panel, EDC 35:5/P-4

Convener

#### Representing

SHRI BALWANT SINGH

Water Supply & Sewage Disposal Undertaking, Municipal Corporation of Delhi

Members

DEPUTY ENGINEER ( MECHA-NICAL)
SHRI P. L. JAIN
SHRI K. S. PATEL ( Alternate )

SHRI M. A. JALIHAI.
SHRI S. G. PHATAK ( Alternate )

SHRI B. P. MITTAL

SHRI K. G. SHARMA (Alternate) SHRI S. T. NAIR SHRI K. IYENGER (Alternate)

SHRI K. SRINIVASAN SHRI A. N. SASTRY ( Alternate Superintending Engineer, Poona Public Health Circle, Poona

Ivoti Ltd, Baroda

Kirloskar Brothers Ltd, Kirloskarvadi

Flowmore Pvt Ltd, New Delhi

Mather & Platt Ltd, Bombay

Best Co Pvt Ltd, Madras

#### BUREAU OF INDIAN STANDARDS

Headquarters:			
Manak Bhavan, 9 Bahadur Shah Zafar Marg. NEW DELHI 1	1000	2	
Telephones: 331 01 31, 331 13 75  Telegrams: Ma ( Common to	anaks	ans	
Regional Offices:	Tele	pho	one
	(331 331		
*Eastern : 1/14 C. I. T. Scheme VII M, V. I. P. Road, Maniktoia, CALCUTTA 700054	` 36	24	99
Northern: SCO 445-446, Sector 35-C, CHANDIGARH 160036	13	18 16 24	41
Southern: C. I. T. Campus, MADRAS 600113	₹41	25 29	19
†Western: Manakalaya, E9 MIDC, Marol, Andheri (East), BOMBAY 400093	6 32	92	95
Branch Offices:			
'Pushpak', Nurmohamed Shaikh Marg, Khanpur, AHMADABAD 380001		63 63	
‡Peenya Industrial Area 1st Stage, Bangalore Tumkur Road BANGALORE 560058	(38   38	49 49	55 56
Gangotri Complex, 5th Floor, Bhadbhada Road, T. T. Nagar, BHOPAL 462003	` 6	67	16
Plot No. 82/83, Lewis Road, BHUBANESHWAR 751002 53/5, Ward No. 29, R.G. Barua Road, 5th Byelane, GUWAHATI 781003		36 31	
5-8-56C L. N. Gupta Marg ( Nampally Station Road ), HYDERABAD 500001		10	
R14 Yudhister Marg, C Scheme, JAIPUR 302005	16		32
117/418 B Sarvodaya Nagar, KANPUR 208005	{21 21		
Patliputra Industrial Estate, PATNA 800013	` 6	23	05
T.C. No. 14/1421. University P.O., Palayam TRIVANDRUM 695035	{6 {6	21 21	
Inspection Offices ( With Sale Point ):			
Pushpanjali, First Floor, 205-A West High Court Road, Shankar Nagar Square, NAGPUR 440010		51	
Institution of Engineers (India) Building, 1332 Shivaji Naga PUNE 411005	r, 5	24	35
*Sales Office in Calcutta is at 5 Chowringhee Approach, P. O. Prin. Street, Calcutta 700072	cep 2	7 68	00

Street, Calcutte 700072

<sup>†</sup>Sales Office in Bombay is at Novelty Chambers, Grant Road, 89 65 28 Bombay 400007

<sup>‡</sup>Sales Office in Bangalore is at Unity Building, Narasimharaja Square, 22 36 71 Bangalore 560002

#### AMENDMENT NO. 1 JULY 1994 TO

# IS 5600: 1970 SPECIFICATION FOR SEWAGE AND DRAINAGE PUMPS

[ Page 6, clause 10.1(c) ] — Substitute the following for the existing matter: 'Hand hole should be provided in the easing to access the easing throat to check clogging.'

(HMD 20)

Reprography Unit, BIS, New Delhi, India