

Indian Standard
METHOD OF TEST FOR TOUGHNESS
OF NATURAL BUILDING STONES

(Third Reprint AUGUST 1997)

UDC 691.21 : 620.178

© Copyright 1969

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

*Indian Standard***METHOD OF TEST FOR TOUGHNESS
OF NATURAL BUILDING STONES****Composition of Stone Sectional Committee, BDC 6***Chairman*

SHRI O. MUTHACHEN

*Representing*Central Public Works Department (Ministry of
Health, Family Planning, Works, Housing &
Urban Development)*Members*

SHRI G. C. DAS

SHRI M. K. GUPTA

DR IQBAT ALI

SHRI A. B. LINGAM (*Alternate*)

SHRI JACOB THOMAS

SHRI S. K. JOGLEKAR

National Test House, Calcutta

Himalayan Tiles and Marble Private Ltd, Bombay
Engineering Research Laboratory, Andhra Pradesh

Public Works Department, Government of Kerala

Central Public Works Department (Architectural
Wing) (Ministry of Health, Family Planning,
Works, Housing & Urban Development)

Makrana Marble & Stone Co, Makrana

The Hindustan Construction Co Ltd, Bombay

Public Works Department, Government of Rajasthan

Builders' Association of India, Bombay

Geological Survey of India, Calcutta

Institution of Engineers (India), Calcutta

Central Building Research Institute (CSIR), Roorkee

Ministry of Transport & Shipping (Roads Wing)

SHRI J. H. KABRA

SHRI V. S. KAMAT

SHRI KESHAWANAND SHARMA

SHRI S. KRISHNA IYER

SHRI V. S. KRISHNASWAMY

SHRI T. R. MEHANDRU

SHRI G. S. MEHROTRA

SHRI D. L. MOTWANI

SHRI K. H. PARIKH

Associated Stone Industries (Kotah) Ltd,
RamganjmandiSHRI J. S. SHAH (*Alternate*)

SHRI PREM SWARUP

Department of Geology & Mining, Government of
Uttar PradeshSHRI A. K. AGARWAL (*Alternate*)

SHRI RABINDER SINGH

National Buildings Organization (Ministry of Health,
Family Planning, Works, Housing & Urban
Development)DR A. V. R. RAO (*Alternate*)

SHRI SATJIT SINGH

SHRI H. SEETHARAMAIAH

SHRI M. L. SETHI

Dholpur Stone Co, Dholpur

Public Works Department, Mysore

Department of Geology and Mining, Government of
RajasthanSHRI Y. N. DAVE (*Alternate*)

SUPERINTENDING ENGINEER

Public Works Department, Government of Tamil
Nadu

(DESIGNS & MARINE WORKS)

(*Continued on page 2*)

(*Continued from page 1*)

Members

SHRI S. V. SURYANARAYANA

SHRI M. V. YOGI

SHRI K. N. SUBHA RAO (*Alternate*)

SHRI R. NAGARAJAN,
Director (Civ Engg)

Representing

Central Water & Power Commission (Ministry of
Irrigation & Power)

Engineer-in-Chief's Branch (Ministry of Defence)

Director General, ISI (*Ex-officio Member*)

Secretary

SHRI K. M. MATHUR

Assistant Director (Civ Engg), ISI

Indian Standard

METHOD OF TEST FOR TOUGHNESS OF NATURAL BUILDING STONES

0. FOREWORD

0.1 This Indian Standard was adopted by the Indian Standards Institution on 19 July 1969, after the draft finalized by the Stone Sectional Committee had been approved by the Civil Engineering Division Council.

0.2 The property of toughness of stone is resistance to failure under impact. Stones of low toughness are apt to fail when exposed to rough usage, as occurs on steps, flooring of factories, stores, warehouses, godown, etc. This standard provides a method for measuring toughness of stones.

0.3 In the formulation of this standard due weightage has been given to international co-ordination among the standards and practices prevailing in different countries in addition to relating it to the practices in the field in this country.

0.4 In reporting the results of a test or analysis made in accordance with this standard, if the final value, observed or calculated, is to be rounded off, it shall be done in accordance with IS:2-1960*.

1. SCOPE

1.1 This standard lays down the procedure for determination of toughness of natural building stones.

2. SAMPLING

2.1 The sample shall be selected by the purchaser or his authorized representative from the quarried stone or taken from the natural rock as described in 2.2 and 2.3 so as to represent a true average of the type or grade of stone under consideration.

2.2 Stone from Ledges or Quarries — The ledge or quarry face of the stone shall be inspected to determine any variation in different strata. Differences in colour and structure shall be observed. Separate samples of stone weighing at least 25 kg each of unweathered type shall be obtained

*Rules for rounding off numerical values (*revised*).

from all strata that appear to vary in colour and structure. Pieces that have been damaged by blasting shall not be included in the sample.

2.3 Field Stone and Boulders — A detailed inspection of the deposits of field stone and boulders, over the area where the supply is to be obtained, shall be made. The different kinds of stone and their condition in the various deposits shall be recorded. Separate samples shall be selected of all classes of stone that would be considered for use in construction as indicated by visual inspection.

2.4 When perceptible variations occur in the quality of rock, the purchaser shall select as many samples as are necessary for determining the range in properties.

3. TEST SPECIMENS

3.1 Test specimens shall be cylinders 25 mm long and 25 mm in diameter.

3.2 Three test specimens shall constitute a test set.

3.3 One set of specimens shall be drilled perpendicular and another parallel to the plane of structural weakness of the stone, if such plane is apparent. If such plane is not apparent one set shall be drilled at random.

3.4 The specimen shall be cut from the samples with core drills or in any other way which will not induce incipient fracture, but shall not be chipped or broken off with a hammer. After sawing, the ends of the specimens shall be ground plane with water and carborundum or emery, on a cast iron lap, until the cylinders are of the size mentioned in **3.1**.

3.5 The ends of the cylinders shall be plane surfaces at right angles to the axis of the cylinders.

4. APPARATUS

4.1 Toughness Testing Machine — The toughness test shall be carried out in a machine conforming essentially to the requirements described in Appendix A.

5. TEST PROCEDURE

5.1 The cylindrical test specimen shall be securely held in the anvil without rigid lateral support, and under the plunger in such a way that the centre of its upper surface shall, throughout the test, be tangential to the spherical end of the plunger at its lowest point. The hammer shall be given a free fall of 1 cm for the first blow; 2 cm for the second blow, and an increase of 1 cm fall for each succeeding blow until failure of the test specimen occurs.

6. REPORT OF THE TEST

6.1 The height of the blow at failure shall be the toughness of the specimen.

6.2 In cases when a plane of structural weakness is apparent, the individual and average toughness of the three specimens in each set shall be reported and identified.

6.3 The individual and average toughness of three specimens shall be reported when no plane of structural weakness is apparent.

6.4 Any peculiar condition of a test specimen which might effect the result, such as the presence of seams, fissures, etc, shall be noted and recorded with the test results.

A P P E N D I X A

(Clause 4.1)

REQUIREMENTS OF TOUGHNESS TESTING MACHINE

A-1. GENERAL

A-1.1 Any form of impact machine which will comply with the following essentials may be used in making the test.

- a) *Holding Device for Test Specimen* — A cast-iron anvil, weighing not less than 50 kg firmly fixed upon a solid foundation.
- b) *Striking Hammer* — A hammer weighing 2 kg arranged so as to fall freely between suitable guides.
- c) *Plunger* — A plunger made of hardened steel and weighing 1 kg arranged to slide freely in a vertical direction in a sleeve, the lower end of the plunger being spherical in shape with a radius of 1 cm.
- d) Means for raising the hammer and for dropping it upon the plunger from any specified height from 1 cm to not less than 75 cm and means for determining the height of the fall to approximately 1 mm.
- e) Means for holding the cylindrical test specimen securely in the anvil, without rigid lateral support, and under the plunger in such a way that the centre of its upper surface shall throughout the test, be tangential to the spherical end of the plunger at its lowest point.

BUREAU OF INDIAN STANDARDS

Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002

Telephones: 323 0131, 323 3375, 323 9402

Fax : 91 11 3234062, 91 11 3239399, 91 11 3239382

Telegrams : Manaksanstha
(Common to all Offices)

Telephone

Central Laboratory:

Plot No. 20/9, Site IV, Sahibabad Industrial Area, Sahibabad 201010

8-77 00 32

Regional Offices:

Central : Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002 323 76 17

*Eastern : 1/14 CIT Scheme VII M, V.I.P. Road, Manikola, CALCUTTA 700054 337 86 62

Northern : SCO 335-336, Sector 34-A, CHANDIGARH 160022 60 38 43

Southern : C.I.T. Campus, IV Cross Road, CHENNAI 600113 235 23 15

†Western : Manakalaya, E9, Behind Marol Telephone Exchange, Andheri (East), MUMBAI 400093 832 92 95

Branch Offices::

'Pushpak', Nurmohamed Shaikh Marg, Khanpur, AHMEDABAD 380001 550 13 48

‡Peenya Industrial Area, 1st Stage, Bangalore-Tumkur Road, BANGALORE 560058 839 49 55

Gangotri Complex, 5th Floor, Bhadbhada Road, T.T. Nagar, BHOPAL 462003 55 40 21

Plot No. 62-63, Unit VI, Ganga Nagar, BHUBANESHWAR 751001 40 36 27

Kalaikathir Buildings, 670 Avinashi Road, COIMBATORE 641037 21 01 41

Plot No. 43, Sector 16 A, Mathura Road, FARIDABAD 121001 8-28 88 01

Savitri Complex, 116 G.T. Road, GHAZIABAD 201001 8-71 19 96

53/5 Ward No.29, R.G. Barua Road, 5th By-lane, GUWAHATI 781003 54 11 37

5-8-56C, L.N. Gupta Marg, Nampally Station Road, HYDERABAD 500001 20 10 83

E-52, Chitaranjan Marg, C- Scheme, JAIPUR 302001 37 29 25

117/418 B, Sarvodaya Nagar, KANPUR 208005 21 68 76

Seth Bhawan, 2nd Floor, Behind Leela Cinema, Naval Kishore Road, LUCKNOW 226001 23 89 23

NIT Building, Second Floor, Gokulpat Market, NAGPUR 440010 52 51 71

Patliputra Industrial Estate, PATNA 800013 26 23 05

Institution of Engineers (India) Building 1332 Shivaji Nagar, PUNE 411005 32 36 35

T.C. No. 14/1421, University P. O. Palayam, THIRUVANANTHAPURAM 695034 6 21 17

*Sales Office is at 5 Chowringhee Approach, P.O. Princep Street, CALCUTTA 700072 27 10 85

†Sales Office is at Novelty Chambers, Grant Road, MUMBAI 400007 309 65 28

‡Sales Office is at 'F' Block, Unity Building, Narashimaraaja Square, BANGALORE 560002 222 39 71