



PRELIMINARY SCREENING MANUAL FOR C&I SOLAR PROJECTS IN THAILAND

Owner/User Information				
Category	Requirement	Requirement Satisfied		Supporting Document
Location	Areas surrounding Bangkok, Ayutthaya, Chonburi, Rayong, and other provinces [remote areas/southern coastal areas are prohibited].	Yes	No	Site Location and Coordinate
Electricity Distribution Company	MEA or PEA Network [IPP network area need additional evaluation].	Yes	No	One years worth of electricity bill data, the official permitted installed capacity statement (IPP Network)
Industry sector	【Shopping malls, markets, offices, schools, government buildings, and low-pollution or low-emission factories】 [High-pollution and high-corrosion industries such as ceramics, textiles, and chemicals are prohibited from entering]	Yes	No	Company Registration Certificate, Memorandum of Association (MOA), List of Shareholders (Bor.Jor.5)
Registered Capital	≥500 Million THB * Not required for non-profit organisations.	Yes	No	Company Registration Certificate, Memorandum of Association (MOA), List of Shareholders (Bor.Jor.5)
Years of Operation	≥3 Years *If new factory, need to confirm investor financial capability, whether endorsed by the Group Company	Yes	No	Company Registration Certification, and relevant evidence

Technical and Construction Indicators				
Category	Requirement	Requirement Satisfied		Supporting Document
Land/Factory Ownership	The landowner, building owner, and electricity user must be the same entity	Yes	No	Chanote Title Document
Factory Leasehold	Lease Term ≥ 15 Years, aligned with the PPA term in IRR projection	Yes	No	Land Lease Agreement
Building Compliance	Must: Complete building permit approval documents, Optional: structural drawings, roof structure drawings, and roof plan are available	Yes	No	Provide complete and signed drawings with the engineer's stamp
Electrical Drawings	A clear electrical single-line diagram is available	Yes	No	Company/Factory Electrical SLD Diagram
Roof Type	Roofing material shall be corrugated steel or concrete roof (asbestos/plastic materials are	Yes	No	Clear Roof photos
Roof Condition	Roof condition must be good and unobstructed; corrugated steel roofs must be free of rust or have only minor rust, and concrete roofs must be structural suitable.	Yes	No	Clear Roof photos
Ground or Floating Installation	The enduser must be the landowner.	Yes	No	Chanote Title Document or Leasing Agreement
Projected Installation Capacity (DC)	≥100kWp	Yes	No	Preliminary Solar Panel Layout Diagram
Energy Storage Requirement	Optional: Does the owner require battery energy storage?	Yes	No	Customer intent documents/email/MOU

Electricity Usage Pattern	Solar system is for self-consumption only	Yes	No	Customer intent documents/email
Forecasted PV Energy Self-Consumption Rate	$\geq 80\%$	Yes	No	Customer intent documents/email, at least one year worth of monthly electricity consumption/bills and electricity load data
Estimated Yearly Electricity Generation	PVsyst report is available	Yes	No	PVsyst Report
PR Value	System PR value $\geq 80\%$.	Yes	No	PVsyst Report

Financial Indicators				
Category	Requirement	Requirement Satisfied		Supporting Document
PPA Agreement Term	PPA Term ≥ 15 Years	Yes	No	Customer intent documents/email
Electricity Price Discount	$\leq 30\%$	Yes	No	Customer intent documents/email
Self-Consumption Rate	$\geq 80\%$	Yes	No	Load curve and electricity usage analysis report
Estimated Project IRR	$\geq 12\%$	Yes	No	Financial and IRR Calculation report