

MCS-4 Diagnosticsbericht

Erstellt: 2026-07-04 18:47:33

Software version: 2.4

Modus: Simulator | COM-Port:

Zusammenfassung

- Dekodierte Telegrams: 695
- Bytes empfangen/erzeugt: 5560
- Sensors in dashboard: 5
- Aktive Alarms: 5

Sensor Overview

ID	Sensor	Value	Unit	Status	Alarm	Min	Max	Zeit
1	Messpunkt 1 P3L0	81.40	°C	ALARM	Messpunkt 1 P3L0: 81.40 °C outside alarm limit	79.00	99.00	18:47:28
2	Messpunkt 2 P1L1	5.00	bar	ALARM	Messpunkt 2 P1L1: 5.00 bar outside alarm limit	5.00	5.40	18:47:28
3	Messpunkt 3 P8L0	1430.00	rpm	ALARM	Messpunkt 3 P8L0: 1430.00 rpm outside alarm limit	1420.00	1540.00	18:47:28
4	Messpunkt 4 P3L0	76.50	°C	ALARM	Messpunkt 4 P3L0: 76.50 °C outside alarm limit	76.50	81.50	18:47:28
5	Messpunkt 5 P4L0	465.00	°C	ALARM	Messpunkt 5 P4L0: 465.00 °C outside alarm limit	452.00	468.00	18:47:28

Aktive Alarms

- Messpunkt 1 P3L0: 81.40 °C outside alarm limit
- Messpunkt 2 P1L1: 5.00 bar outside alarm limit
- Messpunkt 3 P8L0: 1430.00 rpm outside alarm limit
- Messpunkt 4 P3L0: 76.50 °C outside alarm limit
- Messpunkt 5 P4L0: 465.00 °C outside alarm limit

Hinweis

The MCS-4 decoder is currently an extendable base decoder. Full word-type and scaling logic is being completed step by step using the MCS-4 documentation.