



Care Net Consultants (Pty) Ltd
Reg no: 2012 / 038468 / 07
VAT no: 4620265191

 www.carenetconsultants.co.za
 +27 60 070 2723
 salesdesk@carenetconsultants.co.za
 154 Allan Road, Midrand 1684



EXAMPLE DOCUMENT. Dralenko Kitchens Manufacturing (Pty) Ltd is a fictitious company. Every company, person, address, date, figure and reference number in this example is made up; only the Care Net letterhead and any public emergency number are real. For guidance only; not a document to sign or rely on.

Example for a Health and Safety File, Section F: Registers and inspections

Ladder and Portable Electrical Equipment Inspection Register

Dralenko Kitchens Manufacturing, Hamilton factory, Bloemfontein. Register for the second quarter of 2026

About this example	Detail
Company in the example	Dralenko Kitchens Manufacturing (Pty) Ltd, a fictitious company
Where it is filed	Section F: Registers and inspections
Published by	Care Net Consultants, as guidance for companies building a Health and Safety File

How to use this example


This example shows the form and content Care Net recommends for this document in a Health and Safety File. Adapt it to your company, your sites and your appointments; your registered Health and Safety practitioner confirms it before your File is released. Not legal advice.

Contents

1. Register details
2. How the register works
3. Monthly inspection rounds
4. Ladders: exceptions and sample entries
5. Portable electrical equipment: exceptions and sample entries
6. Review



YOUR PARTNER IN WORKPLACE HEALTH.



Ladder and Portable Electrical Equipment Inspection Register


Dralenko Kitchens Manufacturing, Hamilton factory, Bloemfontein. Register for the second quarter of 2026

1. Register details

Item	Detail
Site	Hamilton factory, 14 Kiewiet Street, Hamilton, Bloemfontein (fictitious address)
Equipment covered	Portable ladders and step ladders; portable electrical tools and extension leads used in the workshop and assembly bays
Appointed inspector	Pieter Botha, Maintenance Supervisor, appointed in writing as the competent person for ladders and portable electrical equipment (appointment letter in Section B)
Inspection interval	Monthly, as the company's risk assessment sets, and before first use of any new or repaired item
Register kept by	Naledi Mokoena, Health and Safety Officer

2. How the register works

1. Every ladder and portable electrical item carries a unique number and a coloured inspection tag for the current month.
2. The inspector checks each item against the checklist for its type and records the result below on the day.
3. An item that fails is tagged **Do not use**, removed to the locked quarantine cage and recorded as an action until it is repaired or destroyed.
4. The Health and Safety Officer reviews the register monthly and reports open actions to the health and safety committee.



3. Monthly inspection rounds


Every ladder and portable electrical item in use was inspected on each monthly round. The round sheets, one line per item for each round, are filed behind this register.

Round	Ladders inspected	Portable electrical items inspected	Every item in use inspected
06/04/2026	6 of 6 (LAD 01 to LAD 06)	17 of 17 (PE 01 to PE 17)	Yes
04/05/2026	6 of 6 (LAD 03 replaced by LAD 07)	17 of 17	Yes
01/06/2026	6 of 6	17 of 17; one untagged item found and removed (PE 18)	Yes

4. Ladders: exceptions and sample entries

An extract from the round sheets: every failure, repair and new item, with a sample of the passed entries.

Date	Item no.	Description	By	Findings	Action and status
06/04/2026	LAD 01	Aluminium step ladder, 6 treads, assembly bay	P. Botha	Good condition; feet and locking stays intact	None. Green tag fitted
06/04/2026	LAD 02	Fibreglass extension ladder, 3,6 m, maintenance store	P. Botha	One rubber foot worn through	Tagged Do not use; foot replaced 08/04/2026; reinspected and passed 08/04/2026. Closed
06/04/2026	LAD 03	Wooden step ladder, paint store	P. Botha	Split in rear stile; not repairable	Destroyed 07/04/2026; replaced with LAD 07 (fibreglass). Closed
04/05/2026	LAD 01	Aluminium step ladder, assembly bay	P. Botha	Good condition	None. Yellow tag fitted
04/05/2026	LAD 07	Fibreglass step ladder, paint store (new)	P. Botha	Inspected before first use; good condition	Entered in register. Closed




Date	Item no.	Description	By	Findings	Action and status
01/06/2026	LAD 02	Fibreglass extension ladder, maintenance store	P. Botha	Good condition; label legible	None. Blue tag fitted

5. Portable electrical equipment: exceptions and sample entries

Date	Item no.	Description	By	Findings	Action and status
06/04/2026	PE 04	Angle grinder, 115 mm, workshop	P. Botha	Casing sound; plug and cable good; guard fitted	None. Green tag fitted
06/04/2026	PE 09	Extension lead, 20 m, assembly bay	P. Botha	Cable sheath cut near the plug; inner cores visible	Tagged Do not use; lead shortened and new plug fitted by the electrician 09/04/2026; reinspected and passed. Closed
06/04/2026	PE 12	Portable drill, assembly bay	P. Botha	Trigger switch sticks	Removed from use; sent for repair 07/04/2026; returned and passed 21/04/2026. Closed
04/05/2026	PE 15	Mobile earth leakage unit, workshop	P. Botha	Test button trips the unit correctly	None. Yellow tag fitted
01/06/2026	PE 09	Extension lead, 18 m after repair	P. Botha	Good condition	None. Blue tag fitted
01/06/2026	PE 18	Heat gun, paint store	P. Botha	No inspection tag; item brought from home by an employee	Removed from site 01/06/2026; toolbox talk on personal tools held 02/06/2026. Closed

6. Review

Quarter summary: three monthly rounds, on 06/04, 04/05 and 01/06/2026, each covering every ladder and portable electrical item in use: 69 inspections in all (23 items



on each round), plus the reinspections after repair and before first use. Four items failed and one untagged item was found and removed; all five actions were closed, the April actions by 21/04/2026 and the June action on the day it was found. No open actions at the end of June 2026. Reported to the health and safety committee meeting of 09/07/2026.

Appointed inspector

Pieter Botha, Date: 01/07/2026

Health and Safety Officer (register reviewed)

Naledi Mokoena, Date: 03/07/2026

End of the example. The company, people and records in it are fictitious; the cover page explains how to use it.



YOUR PARTNER IN WORKPLACE HEALTH.

