

Water Leakage Guide

Domain: INCIDENT_KNOWLEDGE | AssetBridge AI Knowledge Document

1. Immediate Safety Actions

Upon identifying an active water leak, prioritize life safety. If water is leaking near electrical outlets, ceiling lights, or distribution boards, immediately isolate the main electrical circuit breaker. Do not touch wet metal surfaces or standing water if energized.

2. Main Water Supply Isolation

Locate the primary stopcock or main water shut-off valve (typically located near the ground floor utility inlet, water meter, or overhead tank manifold). Turn the valve clockwise until firmly seated to stop the main supply. Open the lowest garden tap to relieve residual pipe pressure.

3. Common Leak Sources and Diagnostics

Common sources include broken PVC pipe joints, failed rubber washers on compression fittings, corroded galvanized iron pipes, loose flex hoses beneath sinks, and failed waterproofing membrane on flat slabs. Check pressure gauges and inspect joint seals for hairline cracking.

4. Temporary Containment & Evidence Gathering

Place catch basins or buckets under the drip path. Clear furniture and valuables from the damp perimeter. Capture at least 3 high-resolution timestamped photographs: wide perimeter view, close-up of the leaking joint/component, and secondary moisture stains.

5. Professional Inspection Escalation

Contact your designated AssetBridge local representative. For pressurized supply line bursts or concealed slab leaks, mandate a certified plumbing contractor inspection within 4 to 12 hours.