



MEMORANDUM

DATE : January 12, 2024
TO : Smartfuels Station Heads
CC : CEO / COO / HRD / Finance Dept. / Audit /Area Managers /
Asst. Area Supervisors
FROM : Operations Admin
SUBJECT : PRODUCT RECEIVING PROCESS

Ma-SWABENG buhay!

For guidance, see the Product Receiving Process:





STEPS	ACTIVITIES	SMART WAY	IN CHARGE	
			STATION	DRIVER
1	Guide the Lorry / Truck Driver	Ensure that there are no blockages in the Remote Fill Area	✓	
2	Instruct the Lorry Driver to Park Safely	Lorry on Hand break		✓
		Wheel Chocks (wooden type) must be in place		✓
		The Engine must be turned off		✓
		Ensure that the Lorry was parked safely	✓	
3	Place Fire Extinguisher and Warning Signs for Safety	Fire Extinguisher and safety cones must be in place	✓	
4	Check Documents	Check and Record the details	✓	
5	Measure the Underground Tanks	Accurate reading and must not overfill the tank capacity	✓	
6	Pump Reading	Accurate reading and must be recorded.	✓	
7	Inspect the Seals	Check the seals and make sure it was not tampered	✓	
8	Check the Ullage Marker	Ensure that the product touches the ullage marker. Use non-static flashlight if needed.	✓	
9	Attach the Ground Wire from the Lorry to the Ground Rod	To avoid “static” electricity accidents.		✓
10	Collect Sample Products	Get two (2) sample products per compartment.	✓	✓
		Conduct product-water testing	✓	
11	Connect the Hose from the Lorry to the Remote Fill and Start	Communication is important to avoid wrong product loading.		✓
12	Disconnect the Hose after the Discharge	Provide pail while disconnecting the hoses to avoid spillage.		✓
13	Inform the Driver to Move the Lorry Back and Forth or “CHA-CHA”	Guide the Driver	✓	
		“CHA-CHA”		✓
14	Inspect the Lorry to Ensure that the Compartment is Empty	Double check if the compartment is emptied.	✓	
15	Measure the Underground Tank to Compute the Quantity Received	Accurate reading and must be recorded.	✓	



16	Pump Reading	Reading must be recorded	✓	
17	Signing of Documents and Submit Product Delivery Reports	Fill-out all needed data on the product delivery report and sign all documents.	✓	
18	Guide the Lorry Driver	Guide-out to avoid accidents.	✓	

WATER CONTAMINATION TEST PROCESS:



1. Maglagay ng 50mL na produkto sa graduated cylinder galing sa sample bottle.
2. Haluan ng 50mL na tubig ang graduated cylinder.
3. Silipin ang level kung saan namagitan o naghiwalay ang produkto at tubig.
4. Kuhanan ng larawan at lagyan ng label (DC1-6U-51mLC-BS; DV1-6U-51mLC-BS).
5. I-shake ang mixture ng produkto at tubig at silipin ulit ang level.
6. Kuhanan ng larawan at lagyan ng label (DC1-6U-51mLC-AS; DV1-6U-51mLC-AS).
7. Tanggapin ang delivery kapag ang level ay nasa 50mL – 53mL. I-reject kapag ito ay umabot sa 55mL pataas.
8. Ulitin ang process #1 - #7 sa lahat ng sample bottles.

LEGEND:

DC1 – Dome Cover Compartment #1
DV1 – Discharge Valve Compartment # 1
6U – 6 is quantity; U is the product
 (D – Diesel; U – Regular; P – Premium)
51mLC – 51mL is the level; C stands for clear
BS – Before Shake
AS – After Shake

RECORDING OF BEGINNING AND ENDING INVENTORY USING AUTOMATIC GAUGING TANK (ATG)

1. Before receiving the product, the receiver **MUST** print an ATG reading as the Beginning Inventory Data.
2. When all product deliveries were received, wait for 20 minutes before printing an ATG reading as the final Ending Inventory Data. Thus, conduct also PUMP READING.
3. If the ATG auto-printed after receiving the products before the 20-minute timeframe, the data will be the “ESTIMATED” reading.
4. The “ESTIMATED” reading must be written into the Receiving Delivery Report and must be noted with “(EST)” besides the reading.
5. The “FINAL” reading, that is after the 20-minute time must be written to the Receiving Delivery Report for documentation.



This is also to remind our product receivers to indicate the TOTAL LITERS SOLD into the report while on the process of receiving the Wet Product Delivery.


For your information and immediate action. Any inquiries please look/ask Mr. Alvin Pablo (0976) 311-4589 or (0917) 630-4494. Thank you.

Prepared by:



Alvin Wesley A. Pablo
Asst. Retail Operations Manager

Approved by:



Roberto Dunga Jr.
Retail Operations Manager