

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
70	All work activities involving the pulling off cables	Cable Pulling Pedestrians and vehicles, Existing services, Collapse of trench/excavation, Cable trapped in duct, Cable comes loose from winch, Operatives Coming into contact with the winch rope, Unstable drum / winch, Ground Conditions	Employees, Other Contractors, Members of the Public	<ul style="list-style-type: none"> - All excavations in highway to be guarded in accordance with NRSWA guidelines (Red Book) and the necessary signage displayed. - Ensure ducts are cleared of debris prior to operations. - Ensure duct guides are fitted to mouth of duct. - Ensure stocking is correctly fitted to cable end. Drilled and shackle fitted prior to using the winch. - The winch must be sited within a protected area. - Emergency stop button must be tested and in working before operations commence. - All operatives must be instructed not to touch the rope whilst it is in motion. - Operatives must wear suitable gloves on all accessions whilst handling the winch rope. - Operatives must not stand between the winch and the line of cable pull 	Low

				<p>whilst the winch is in operation.</p> <p>Drum trailer/winch to be situated on firm ground.</p> <ul style="list-style-type: none"> - Firm base to be placed down if not available at site. - Clear and maintained clear trench. 	
--	--	--	--	---	--