

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
27	Carrying flammable Liquid / LPG or other fire generating substance with ability to cause fire.	Fire Flammable substance being released and catching fire	Employees, other contractors and public	<ul style="list-style-type: none"> - All flammable substances must be stored and secured in a safe manner. - Cylinders to be transported, stored and used in upright position. - If gas containers are carried in vehicle means of ventilation must be provided. - Vehicles will need appropriate extinguishers; as a minimum 2kg dry powder. - Some activities such as working with live gas require more extinguishers to be carried. - Extinguishers shall be securely mounted in an accessible and visible location. All extinguishers will have a thorough annual inspection by a competent person. - All vehicles carrying flammable liquids or LPG must display the appropriate hazardous signage. 	Low