

No	Activity	Hazard	Person(s) in Danger	Control Measures	Residual Risk Rating
39	All reinstatement activities involving the use of bitumen materials	<b>Working with Bitumen</b>  Burns, Inhalations	Employees, other contractors and public	<ul style="list-style-type: none"> <li>- Appropriate number of operatives trained to NRSWA standard.</li> <li>- Trained competent persons.</li> <li>- Operatives trained in use of equipment.</li> <li>- Ensure access is denied to unauthorised persons.</li> <li>- Ensure equipment is inspected visually before use.</li> <li>- Ensure boiler is positioned safely</li> <li>- Gas cylinder must be at least 3 metres away from boiler.</li> <li>- Do not overfill boiler or leave unattended.</li> <li>- Ensure lid is in place at all times to avoid possible water ingress.</li> <li>- Ensure adequate fire extinguishers available</li> <li>- Do not transport hot boiler with burner on. Appropriate Personal Protective Equipment provided and worn at all times.</li> <li>- Have available, and comply with the COSHH sheets for all substances used.</li> <li>- Suitable and sufficient first aid kit in the event of a burn.</li> </ul>	Low